

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 06 10 00 - Rough Carpentry.
- .2 Section 07 21 16 - Blanket Insulation.
- .3 Section 09 22 16 - Non-Structural Metal Framing.
- .4 Section 09 91 23 - Interior Painting.

1.2 REFERENCES

- .1 Aluminum Association (AA)
 - .1 AA DAF 45-03(R2009), Designation System for Aluminum Finishes.
- .2 ASTM International
 - .1 ASTM C475-02(2007), Standard Specification for Joint Compound and Joint Tape for Finishing Gypsum Board.
 - .2 ASTM C514-04(2009e1), Standard Specification for Nails for the Application of Gypsum Board.
 - .3 ASTM C557-03(2009)e1, Standard Specification for Adhesives for Fastening Gypsum Wallboard to Wood Framing.
 - .4 ASTM C840-08, Standard Specification for Application and Finishing of Gypsum Board.
 - .5 ASTM C954-07, Standard Specification for Steel Drill Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Steel Studs From 0.033 in. (0.84 mm) to 0.112 in. (2.84 mm) in Thickness.
 - .6 ASTM C1002-07, Standard Specification for Steel Self-Piercing Tapping Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Wood Studs or Steel Studs.
 - .7 ASTM C1047-09, Standard Specification for Accessories for Gypsum Wallboard and Gypsum Veneer Base.
 - .8 ASTM C1280-99, Standard Specification for Application of Gypsum Sheathing.
 - .9 ASTM C1177/C1177M-08, Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing.
 - .10 ASTM C1178/C1178M-08, Standard Specification for Glass Mat Water-Resistant Gypsum Backing Board.
 - .11 ASTM C1396/C1396M-09a, Standard Specification for Gypsum Wallboard.
- .3 Association of the Wall and Ceilings Industries International (AWCI)

- .1 AWCI Levels of Gypsum Board Finish-97.
- .4 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-71.25-M88, Adhesive, for Bonding Drywall to Wood Framing and Metal Studs.
- .5 Underwriters' Laboratories of Canada (ULC)
 - .1 CAN/ULC-S102-07, Standard Method of Test of Surface Burning Characteristics of Building Materials and Assemblies.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for gypsum board assemblies and include product characteristics, performance criteria, physical size, finish and limitations.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store gypsum board assemblies materials level in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Protect from weather, elements and damage from construction operations.
 - .3 Handle gypsum boards to prevent damage to edges, ends or surfaces.
 - .4 Replace defective or damaged materials with new.

1.5 AMBIENT CONDITIONS

- .1 Maintain temperature 10 degrees C minimum, 21 degrees C maximum for 48 hours prior to and during application of gypsum boards and joint treatment, and for 48 hours minimum after completion of joint treatment.
- .2 Apply board and joint treatment to dry, frost free surfaces.

- .3 Ventilation: ventilate building spaces as required to remove excess moisture that would prevent drying of joint treatment material immediately after its application.

Part 2 Products

2.1 MATERIALS

- .1 Standard gypsum board: to ASTM C1396/C1396M regular and Type X, thickness as indicated, 1200 mm wide x maximum practical length, ends square cut, edges tapered.
- .2 Drywall furring channels: 0.5 mm core thickness galvanized steel channels for screw attachment of gypsum board.
- .3 Resilient drywall furring: 0.5 mm base steel thickness galvanized steel for resilient attachment of gypsum board.
- .4 Nails: to ASTM C514.
- .5 Steel drill screws: to ASTM C1002.
- .6 Stud adhesive: to ASTM C557.
- .7 Laminating compound: as recommended by manufacturer, asbestos-free.
- .8 Casing beads, corner beads, control joints and edge trim: to ASTM C1047, metal, zinc-coated by hot-dip process, 0.5 mm base thickness, perforated flanges, one piece length per location.
- .9 Cornice cap: 12.7 mm deep x partition width, of 1.6 mm base thickness galvanized sheet steel, prime painted. Include splice plates for joints.
- .10 Shadow mould: 35 mm high, snap-on trim, of 0.6 mm base steel thickness galvanized sheet, white colour.
- .11 Sealants: in accordance with Section 07 92 00 - Joint Sealants.
- .12 Joint compound: to ASTM C475, asbestos-free.

Part 3 Execution

3.1 EXAMINATION

- .1 Verification of Conditions: verify conditions of substrates previously installed under other Sections or Contracts are acceptable for gypsum board assemblies installation in accordance with manufacturer's written instructions.

- .1 Visually inspect substrate in presence of Departmental Representative.
- .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
- .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 ERECTION

- .1 Do application and finishing of gypsum board to ASTM C840 except where specified otherwise.
- .2 Do application of gypsum sheathing to ASTM C1280.
- .3 Erect hangers and runner channels for suspended gypsum board ceilings to ASTM C840 except where specified otherwise.
- .4 Support light fixtures by providing additional ceiling suspension hangers within 150 mm of each corner and at maximum 600 mm around perimeter of fixture.
- .5 Install work level to tolerance of 1:1200.
- .6 Frame with furring channels, perimeter of openings for access panels, light fixtures, diffusers, grilles.
- .7 Install 19 x 64 mm furring channels parallel to, and at exact locations of steel stud partition header track.
- .8 Furr for gypsum board faced vertical bulkheads within and at termination of ceilings.
- .9 Furr above suspended ceilings for gypsum board fire and sound stops and to form plenum areas as indicated.
- .10 Install wall furring for gypsum board wall finishes to ASTM C840, except where specified otherwise.
- .11 Furr openings and around built-in equipment, cabinets, access panels, on four sides. Extend furring into reveals. Check clearances with equipment suppliers.
- .12 Furr duct shafts, beams, columns, pipes and exposed services where indicated.
- .13 Erect drywall resilient furring transversely across studs, spaced maximum 600 mm on centre and not more than 150 mm from ceiling/wall juncture. Secure to each support with 38 mm common nail 25 mm drywall screw.
- .14 Install 150 mm continuous strip of 12.7 mm gypsum board along base of partitions where resilient furring installed.

3.3 APPLICATION

- .1 Apply gypsum board after bucks, anchors, blocking, sound attenuation, electrical and mechanical work have been approved.
- .2 Apply single and double layer gypsum board to metal furring or framing using screw fasteners for first layer, screw fasteners for second layer. Maximum spacing of screws 300 mm on centre.
 - .1 Single-Layer Application:
 - .1 Apply gypsum board on ceilings prior to application of walls to ASTM C840.
 - .2 Apply gypsum board vertically or horizontally, providing sheet lengths that will minimize end joints.
 - .2 Double-Layer Application:
 - .1 Install gypsum board for base layer and exposed gypsum board for face layer.
 - .2 Apply base layer to ceilings prior to base layer application on walls; apply face layers in same sequence. Offset joints between layers at least 250 mm.
 - .3 Apply base layers at right angles to supports unless otherwise indicated.
 - .4 Apply base layer on walls and face layers vertically with joints of base layer over supports and face layer joints offset at least 250 mm with base layer joints.
- .3 Apply 12 mm diameter bead of acoustic sealant continuously around periphery of each face of partitioning to seal gypsum board/structure junction where partitions abut fixed building components. Seal full perimeter of cut-outs around electrical boxes, ducts, , in partitions where perimeter sealed with acoustic sealant.
- .4 Install ceiling boards in direction that will minimize number of end-butt joints. Stagger end joints at least 250 mm.
- .5 Install gypsum board on walls vertically to avoid end-butt joints. At stairwells and similar high walls, install boards horizontally with end joints staggered over studs, except where local codes or fire-rated assemblies require vertical application.
- .6 Install gypsum board with face side out.
- .7 Do not install damaged or damp boards.
- .8 Locate edge or end joints over supports. Stagger vertical joints over different studs on opposite sides of wall.

3.4 INSTALLATION

- .1 Erect accessories straight, plumb or level, rigid and at proper plane. Use full length pieces where practical. Make joints tight, accurately aligned and rigidly secured. Mitre and fit corners accurately, free from rough edges. Secure at 150 mm on centre .
- .2 Install casing beads around perimeter of suspended ceilings.
- .3 Install casing beads where gypsum board butts against surfaces having no trim concealing junction and where indicated. Seal joints with sealant.
- .4 Install insulating strips continuously at edges of gypsum board and casing beads abutting metal window and exterior door frames, to provide thermal break.
- .5 Install shadow mould at gypsum board/ceiling juncture. Minimize joints; use corner pieces and splicers. Construct control joints of preformed units set in gypsum board facing and supported independently on both sides of joint.
- .6 Locate control joints at changes in substrate construction and at approximate 10 m spacing on long corridor runs and at approximate 15 m spacing on ceilings.
- .7 Install control joints straight and true.
- .8 Construct expansion joints at building expansion and construction joints. Provide continuous dust barrier.
- .9 Install expansion joint straight and true.
- .10 Install cornice cap where gypsum board partitions do not extend to ceiling.
- .11 Fit cornice cap over partition, secure to partition track with two rows of sheet metal screws staggered at 300 mm on centre.
- .12 Splice corners and intersections together and secure to each member with 3 screws.
- .13 Install access doors to electrical and mechanical fixtures specified in respective sections.
 - .1 Rigidly secure frames to furring or framing systems.
- .14 Finish face panel joints and internal angles with joint system consisting of joint compound, joint tape and taping compound installed according to manufacturer's directions and feathered out onto panel faces.

- .15 Gypsum Board Finish: finish gypsum board walls and ceilings to following levels in accordance with AWCI Levels of Gypsum Board Finish:
 - .1 Levels of finish:
 - .1 Level 4: embed tape for joints and interior angles in joint compound and apply three separate coats of joint compound over joints, angles, fastener heads and accessories; surfaces smooth and free of tool marks and ridges.
- .16 Finish corner beads, control joints and trim as required with two coats of joint compound and one coat of taping compound, feathered out onto panel faces.
- .17 Fill screw head depressions with joint and taping compounds to bring flush with adjacent surface of gypsum board so as to be invisible after surface finish is completed.
- .18 Sand lightly to remove burred edges and other imperfections. Avoid sanding adjacent surface of board.
- .19 Completed installation to be smooth, level or plumb, free from waves and other defects and ready for surface finish.
- .20 Remove ridges by light sanding or wiping with damp cloth.

3.5 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day. Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.

3.6 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by gypsum board assemblies installation.

END OF SECTION

Part 1 General

1.1 RELATED SECTIONS

- .1 Section 07 21 16 - Blanket Insulation.
- .2 Section 09 21 16 - Gypsum Board Assemblies.

1.2 REFERENCES

- .1 American Society for Testing and Materials International,
 (ASTM).
 - .1 ASTM C645-00, Specification for Non-structural Steel
 Framing Members.
 - .2 ASTM C754-00, Specification for Installation of Steel
 Framing Members to Receive Screw-Attached Gypsum Panel
 Products.
- .2 Canadian General Standards Board (CGSB).
 - .1 CAN/CGSB-1.40-97, Primer, Structural Steel, Oil Alkyd
 Type.

1.3 QUALITY ASSURANCE

- .1 Test Reports: certified test reports showing compliance with
 specified performance characteristics and physical
 properties.
- .2 Certificates: product certificates signed by manufacturer
 certifying materials comply with specified performance
 characteristics and criteria and physical requirements.
- .3 Pre-Installation Meetings: conduct pre-installation meeting
 to verify project requirements, manufacturer's installation
 instructions and manufacturer's warranty requirements.

1.4 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with
 Section 01 74 21 - Construction/Demolition Waste Management
 And Disposal.
- .2 Remove from site and dispose of packaging materials at
 appropriate recycling facilities.
- .3 Divert unused metal materials from landfill to metal
 recycling facility approved by Departmental Representative.
- .4 Divert unused gypsum materials from landfill to recycling
 facility approved by Departmental Representative.

Part 2 Products

2.1 MATERIALS

- .1 Non-load bearing channel stud framing: to ASTM C645, stud size indicated, 20 gauge steel thickness, roll formed from galvanized steel sheet, for screw attachment of gypsum board. Knock-out service holes at 460 mm centres.
- .2 Floor and ceiling tracks: to ASTM C645, 20 gauge, in widths to suit stud sizes, 32 mm flange height.
- .3 Metal channel stiffener: 1.4 mm thick cold rolled steel, coated with rust inhibitive coating.
- .4 Steel Sheet: 1.5 mm thickness hot dipped galvanized steel sheet; welded to steel framing where indicated.
- .5 Acoustical sealant: Butyl; to Section 07 92 00.
- .6 Insulating strip: rubberized, moisture resistant 3 mm thick foam strip, width of track, with self sticking adhesive on one face, lengths as required.

Part 3 Execution

3.1 ERECTION

- .1 Align partition tracks at floor and ceiling and secure at 600 mm on centre maximum.
- .2 Install insulating strip under stud shoe tracks of partitions on slabs on grade.
- .3 Place studs vertically at 400 mm on centre and not more than 50 mm from abutting walls, and at each side of openings and corners. Position studs in tracks at floor and ceiling. Cross brace steel studs as required to provide rigid installation to manufacturer's instructions.
- .4 Erect metal studding to tolerance of 1:1000.
- .5 Attach studs to track using screws .
- .6 Co-ordinate simultaneous erection of studs with installation of service lines. When erecting studs ensure web openings are aligned.
- .7 Co-ordinate erection of studs with installation of door/window frames and special supports or anchorage for work specified in other Sections.
- .8 Provide two studs extending from floor to ceiling at each side of openings wider than stud centres specified. Secure

- studs together, 50 mm apart using column clips or other approved means of fastening placed alongside frame anchor clips.
- .9 Erect track at head of door/window openings and sills of sidelight/window openings to accommodate intermediate studs. Secure track to studs at each end, in accordance with manufacturer's instructions. Install intermediate studs above and below openings in same manner and spacing as wall studs.
 - .10 Frame openings and around built-in equipment, cabinets, access panels, on four sides. Extend framing into reveals. Check clearances with equipment suppliers.
 - .11 Provide 40 mm stud or furring channel secured between studs for attachment of fixtures behind lavatory basins, toilet and bathroom accessories, and other fixtures including grab bars and towel rails, attached to steel stud partitions.
 - .12 Install steel sheet welded to framing members where indicated; overlap steel sheet by 300 mm horizontally and one full framing space vertically.
 - .13 Install steel studs or furring channel between studs for attaching electrical and other boxes.
 - .14 Extend partitions to ceiling height except where noted otherwise on drawings.
 - .15 Maintain clearance under beams and structural slabs to avoid transmission of structural loads to studs. . Use double track slip joint .
 - .16 Install continuous insulating strips to isolate studs from uninsulated surfaces.
 - .17 Install two continuous beads of acoustical sealant and insulating strip under studs and tracks around perimeter of sound control partitions.

3.2 CLEANING

- .1 Upon completion of installation, remove surplus materials, rubbish, tools and equipment barriers.

END OF SECTION

Part 1 General

1.1 SECTION INCLUDES

- .1 Type CT ceramic wall tiling.

1.2 REFERENCES

- .1 American National Standards Institute (ANSI)/Ceramic Tile Institute (CTI)
 - .1 ANSI A108.1-99, Specification for the Installation of Ceramic Tile (Includes ANSI A108.1A-C, 108.4-.13, A118.1-.10, ANSI A136.1).
 - .2 CTI A118.3-92, Specification for Chemical Resistant, Water Cleanable Tile Setting and Grouting Epoxy and Water Cleanable Tile Setting Epoxy Adhesive (included in ANSI A108.1).
 - .3 CTI A118.4-92, Specification for Latex Cement Mortar (included in ANSI A108.1).
 - .4 CTI A118.5-92, Specification for Chemical Resistant Furan Resin Mortars and Grouts for Tile Installation (included in ANSI A108.1).
 - .5 CTI A118.6-92, Specification for Ceramic Tile Grouts (included in ANSI A108.1). American Society for Testing and Materials International (ASTM)
 - .6 ASTM C144-04, Specification for Aggregate for Masonry Mortar.
- .2 Canadian General Standards Board (CGSB)
 - .1 CGSB 71-GP-22M-78 (AMEND.), Adhesive, Organic, for Installation of Ceramic Wall Tile.
 - .2 CAN/CGSB-75.1-M88, Tile, Ceramic.
 - .3 CAN/CGSB-25.20-95, Surface Sealer for Floors.
- .3 Terrazzo Tile and Marble Association of Canada (TTMAC)
 - .1 Tile Specification Guide 09 30 00, Tile Installation Manual.
 - .2 Tile Maintenance Guide.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Provide product data in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Include manufacturer's information on:
 - .1 Ceramic tile, marked to show each type, size, and shape required.

- .2 Chemical resistant mortar and grout (Epoxy and Furan).
- .3 Cementitious backer unit.
- .4 Dry-set cement mortar and grout.
- .5 Divider strip.
- .6 Elastomeric membrane and bond coat.
- .7 Reinforcing tape.
- .8 Levelling compound.
- .9 Latex cement mortar and grout.
- .10 Commercial cement grout.
- .11 Organic adhesive.
- .12 Slip resistant tile.
- .13 Waterproofing isolation membrane.
- .14 Fasteners.
- .3 Provide samples in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Tile: submit duplicate, 300 x 300 mm sample panels of each colour, texture, size, and pattern of tile.
 - .2 Trim shapes, bullnose cap and cove including bullnose cap and base pieces at internal and external corners of vertical surfaces, each type, colour, and size.
 - .3 Adhere tile samples to 11 mm thick plywood and grout joints to represent project installation.

1.4 QUALITY ASSURANCE

- .1 Quality Assurance Submittals:
 - .1 Manufacturer's Instructions: manufacturer's installation instructions.
 - .2 Manufacturer's Field Reports: manufacturer's field reports specified.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

1.6 AMBIENT CONDITIONS

- .1 Maintain air temperature and structural base temperature at ceramic tile installation area above 12 degrees C for 48 hours before, during, and 48 hours after, installation.

- .2 Do not install tiles at temperatures less than 12 degrees C or above 38 degrees C.
- .3 Do not apply epoxy mortar and grouts at temperatures below 15 degrees C or above 25 degrees C.

1.7 MAINTENANCE

- .1 Extra Materials:
 - .1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
 - .2 Provide minimum 2% of each type and colour of tile required for project for maintenance use. Store where directed.
 - .3 Maintenance material same production run as installed material.

Part 2 Products

2.1 WALL TILE

- .1 Ceramic tile: to CAN/CGSB-75.1, glazed finish, large format;
 - .1 Size: 203 mm x 508 mm.
 - .2 Colour: As selected by Departmental Representative from full range.

2.2 TRIM SHAPES

- .1 Corners and Termination Trim: Stainless steel; provide trim shapes as follows where indicated.
 - .1 Quarter round shapes for external corners.
 - .2 Square shapes for edges and terminations.

2.3 BOND COAT

- .1 Latex Cement mortar: to ANSI A108.1, two-component universal thin-set mortar.

2.4 GROUT

- .1 Epoxy grout: to ANSI A108.1, having quality, colour and characteristics to match epoxy bond coat. Adhesive and grout by same manufacturer.

2.5 PATCHING AND LEVELLING COMPOUND

- .1 Cement base, acrylic polymer compound, manufactured specifically for resurfacing and leveling concrete floors. Products containing gypsum are not acceptable.
- .2 Have not less than the following physical properties:

- .1 Compressive strength - 25 MPa.
- .2 Tensile strength - 7 MPa.
- .3 Flexural strength - 7 MPa. Density - 1.9.
- .3 Capable of being applied in layers up to 50 mm thick, being brought to feather edge, and being trowelled to smooth finish.
- .4 Ready for use in 48 hours after application.

2.6 CLEANING COMPOUNDS

- .1 Specifically designed for cleaning masonry and concrete and which will not prevent bond of subsequent tile setting materials including patching and leveling compounds and elastomeric waterproofing membrane and coat.
- .2 Materials containing acid or caustic material are not acceptable.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 WORKMANSHIP

- .1 Do tile work in accordance with current TTMAC Tile Installation Manual except where specified otherwise.
- .2 Apply tile or backing coats to clean and sound surfaces.
- .3 Fit tile around corners, fitments, fixtures, drains and other built-in objects. Maintain uniform joint appearance. Cut edges smooth and even. Do not split tiles.
- .4 Maximum surface tolerance 1:800.
- .5 Make joints between tile uniform and approximately 1.5 mm wide, plumb, straight, true, even and flush with adjacent tile. Ensure sheet layout not visible after installation. Align patterns.
- .6 Lay out tiles so perimeter tiles are minimum 1/2 size.
- .7 Sound tiles after setting and replace hollow-sounding units to obtain full bond. Make internal angles square.

- .8 Allow minimum 24 hours after installation of tiles, before grouting.
- .9 Clean installed tile surfaces after installation and grouting cured.
- .10 Make control joints where indicated.

3.3 WALL TILE

- .1 Install in accordance with TTMAC Detail 304W.

3.4 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.

END OF SECTION

Part 1 General

1.1 SECTION INCLUDES

- .1 Type ACT acoustic panel ceilings.
- .2 Ceiling suspension system.

1.2 REFERENCES

- .1 American Society for Testing and Materials International (ASTM)
 - .1 ASTM C423-02a, Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method
 - .2 ASTM C635 - Manufacture, Performance, and Testing of Metal Suspension Systems for Acoustical Tile and Lay-in Panel Ceilings.
 - .3 ASTM C636 - Installation of Metal Ceiling Suspension Systems for Acoustical Tile and Lay-in Panels.
 - .4 ASTM E1264-98, Standard Classification for Acoustical Ceiling Products.
 - .5 ASTM E1477-98a(2003), Standard Test Method for Luminous Reflectance Factor of Acoustical Materials by Use of Integrating-Sphere Reflectometers.
- .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-92.1-M89, Sound Absorptive Prefabricated Acoustical Units.
- .3 Canadian Standards Association (CSA International)
 - .1 CSA B111-1974(R2003), Wire Nails, Spikes and Staples.
- .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .5 Underwriter's Laboratories of Canada (ULC)
 - .1 CAN/ULC-S102-2003, Surface Burning Characteristics of Building Materials and Assemblies.

1.3 SUBMITTALS

- .1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Provide product data in accordance with Section 01 33 00 - Submittal Procedures.

- .3 Submit duplicate full size samples of each type acoustical units.

1.4 QUALITY ASSURANCE

- .1 Regulatory Requirements:
 - .1 Fire-resistance rated floor/ceiling and roof/ceiling assembly: certified by Canadian Certification Organization accredited by Standards Council of Canada.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Protect on site stored or installed absorptive material from moisture damage.
- .2 Store extra materials required for maintenance, where directed by Departmental Representative.

1.6 ENVIRONMENTAL REQUIREMENTS

- .1 Permit wet work to dry before beginning to install.
- .2 Maintain uniform minimum temperature of 15 degrees C and humidity of 20 -40 % before and during installation.
- .3 Store materials in work area 48 hours prior to installation.

1.7 EXTRA MATERIALS

- .1 Provide extra materials of acoustic units in accordance with Section 01 78 00 - Closeout Submittals .
- .2 Provide acoustical units amounting to 2 % of gross ceiling area for each pattern and type required for project.
- .3 Ensure extra materials are from same production run as installed materials.
- .4 Clearly identify each type of acoustic unit, including colour and texture.
- .5 Deliver to Departmental Representative, upon completion of the work of this section.

Part 2 Products

2.1 MATERIALS

- .1 Acoustic Ceiling Tile: to ASTM E1264, for suspended ceiling system, 610 mm x 1220 mm size, square edge, cut to suit reflected ceiling plan layout:

- .1 Minimum Noise Reduction Coefficient (NRC) of 0.70.
 - .2 Minimum Ceiling Attenuation Class (CAC) rating 35.
 - .3 Minimum Light reflectance range of 0.80
 - .4 Colour: white.
- .2 Suspension System: Non-fire rated, intermediate duty system to ASTM C 635, commercial quality hot dipped galvanized rolled steel, 24 mm face, perimeter shadow moulding, standard white colour.
 - .3 Accessories: Stabilizer bars, clips, splices, perimeter mouldings with corner covers, hold down clips and as required for completed suspended grid system.
 - .4 Support Channels, Furring and Hangers: Galvanized steel; size and type to suit application and ceiling system flatness requirement specified.

Part 3 Execution

3.1 EXAMINATION

- .1 Do not install acoustical panels and tiles until work above ceiling has been inspected by Departmental Representative.

3.2 INSTALLATION

- .1 Install acoustical panels and tiles in ceiling suspension system.
- .2 Install suspension system in accordance with ASTM C636 and manufacturer's written instructions and as supplemented in this section.
- .3 Install system capable of supporting imposed loads to a deflection of 1/360 maximum.
- .4 Install after major above ceiling work is complete. Coordinate the location of hangers with other work.
- .5 Install hold-down clips to retain panels tight to grid system within 6 m of an exterior door.

3.3 APPLICATION

- .1 Install acoustic units to clean, dry and firm substrate.
- .2 Install acoustical units to reflected ceiling plan.
- .3 Scribe acoustic units to fit adjacent work. Butt joints tight, terminate edges with moulding.

3.4 INTERFACE WITH OTHER WORK

- .1 Co-ordinate ceiling work to accommodate components of other sections, such as light fixtures, diffusers, speakers, sprinkler heads, to be built into acoustical ceiling components.

END OF SECTION

Part 1 General

1.1 SECTION INCLUDES

- .1 Type RSF resilient, non-slip, sheet flooring.
- .2 Integral cove base.

1.2 REFERENCES

- .1 American Society for Testing and Materials International (ASTM)
 - .1 ASTM F1913-04(2014) - Standard Specification for Vinyl Sheet Floor Covering Without Backing.
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).

1.3 SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Submit documentation stating that the moisture content of the concrete slab and the pH of surface is within the flooring manufacturer's written guidelines.
 - .2 Submit a cut diagram indicating seam locations and roll direction. Use mitred seam layouts for corners when changing directions 180 degrees. Cut diagram must be reviewed prior to installation.
- .2 Provide product data in accordance with Section 01 33 00 - Submittal Procedures.
- .3 Provide samples in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Submit duplicate 300 x 300 mm sample pieces of sheet material, feature strips, edge strips.
- .4 Closeout Submittals:
 - .1 Provide maintenance data for resilient flooring for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.

1.5 AMBIENT CONDITIONS

- .1 Maintain air temperature and structural base temperature at flooring installation area above 20 degrees for 48 hours before, during and 48 hours after installation.

Part 2 Products

2.1 MATERIALS

- .1 Resilient Sheet Flooring: Slip retardant sheet flooring, urethane wearlayer with aluminum oxide aggregate;
 - .1 Pattern: Random repeat, reverse sheet for seaming.
 - .2 Thickness: 2.5 mm.
 - .3 Colour: selected by Departmental Representative.

2.2 ACCESSORIES

- .1 Flash Cove Accessories:
 - .1 Cove cap: Vinyl, colour selected by Departmental Representative.
 - .2 Cove stick: Plastic, minimum 19 mm radius.
- .2 Welding Rod: Welding rod as supplied by flooring manufacturer. Colour as selected by Departmental Representative.
- .3 Primers and adhesives: of types recommended by resilient flooring manufacturer for specific material on applicable substrate, above, on or below grade.
 - .1 Maximum VOC limit 60 g/L.
- .4 Sub-floor filler and leveller: as recommended by flooring manufacturer for use with their product.
- .5 Metal edge strips:
 - .1 Aluminum extruded, smooth, mill finish stainless steel with lip to extend under floor finish, shoulder flush with top of adjacent floor finish.
- .6 Edging to floor penetrations: stainless steel , type recommended by flooring manufacturer.
- .7 Floor Finish: type recommended by resilient flooring material manufacturer for material type and location.
 - .1 Maximum VOC limit 100 g/L.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 SITE VERIFICATION OF CONDITIONS

- .1 Ensure concrete floors are clean and dry by using test methods recommended by flooring manufacturer.

3.3 PREPARATION

- .1 Clean floor and apply filler; trowel and float to leave smooth, flat hard surface. Prohibit traffic until filler cured and dry.
- .2 Remove sub-floor ridges and bumps. Fill low spots, cracks, joints, holes and other defects with sub-floor filler.
- .3 Perform calcium chloride moisture testing of concrete floor slabs and certify to Departmental Representative that moisture levels are within manufacturer's range prior to installation of floor coverings.
- .4 Perform test for alkalinity and certify to Departmental Representative that pH levels are within manufacturer's range prior to installation of floor coverings.
- .5 Perform adhesive bond test and certify to Departmental Representative that results of bond test are acceptable.
- .6 Prime to resilient flooring manufacturer's printed instructions.

3.4 APPLICATION: FLOORING

- .1 Provide high ventilation rate, with maximum outside air, during installation, and for 48 to 72 hours after installation. If possible, vent directly to outside. Do not let contaminated air recirculate through district or whole building air distribution system. Maintain extra ventilation for at least one month following building occupation.
- .2 Apply adhesive uniformly using recommended trowel. Do not spread more adhesive than can be covered by flooring before initial set takes place.
- .3 Lay flooring with seams parallel to building lines to produce a minimum number of seams. Border widths minimum 1/3 width of full material.

- .4 Run sheets in direction of traffic.
- .5 Heat weld seams of sheet flooring in accordance with manufacturer's printed instructions.
- .6 As installation progresses, and after installation roll flooring with 45 kg minimum roller to ensure full adhesion.
- .7 Cut flooring around fixed objects.
- .8 Install feature strips and floor markings where indicated. Fit joints tightly.
- .9 Install flooring in pan type floor access covers. Maintain floor pattern.
- .10 Continue flooring over areas which will be under built-in furniture.
- .11 Continue flooring through areas to receive movable type partitions without interrupting floor pattern.
- .12 Terminate flooring at centreline of door in openings where adjacent floor finish or colour is dissimilar.
- .13 Install metal edge strips at unprotected or exposed edges where flooring terminates.

3.5 APPLICATION: FLASH COVE BASE

- .1 Set cove cap to 150 mm height above finished floor, level. Secure using brad nails or adhesive. Mitre inside and outside corners.
- .2 Set cove stick along wall junctions, Secure using adhesive. Mitre inside and outside corners.
- .3 Provide smooth transition at door casing and other areas by cutting back to the cove stick.
- .4 Use scribe and make scribing patterns. Dry fit sheet materials prior to installation to ensure accurate fit. Make seams tight.
- .5 Flash cove wall to floor junctions in accordance with manufacturer's written instructions.

3.6 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Remove excess adhesive from floor, base and wall surfaces without damage.

- .3 Clean, seal and wax floor and base surface to flooring manufacturer's printed instructions.

3.7 PROTECTION

- .1 Protect new floors until final inspection.
- .2 Prohibit traffic on floor for 48 hours after installation.

END OF SECTION

Part 1 General

1.1 SECTION INCLUDES

- .1 Type CPT modular carpet tile.
- .2 Type RB resilient base.

1.2 REFERENCES

- .1 ASTM International
 - .1 ASTM D1335-05, Standard Test Method for Tuft Bind of Pile Yarn Floor Coverings.
 - .2 ASTM D3936-05, Standard Test Method for Resistance to Delamination of the Secondary Backing of Pile Yarn Floor Covering.
- .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-4.2 No. 22-2004, Textile Test Methods - Colourfastness to Rubbing (Crocking).
 - .2 CAN/CGSB-4.2 No.27.6M-2004, Textile Test Methods - Flame Resistance - Methemine Tablet Test for Textile Floor Coverings.CAN/CGSB-4.2 No. 76-94/ISO 2551: 1981, Textile Test Methods - Machine-Made Textile Floor Coverings - Determination of Dimensional Changes Due to the Effects of Varied Water and Heat Conditions.
 - .3 CAN/CGSB-4.2 No.77.1-94/ISO 4919:2000, Textile Test Methods - Carpets - Determination of Tuft Withdrawal Force.
 - .4 CAN/CGSB-4.129-93(R1997), Carpets for Commercial Use.
- .3 Carpet and Rug Institute (CRI)
 - .1 CRI Carpet Installation Standard 2009.
 - .2 CRI Green Label Indoor Air Quality Testing Program.
 - .3 CRI Green Label Plus Indoor Air Quality Testing Program.
- .4 Health Canada / Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .5 National Floor Covering Association (NFCA)
 - .1 National Floor Covering Specification Manual 2007.
- .6 South Coast Air Quality Management District (SCAQMD), California State, Regulation XI. Source Specific Standards
 - .1 SCAQMD Rule 1113-A2007, Architectural Coatings.SCAQMD Rule 1168-A2005, Adhesives and Sealants Applications.
- .7 Underwriters' Laboratories of Canada (ULC)

- .1 CAN/ULC-S102-07, Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies.
- .2 CAN/ULC-S102.2-07, Standard Method of Test for Surface Burning Characteristics of Flooring, Floor Coverings and Miscellaneous Materials and Assemblies.

1.3 ADMINISTRATIVE REQUIREMENTS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for each carpet tile , adhesive , subfloor patching compound and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Samples:
 - .1 Submit for review and acceptance of each unit.
 - .2 Samples will be returned for inclusion into work. Submit duplicate samples of each type of carpet tile specified and duplicate tiles for each colour selected.
- .4 Certificates: submit product certificates signed by manufacturer certifying materials comply with specified performance characteristics and criteria and physical requirements.
- .5 Test and Evaluation Reports:
 - .1 Certified test reports showing compliance with specified performance characteristics and physical properties.
- .6 Manufacturer's Instructions: submit manufacturer's installation and storage instructions.
- .7 Qualification Statements:
 - .1 Compliance: to CAN/ULC-S102 and CAN/ULC-S102.2.
 - .2 Testing: passes testing requirements of:
 - .1 Green Label Plus Indoor Air Quality Testing Program.
 - .3 Tuft bind: meets requirements of CAN/CGSB-4.129 when tested to CAN/CGSB-4.2 No.77.1.

1.4 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.

- .2 Operation and Maintenance Data: submit operation and maintenance data for installed products for incorporation into manual.

1.5 MAINTENANCE MATERIAL SUBMITTALS

- .1 Extra stock materials in accordance with Section 01 78 00: deliver to Owner extra materials from same production run as products installed. Package products with protective covering and identify with descriptive labels.
 - .1 Quantity:
 - .1 Carpet tile: 10.

1.6 QUALITY ASSURANCE

- .1 Qualifications:
 - .1 Flooring Installer:
 - .1 Experienced in performing work of this Section who has specialized in installation of work similar to that required for this project.
 - .2 Must not sub-contract labour without written approval of Departmental Representative.
 - .3 Responsible for proper product installation, including floor testing and preparation as specified and in accordance with carpet manufacturer's written instructions.

1.7 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store materials protected from exposure to harmful weather conditions and at temperature conditions recommended by manufacturer.
 - .3 Store and protect carpet tile and adhesive in original containers or wrapping with manufacturer's seals and labels intact.
 - .4 Store and protect carpet tile and accessories in location as directed by Departmental Representative .

- .5 Store carpet and adhesive at minimum temperature of 18 degrees C and relative humidity of maximum 65% for minimum of 48 hours before installation.
- .6 Prevent damage to materials during handling and storage. Keep materials under cover and free from dampness.
- .7 Safety: comply with requirements of Workplace Hazardous Materials Information System (WHMIS) regarding use, handling, storage, and disposal of hazardous materials.
- .8 Replace defective or damaged materials with new.

1.8 SITE CONDITIONS

- .1 Ambient Conditions:
 - .1 Moisture: ensure substrate is within moisture limits and alkalinity limits recommended by manufacturer. Prepare moisture testing and provide report to Departmental Representative .
 - .2 Temperature: maintain ambient temperature of not less than 18 degrees C from 48 hours before installation to at least 48 hours after completion of work.
 - .3 Relative humidity: maintain between 10% and 65% for 48 hours before, during and 48 hours after installation.
 - .4 Ventilation:
 - .1 Ventilate enclosed spaces in accordance with Section 01 51 00 - Temporary Utilities. Provide fans with HEPA filters.
 - .2 Provide continuous ventilation during and after carpet application. Run ventilation system 24 hours per day during installation; provide continuous ventilation for 7 days after completion of carpet installation.
 - .5 Install carpet after space is enclosed and weatherproof, wet-work in space is completed and nominally dry, work above ceilings is complete.
- .2 Manufacturer's warranty: submit for Departmental Representative's acceptance, manufacturer's standard warranty document executed by authorized company official. Manufacturer's warranty is in addition to and does not limit other rights Owner may have under Contract Documents.
- .3 Warranty period: 1 year, commencing on date of substantial performance of work.
 - .1 Warranty covers labour and repair or replacement of defective components for 1 year after date of substantial performance.

Part 2 Products

2.1 CARPET TILE

- .1 Carpet Tile:
 - .1 Size: 1000 mm x 250 mm.
 - .2 Pattern: Tufted pattern loop.
 - .3 Yarn Type: 100% branded nylon with permanently conductive fibres.
 - .4 Performance:
 - .1 Electrostatic Propensity: Max 3000 volts to AATC 134-91.
 - .2 Delamination: Minimum 8.5 N/cm (5 lbs/inch) to ASTM D3936.
 - .3 Dimensional Stability: Max 0.2% to DIN STD 54318-AACHEN test.
 - .4 Toxicity: CRI Green Label Plus Certified.
 - .5 Maximum Flame Spread Rating: 300.
 - .6 Maximum Smoke Developed: Classification 500.
 - .5 Acceptable Product: Interface Net Effect Collection.

2.2 ACCESSORIES

- .1 Resilient base: Rubber, coved, minimum 1200 mm length and 100 mm high x 3 mm thick, including premoulded end stops and external corners for coved base only, of colour selected by Departmental Representative.
- .2 Carpet adhesive: water based or releasable pressure sensitive type adhesive, VOC limit 50 g/L maximum to SCAQMD Rule 1168.
- .3 Base adhesive: Type recommend by manufacturer, VOC limit 50 g/L maximum to SCAQMD Rule 1168.
- .4 Cementitious Underlayment: self-levelling and trowel grade, premixed, polymer-modified, containing no gypsum, not softened by water after final set. Minimum compressive strength 10 MPa at 8 hours and 20 Mpa at 7 days.
- .5 Underlayment Bond Coat: compatible with releasable pressure sensitive tile to substrate, 100 g/L maximum to SCAQMD Rule 1113.
- .6 Edge Strips:
 - .1 Vinyl:
 - .1 Beveled floor flange minimum 50 mm wide.
 - .2 Beveled surface to finish flush with carpet tile for tight joint and other side to floor finish.
 - .3 Colour: Selected by Departmental Representative.

Part 3 Execution

3.1 INSTALLERS

- .1 Use experienced and qualified technicians to carry out assembly and installation of tile carpet.

3.2 EXAMINATION

- .1 Examine conditions, substrates and work to receive work of this Section, co-ordinate with Section 01 71 00 - Examination and Preparation.
- .2 Verification of Conditions: verify conditions of substrates previously installed under other Sections or Contracts are acceptable for carpet tile installation in accordance with manufacturer's written instructions.
 - .1 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .2 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.3 PREPARATION

- .1 Subfloor Preparation:
 - .1 Inspect concrete and determine special care required to make it a suitable for carpet.
 - .2 Fill and level cracks 3 mm wide or protrusions over 0.8 mm with appropriate and compatible latex polymer fortified patching compound.
 - .3 Comply with manufacturer's written recommendations for maximum patch thickness.
 - .4 Prime large patch areas with compatible primer.
 - .5 Ensure concrete substrates are cured, clean and dry.
 - .6 Ensure concrete substrates are free of paint, dirt, grease, oil, curing or parting agents, and other contaminants, including sealers, that interfere with the bonding of adhesive.
 - .7 Where powdery or porous concrete surface is encountered, apply primer compatible with adhesive to provide a suitable surface for glue-down installation.
- .2 Surface Preparation: prepare surface in accordance with manufacturer's written recommendations and co-ordinate with Section 01 71 00 - Examination and Preparation.
 - .1 Prepare floor surfaces in accordance with CRI Carpet Installation Standard.
- .3 Tile Carpeting Preparation: Pre-condition carpeting: following manufacturer's written instructions.

3.4 INSTALLATION

- .1 Install carpet tiles in accordance with manufacturer's written instructions, and CRI Carpet Installation Standard and co-ordinate with Section 01 73 00 - Execution.
- .2 Co-ordinate tile carpeting work with work of other trades, for proper time and sequence to avoid construction delays.
- .3 Install carpet tile after finishing work is completed but before demountable office partitions and telephone and electrical pedestal outlets are installed.
- .4 Install carpet tile as per manufacturer's recommendation. This can include quarter-turn 90 degree format, monolithic, random, quarter turn ashlar, horizontal, herringbone or vertical ashlar.
- .5 Snugly join carpet tiles in completed installation.
 - .1 Measure distance covered by 11 carpet tiles (10 joints) and ensure distance is in compliance with manufacturer specifications.
 - .2 Do not trap yarn between carpet tiles.
- .6 Apply thin film of pressure-sensitive adhesive according to manufacturer's recommendations.
- .7 Ensure finished installation presents smooth wearing surface free from conspicuous seams, burring and other faults.
- .8 Use material from same dye lot.
 - .1 Ensure colour, pattern and texture match within visual areas.
 - .2 Maintain constant pile direction.
- .9 Fit around architectural, mechanical, electrical and telephone outlets, and furniture fitments, around perimeter of rooms into recesses, and around projections.
- .10 Install carpeting in pan type floor access covers.
- .11 Extend carpet tiles into toe spaces, door reveals, closets, open-bottomed obstructions, removable flanges, alcoves, and similar openings.
- .12 Install carpet tiles smooth and free from bubbles, puckers, and other defects.
- .13 Protect exposed carpet tile edges at transition to other flooring materials with suitable transition strips.
- .14 Install resilient base to manufacturer's written instructions.

3.5 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
 - .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
 - .1 Vacuum carpets clean immediately after completion of installation.

3.6 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Prohibit traffic on carpet for period of 24 hours minimum after installation and until adhesive is cured. Install carpet protection to satisfaction of Departmental Representative.
- .3 Repair damage to adjacent materials caused by tile carpeting installation.

END OF SECTION

Part 1 General

1.1 SUMMARY

- .1 Section Includes:
 - .1 Material and installation of site applied paint finishes to new interior surfaces, including site painting of shop primed surfaces.

1.2 REFERENCES

- .1 Department of Justice Canada (Jus)
 - .1 Canadian Environmental Protection Act (CEPA), 1999, c. 33
- .2 Environmental Protection Agency (EPA)
 - .1 EPA Test Method for Measuring Total Volatile Organic Compound Content of Consumer Products, Method 24 - 1995, (for Surface Coatings).
- .3 Health Canada / Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .4 Master Painters Institute (MPI)
 - .1 MPI Architectural Painting Specifications Manual, 2004.
- .5 National Fire Code of Canada - 2010
- .6 Society for Protective Coatings (SSPC)
 - .1 SSPC Painting Manual, Volume Two, 8th Edition, Systems and Specifications Manual.
- .7 Transport Canada (TC)
 - .1 Transportation of Dangerous Goods Act (TDGA), 1992, c. 34 .

1.3 QUALITY ASSURANCE

- .1 Qualifications:
 - .1 Contractor: minimum of five years proven satisfactory experience. Provide list of last three comparable jobs including, job name and location, specifying authority, and project manager.
 - .2 Journeymen: qualified journeymen who have "Tradesman Qualification Certificate of Proficiency" engaged in painting work.

- .3 Apprentices: working under direct supervision of qualified trades person in accordance with trade regulations.

1.4 SCHEDULING

- .1 Submit work schedule for various stages of painting to Departmental Representative for review. Submit schedule minimum of 48 hours in advance of proposed operations.
- .2 Obtain written authorization from Departmental Representative for changes in work schedule.
- .3 Schedule painting operations to prevent disruption of occupants.

1.5 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit product data and instructions for each paint and coating product to be used.
 - .2 Submit product data for the use and application of paint thinner.
 - .3 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures . Indicate VOCs during application and curing .
- .3 Samples:
 - .1 Submit full range colour sample chips to indicate where colour availability is restricted.
 - .2 Submit duplicate 200 x 300 mm sample panels of each finish with specified paint or coating in colours, gloss/sheen and textures required to MPI Architectural Painting Specification Manual standards submitted on following substrate materials:
 - .1 3 mm plate steel for finishes over metal surfaces.
 - .2 13 mm birch plywood for finishes over wood surfaces.
 - .3 50 mm concrete block for finishes over concrete or concrete masonry surfaces.
 - .4 13 mm gypsum board for finishes over gypsum board and other smooth surfaces.
 - .3 Retain reviewed samples on-site to demonstrate acceptable standard of quality for appropriate on-site surface.

- .4 Test reports: submit certified test reports for paint from approved independent testing laboratories, indicating compliance with specifications for specified performance characteristics and physical properties.
 - .1 Lead, cadmium and chromium: presence of and amounts.
 - .2 Mercury: presence of and amounts.
 - .3 Organochlorines and PCBs: presence of and amounts.
- .5 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .6 Manufacturer's Instructions:
 - .1 Submit manufacturer's installation and application instructions.
- .7 Closeout Submittals: submit maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals include following:
 - .1 Product name, type and use.
 - .2 Manufacturer's product number.
 - .3 Colour numbers.
 - .4 MPI Environmentally Friendly classification system rating.

1.6 MAINTENANCE

- .1 Extra Materials:
 - .1 Deliver to extra materials from same production run as products installed. Package products with protective covering and identify with descriptive labels. Comply with Section 01 78 00 - Closeout Submittals.
 - .2 Quantity: provide one - four litre can of each type and colour of primer stain finish coating. Identify colour and paint type in relation to established colour schedule and finish system.
 - .3 Delivery, storage and protection: comply with Departmental Representative requirements for delivery and storage of extra materials.

1.7 DELIVERY, STORAGE AND HANDLING

- .1 Packing, Shipping, Handling and Unloading:
 - .1 Pack, ship, handle and unload materials in accordance with Section 01 61 00 - Common Product Requirements and manufacturer's written instructions.
- .2 Acceptance at Site:

- .1 Identify products and materials with labels indicating:
 - .1 Manufacturer's name and address.
 - .2 Type of paint or coating.
 - .3 Compliance with applicable standard.
 - .4 Colour number in accordance with established colour schedule.
- .3 Remove damaged, opened and rejected materials from site.
- .4 Storage and Protection:
 - .1 Provide and maintain dry, temperature controlled, secure storage.
 - .2 Store materials and supplies away from heat generating devices.
 - .3 Store materials and equipment in well ventilated area with temperature range 7 degrees C to 30 degrees C.
- .5 Store temperature sensitive products above minimum temperature as recommended by manufacturer.
- .6 Keep areas used for storage, cleaning and preparation clean and orderly. After completion of operations, return areas to clean condition.
- .7 Remove paint materials from storage only in quantities required for same day use.
- .8 Fire Safety Requirements:
 - .1 Provide one 9 kg Type ABC dry chemical fire extinguisher adjacent to storage area.
 - .2 Store oily rags, waste products, empty containers and materials subject to spontaneous combustion in ULC approved, sealed containers and remove from site on a daily basis.
 - .3 Handle, store, use and dispose of flammable and combustible materials in accordance with National Fire Code of Canada requirements.

1.8 SITE CONDITIONS

- .1 Surface and Environmental Conditions:
 - .1 Apply paint finish in areas where dust is no longer being generated by related construction operations or when wind or ventilation conditions are such that airborne particles will not affect quality of finished surface.
 - .2 Apply paint to adequately prepared surfaces and to surfaces within moisture limits.
 - .3 Apply paint when previous coat of paint is dry or adequately cured.

- .2 Additional interior application requirements:
 - .1 Apply paint finishes when temperature at location of installation can be satisfactorily maintained within manufacturer's recommendations.
 - .2 Apply paint in occupied facilities during silent hours only. Schedule operations to approval of Departmental Representative such that painted surfaces will have dried and cured sufficiently before occupants are affected.

Part 2 Products

2.1 MATERIALS

- .1 Paint materials listed in the MPI Approved Products List (APL) are acceptable for use on this project.
- .2 Provide interior non-flat paint products with a VOC range <151 g/L.
- .3 Provide interior flat paint products with a VOC range <51 g/L.
- .4 Provide paint materials for paint systems from single manufacturer.
- .5 Conform to latest MPI requirements for interior painting work including preparation and priming.
- .6 Materials (primers, paints, coatings, varnishes, stains, lacquers, fillers, thinners, solvents, etc.) in accordance with MPI Architectural Painting Specification Manual "Approved Product" listing.
- .7 Linseed oil, shellac, and turpentine: highest quality product from approved manufacturer listed in MPI Architectural Painting Specification Manual, compatible with other coating materials as required.
- .8 Formulate and manufacture water-borne surface coatings with no aromatic solvents, formaldehyde, halogenated solvents, mercury, lead, cadmium, hexavalent chromium or their compounds.

2.2 COLOURS

- .1 Departmental Representative will provide Colour Schedule after Contract award
- .2 Colour schedule will be based upon selection of five base colours and three accent colours. No more than eight colours will be selected for entire project and no more than three colours will be selected in each area.

- .3 Selection of colours from manufacturers full range of colours.
- .4 Where specific products are available in restricted range of colours, selection based on limited range.
- .5 Second coat in three coat system to be tinted slightly lighter colour than top coat to show visible difference between coats.

2.3 MIXING AND TINTING

- .1 Perform colour tinting operations prior to delivery of paint to site. Obtain written approval from Departmental Representative for tinting of painting materials.
- .2 Mix paste, powder or catalyzed paint mixes in accordance with manufacturer's written instructions.
- .3 Use and add thinner in accordance with paint manufacturer's recommendations. Do not use kerosene or similar organic solvents to thin water-based paints.
- .4 Thin paint for spraying in accordance with paint manufacturer's instructions.
- .5 Re-mix paint in containers prior to and during application to ensure break-up of lumps, complete dispersion of settled pigment, and colour and gloss uniformity.

2.4 GLOSS/SHEEN RATINGS

- .1 Paint gloss is defined as sheen rating of applied paint, in accordance with following values:

	Gloss @ 60 degrees	Sheen @ 85 degrees
Gloss Level 1 - Matte Finish (flat)	Max. 5	Max. 10
Gloss Level 2 - Velvet-Like Finish	Max.10	10 to 35
Gloss Level 3 - Eggshell Finish	10 to 25	10 to 35
Gloss Level 4 - Satin-Like Finish	20 to 35	min. 35
Gloss Level 5 - Traditional Semi-Gloss Finish	35 to 70	
Gloss Level 6 - Traditional Gloss	70 to 85	
Gloss Level 7 - High Gloss Finish	More than 85	

- .2 Gloss level ratings of painted surfaces will be provided by Departmental Representative after Contract Award.

2.5 INTERIOR PAINTING SYSTEMS

- .1 Concrete vertical surfaces: including horizontal soffits:
 - .1 INT 3.1C - High performance architectural latex finish.
 - .2 INT 3.1G - Waterborne epoxy (tile-like) finish for smooth concrete.
- .2 Concrete horizontal surfaces: floors and stairs:
 - .1 INT 3.2L - Waterborne epoxy floor finish.
- .3 Concrete masonry units: smooth and split face block and brick:
 - .1 INT 4.2D - High performance architectural latex finish.
 - .2 INT 4.2J - Waterborne epoxy (tile-like) finish for dry environments.
- .4 Structural steel and metal fabrications: columns, beams, joists:
 - .1 INT 5.1B - Waterborne light industrial coating.
 - .2 INT 5.1N - Waterborne light industrial coating (over epoxy primer).
- .5 Galvanized metal: doors, frames, railings, misc. steel, pipes, overhead decking, and ducts.
 - .1 INT 5.3B - Waterborne light industrial coating.
- .6 Dimension lumber:
 - .1 INT 6.2B - High performance architectural latex finish.
- .7 Wood paneling and casework: partitions, panels, shelving, millwork:
 - .1 INT 6.4E - Polyurethane varnish finish (over stain).
- .8 Plaster and gypsum board: gypsum wallboard, drywall, "sheet rock type material", and textured finishes:
 - .1 INT 9.2B - High performance architectural latex finish.
- .9 Canvas and cotton coverings.
 - .1 INT 10.1A - Latex finish.

2.6 SOURCE QUALITY CONTROL

- .1 Perform following tests on each batch of consolidated post-consumer material before surface coating is reformulated and canned. Testing by laboratory or facility which has been accredited by Standards Council of Canada.

- .1 Lead, cadmium and chromium are to be determined using ICP-AES (Inductively Coupled Plasma - Atomic Emission Spectroscopy) technique no. 6010 as defined in EPA SW-846.
- .2 Mercury is to be determined by Cold Vapour Atomic Absorption Spectroscopy using Technique no. 7471 as defined in EPA SW-846.
- .3 Organochlorines and PCBs are to be determined by Gas Chromatography using Technique no. 8081 as defined in EPA SW-846.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and data sheet.

3.2 GENERAL

- .1 Perform preparation and operations for interior painting in accordance with MPI Architectural Painting Specifications Manual except where specified otherwise.
- .2 Apply paint materials in accordance with paint manufacturer's written application instructions.

3.3 EXAMINATION

- .1 Investigate existing substrates for problems related to proper and complete preparation of surfaces to be painted. Report to Departmental Representative damages, defects, unsatisfactory or unfavourable conditions before proceeding with work.
- .2 Conduct moisture testing of surfaces to be painted using properly calibrated electronic moisture meter, except test concrete floors for moisture using simple "cover patch test". Do not proceed with work until conditions fall within acceptable range as recommended by manufacturer.
- .3 Maximum moisture content as follows:
 - .1 Stucco, plaster and gypsum board: 12 %.
 - .2 Concrete: 12 %.
 - .3 Clay and Concrete Block/Brick: 12 %.
 - .4 Wood: 15 %.

3.4 PREPARATION

- .1 Protection:

- .1 Protect existing building surfaces and adjacent structures from paint spatters, markings and other damage by suitable non-staining covers or masking. If damaged, clean and restore surfaces as directed by Departmental Representative .
- .2 Protect items that are permanently attached such as Fire Labels on doors and frames.
- .3 Protect factory finished products and equipment.
- .4 Protect passing pedestrians, building occupants and general public in and about the building.
- .2 Surface Preparation:
 - .1 Remove electrical cover plates, light fixtures, surface hardware on doors, bath accessories and other surface mounted equipment, fittings and fastenings prior to undertaking painting operations. Identify and store items in secure location and re-installed after painting is completed.
 - .2 Move and cover furniture and portable equipment as necessary to carry out painting operations. Replace as painting operations progress.
 - .3 Place "WET PAINT" signs in occupied areas as painting operations progress. Signs to approval of Departmental Representative .
- .3 Clean and prepare surfaces in accordance with MPI Architectural Painting Specification Manual requirements. Refer to MPI Manual in regard to specific requirements and as follows:
 - .1 Remove dust, dirt, and other surface debris by vacuuming, wiping with dry, clean cloths or compressed air .
 - .2 Wash surfaces with a biodegradable detergent and bleach where applicable and clean warm water using a stiff bristle brush to remove dirt, oil and other surface contaminants.
 - .3 Rinse scrubbed surfaces with clean water until foreign matter is flushed from surface.
 - .4 Allow surfaces to drain completely and allow to dry thoroughly.
 - .5 Prepare surfaces for water-based painting, water-based cleaners should be used in place of organic solvents.
 - .6 Use trigger operated spray nozzles for water hoses.
 - .7 Many water-based paints cannot be removed with water once dried. Minimize use of mineral spirits or organic solvents to clean up water-based paints.
- .4 Prevent contamination of cleaned surfaces by salts, acids, alkalis, other corrosive chemicals, grease, oil and solvents before prime coat is applied and between applications of remaining coats. Apply primer, paint, or pretreatment as

soon as possible after cleaning and before deterioration occurs.

- .5 Where possible, prime non-exposed surfaces of new wood surfaces before installation. Use same primers as specified for exposed surfaces.
 - .1 Apply wood filler to nail holes and cracks.
 - .2 Tint filler to match stains for stained woodwork.
- .6 Sand and dust between coats as required to provide adequate adhesion for next coat and to remove defects visible from a distance up to 1000 mm.
- .7 Clean metal surfaces to be painted by removing rust, loose mill scale, welding slag, dirt, oil, grease and other foreign substances in accordance with MPI requirements. Remove traces of blast products from surfaces, pockets and corners to be painted by brushing with clean brushes blowing with clean dry compressed air or vacuum cleaning .
- .8 Touch up of shop primers with primer as specified.
- .9 Do not apply paint until prepared surfaces have been accepted by Departmental Representative

3.5 APPLICATION

- .1 Method of application to be as approved by Departmental Representative. Conform to manufacturer's application instructions unless specified otherwise.
- .2 Brush and Roller Application:
 - .1 Apply paint in uniform layer using brush and/or roller type suitable for application.
 - .2 Work paint into cracks, crevices and corners.
 - .3 Paint surfaces and corners not accessible to brush using spray, daubers and/or sheepskins. Paint surfaces and corners not accessible to roller using brush, daubers or sheepskins.
 - .4 Brush and/or roll out runs and sags, and over-lap marks. Rolled surfaces free of roller tracking and heavy stipple.
 - .5 Remove runs, sags and brush marks from finished work and repaint.
- .3 Spray application:
 - .1 Provide and maintain equipment that is suitable for intended purpose, capable of atomizing paint to be applied, and equipped with suitable pressure regulators and gauges.
 - .2 Keep paint ingredients properly mixed in containers during paint application either by continuous

- mechanical agitation or by intermittent agitation as frequently as necessary.
- .3 Apply paint in uniform layer, with overlapping at edges of spray pattern. Back roll first coat application.
 - .4 Brush out immediately all runs and sags.
 - .5 Use brushes and rollers to work paint into cracks, crevices and places which are not adequately painted by spray.
 - .4 Use dipping, sheepskins or daubers only when no other method is practical in places of difficult access.
 - .5 Apply coats of paint continuous film of uniform thickness. Repaint thin spots or bare areas before next coat of paint is applied.
 - .6 Allow surfaces to dry and properly cure after cleaning and between subsequent coats for minimum time period as recommended by manufacturer.
 - .7 Sand and dust between coats to remove visible defects.
 - .8 Finish surfaces both above and below sight lines as specified for surrounding surfaces, including such surfaces as tops of interior cupboards and cabinets and projecting ledges.
 - .9 Finish closets and alcoves as specified for adjoining rooms.

3.6 MECHANICAL/ELECTRICAL EQUIPMENT

- .1 Paint finished area exposed conduits, piping, hangers, ductwork and other mechanical and electrical equipment with colour and finish to match adjacent surfaces, except as indicated.
- .2 Boiler room, mechanical and electrical rooms: paint exposed conduits, piping, hangers, ductwork and other mechanical and electrical equipment.
- .3 Other unfinished areas: leave exposed conduits, piping, hangers, ductwork and other mechanical and electrical equipment in original finish and touch up scratches and marks.
- .4 Touch up scratches and marks on factory painted finishes and equipment with paint as supplied by manufacturer of equipment.
- .5 Do not paint over nameplates.
- .6 Keep sprinkler heads free of paint.

- .7 Paint inside of ductwork where visible behind grilles, registers and diffusers with primer and one coat of matt black paint.
- .8 Paint fire protection piping.
- .9 Paint disconnect switches for fire alarm system and exit light systems in red enamel.
- .10 Paint natural gas piping.
- .11 Paint both sides and edges of backboards for telephone and electrical equipment before installation. Leave equipment in original finish except for touch-up as required, and paint conduits, mounting accessories and other unfinished items.
- .12 Do not paint interior transformers and substation equipment.

3.7 SITE TOLERANCES

- .1 Walls: no defects visible from a distance of 1000 mm at 90 degrees to surface.
- .2 Ceilings: no defects visible from floor at 45 degrees to surface when viewed using final lighting source.
- .3 Final coat to exhibit uniformity of colour and uniformity of sheen across full surface area.

3.8 RESTORATION

- .1 Clean and re-install hardware items removed before undertaken painting operations.
- .2 Remove protective coverings and warning signs as soon as practical after operations cease.
- .3 Remove paint splashings on exposed surfaces that were not painted. Remove smears and spatter immediately as operations progress, using compatible solvent.
- .4 Protect freshly completed surfaces from paint droppings and dust to approval of Departmental Representative. Avoid scuffing newly applied paint.
- .5 Restore areas used for storage, cleaning, mixing and handling of paint to clean condition as approved by Departmental Representative.

END OF SECTION