

**Part 1 General**

**1.1 REFERENCE**

- .1 Read and be governed by Section 26 05 00.

**1.2 RELATED WORK**

- .1 Comply with relevant Sections of this and other Divisions of this Specification.

**1.3 SYSTEM DESCRIPTION**

- .1 The complete and separate telephone and data raceway systems, consist of outlet boxes, cover plates, plywood backboards, terminal cabinets, conduits, cabletroughs, pull boxes, J-hooks, sleeves and caps, pulling cables, and concrete encased ducts.

**Part 2 Products**

**2.1 MATERIALS**

- .1 All outlet boxes, wiring devices, cover plates, terminal cabinets, conduits, cabletroughs, plywood backboards, pull boxes, sleeves and caps, pulling cables, and concrete encased ducts are described elsewhere in this Specification.
- .2 J-hooks:
  - .1 J-hooks to be B-line #BCH64X or equivalent c/w support bracket and threaded rod to ceiling.

**Part 3 Execution**

**3.1 INSTALLATION**

- .1 Install separate telephone and data raceway systems, including cabletrough, J-hooks, terminal cabinets, outlet boxes, wiring devices, pull boxes, cover plates, conduit, sleeves and caps, pulling cables, concrete encased ducts, miscellaneous and positioning material to constitute a complete system.
- .2 Cap and/or seal all unused sleeves and slots.
- .3 Caulk all unused sleeves, fire and smoke tight.
- .4 Conduits for tel/data wiring to be based on the following table with a 40% fill ratio:

WIRE TYPE AND QUANTITY BASED ON CAT. 6		MINIMUM CONDUIT SIZE FOR EACH OUTLET TYPE
Non-Plenum Rated Tele/Data Outlet	Plenum Rated Tele/Data Outlet	
4	4	21mm

(Cont'd)

7	8	27mm
10	12	35mm
15	17	41mm
27	30	53mm
60	68	78mm
110	121	103mm

### 3.2 EXPANSION FITTINGS

- .1 Conduit expansion fittings to be provided on all conduits crossing expansion joints, and at maximum of 60 m spacing.
- .2 Install expansion fittings perpendicular to expansion joint.

**END OF SECTION**

---

**Part 1            General**

**1.1                REFERENCES**

- .1        UL6500 – Standard for Audio/Video and Musical Instrument Apparatus for Household, Commercial and Similar General Use.
- .2        UL 2043 – Standard for Fire Test for Heat and Visible Smoke Release for Discrete Products and Their Accessories Installed in Air-Handling Spaces; 1996.
- .3        ASTM E 1374-02 – Standard Guide for Open Office Acoustics and Applicable ASTM Standards.
- .4        ASTM E 1573-02 – Standard Test Method for Evaluating Masking Sound in Open Office Using A-Weighted and One-Third Octave Band Sound Pressure Levels.
- .5        ASTM E 1130-02e1 – Standard Test Method for Objective Measurement of Speech Privacy in Open Offices Using Articulation Index.
- .6        FCC – EN 55103-1&2 – Audio, Video and Entertainment Lighting Control.

**1.2                SHOP DRAWINGS**

- .1        Submit shop drawings in accordance with Section 26 05 00.

**1.3                QUALITY ASSURANCE**

- .1        Manufacturer Qualifications: Minimum of 10 years manufacturing sound masking systems.
- .2        Installer Qualifications – Approved by manufacturer representative and are trained with the specified products or have demonstrated experience with the installation of similar products to those specified.
- .3        System Adjustment – Done by an approved manufacturer representative or trained contractor to satisfaction of end user.
- .4        Single Source Responsibility – All components by one (1) manufacturer.

**1.4                DELIVERY, STORAGE AND HANDLING**

- .1        Protect from moisture during shipping, storage and handling.
- .2        Deliver in manufacturer's original unopened and undamaged packages with manufacturer's labels legible and intact.
- .3        Inspect manufacturer's packages upon receipt.
- .4        Handle packages carefully.

---

**1.5 WARRANTY AND MAINTENANCE**

- .1 Provide a written warranty that products installed shall be free from defects in parts or assembly for a 5-year period from date of completion of installation.

**Part 2 Products**

**2.1 SYSTEM COMPONENTS**

- .1 General System Overview: The sound masking system shall be comprised of a selection of 1) Sound Masking Generator Kit; 2) Amplifier; 3) Sound Masking Loud Speakers; 4) Sound Volume Control; and 5) Sound Equalizer. System to be supplied with all necessary components and hardware. Equivalent systems by reputable supplier shall be accepted.

**2.2 SOUND MASKING GENERATOR KIT**

- .1 Pre-assembled unit for general purpose sound masking with the following built-in features:
  - .1 Selectable between pink and white noise.
  - .2 Rack mounted in 10RU rack.
  - .3 Random analog topology.
  - .4 4W, 70.7V and line level outputs.
- .2 Acceptable manufacturer or approved equal:
  - .1 Atlas Sound #GPN 1200K c/w rack #WMA10-23 and all accessories.

**2.3 AMPLIFIER**

- .1 Power output: 100W @ 70.7V
- .2 Power input: 120V
- .3 One channel 1RU rack mounted or on rack mounted shelf.
- .4 Front panel signal LED's and master adjustment controls.
- .5 Audio sense turn-on from standby mode.
- .6 Acceptable manufacturer or approved equal:
  - .1 Atlas Sound #PA1001G

**2.4 SPEAKERS**

- .1 8" dual cone.
- .2 Pre-assembled unit for general purpose with the following built-in features:
  - .1 Loudspeaker.

- .2 Transformer.
- .3 Enclosure.
- .4 Baffle.
- .5 Mounting hardware.
- .3 Suitable for use above suspended ceiling space.
- .4 Acceptable manufacturers or approved equal:
  - .1 Atlas Sound #M1000

**2.5 VOLUME CONTROL (ATTENUATOR)**

- .1 Power rating: 100W.
- .2 Attenuation step: 1.5dB.
- .3 Total attenuation: 15dB.
- .4 Acceptable manufacturer or approved equal:
  - .1 Atlas Sound #E408-100-RM

**2.6 EQUALIZER**

- .1 Front panel mounted LPF/HPF.
- .2 Thirty-one (31) frequency adjustments.
- .3 20mm slide controls.
- .4 1RU rack mounted.
- .5 Output of generator to be split between equalizer inputs.
- .6 Acceptable manufacturer or approved equal:
  - .1 Atlas Sound #EQM-131

**2.7 MANUFACTURERS**

- .1 Acceptable manufacturer:
  - .1 Atlas Sound
  - .2 LogiSon
  - .3 Substitutions: Engineer approved equal

---

**Part 3 Execution**

**3.1 EXAMINATION**

- .1 Ensure that facility build out is at a stage suitable for the system installation.
- .2 Ensure that facility is constructed according to plans including wall locations, ceiling types and plenum barriers.
- .3 Ensure that the plenum height is appropriate as per manufacturer's recommendations and as per plan.
- .4 Ensure power requirements have been provided as per plan.
- .5 Ensure sufficient space for centrally located components is available as per plan and manufacturer's specifications.
- .6 Ensure any third-party components required to be interfaced with the system have been provided.

**3.2 PERMITS**

- .1 Obtain necessary permits for installation work.

**3.3 INSTALLATION**

- .1 Follow all applicable codes for the area.
- .2 Follow manufacturer's recommendations regarding installation.
- .3 Follow the system design for location of loudspeakers and wiring.
- .4 Record any necessary changes to the system design on the plan.
- .5 Ensure that supplementary materials used meet applicable safety standards.

**3.4 FIELD QUALITY CONTROL**

- .1 Ensure that plenum heights meet the minimum recommended by the manufacturer for the loudspeakers.
- .2 Ensure that distance between the top of the loudspeaker and the deck meets manufacturer's minimum specifications.
- .3 Ensure that loudspeakers are suspended in a level manner.
- .4 Ensure that loudspeakers are not obstructed as much as possible.
- .5 Ensure cables are properly supported in the ceiling.
- .6 Ensure cables are securely terminated.

---

**3.5 SYSTEM ADJUSTMENT**

- .1 Follow manufacturer's recommendations for system settings.

**3.6 CLEANING**

- .1 Ensure that empty packaging is removed.
- .2 Ensure that any material waste is removed.
- .3 Ensure the product is clean and presentable where required.

**3.7 DEMONSTRATION AND TRAINING**

- .1 Demonstrate operational system to customer by walking the space.
- .2 Demonstrate functionality of the system to the customer or customer's representative.
- .3 Train customer employee to maintain system as required.

**3.8 TESTING AND REPORTING**

- .1 Test area for consistency of masking volume and quality.
- .2 Verify that paging zoning and levels are appropriate and as per plan.
- .3 Test masking volumes with mechanicals off and with space unoccupied.
- .4 Provide a printed report detailing system settings.

**END OF SECTION**