



Royal Canadian Mounted Police
Gendarmerie royale du Canada

RETURN BIDS TO :

RETOURNER LES SOUMISSIONS :

Bid Receiving Unit / Grope de la réception des soumissions

Procurement and Contracting Services
 73 Leikin Drive,
 Visitor Center - Building M1
 Mailstop # 15
 Ottawa, ON K1A 0R2

Attn: Shannon Plunkett (613) 843-3798

AMENDMENT TO THE INVITATION TO TENDER

Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

MODIFICATION À L'APPEL D'OFFRES

Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté I Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Telephone No. – No de téléphone:

()

Facsimile No. – No de télécopieur:

()

Title-Sujet Construction – Detachment - Arviat		
Solicitation No. – No. de l'invitation 201601066	Amend. – Modif. No. : 4	Date July 22st, 2015
Client Reference No. - No. de Référence du Client 201601066		
GETS Reference No. – No de Référence du SEAG 201601066		
Solicitation Closes – L'invitation prend fin at - à 2 :00 pm EDT on - le July 28th, 2015		
F.O.B. - F.A.B. Destination		
Address Enquiries to: - Adresser toute questions à : Eric Glynn – Contracting Authority Eric.glynn@rcmp-grc.gc.ca		
Telephone No. - No de téléphone 613-843-5533	Fax: 613-825-0082	
Destination of Goods - Destinations des biens: See Herein		
Instructions : See Herein / Voir aux présentes		
Delivery Required – Livraison exigée: See Herein		
Name and Title of person authorized to sign on behalf of Vendor/Firm. Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		



Royal Canadian Mounted Police

Gendarmerie royale du Canada

Amendment #4 of Solicitation 201601066 has been issued to respond to Questions and Answers – Part 3 and to provide Addendum #3 to the Specifications/Drawings.

Questions and Answers – Part 3:

Q49 – Under Annex “A” – Specifications, Section 11 24 24: Are fall arrest anchors still requested for this project?

A49 – Fall Arrest Anchors are not required for this project.

Q50 – Under Annex “A” – Specifications, Section 11 24 24: Fall Arrest Anchor System is specific for an anchor system for window washing and exterior building maintenance from a swing stage. Is the intent to have a fall protection system installed on the roof consisting of roof anchors and a horizontal lifeline (HLL)?

A50 – Fall Arrest Anchors are not required for this project, and windows will be washed from the ground level.

Q51 – Under Annex “B” – Drawings, Sheet 1408-A-100 indicates that the exterior window on grid 1 between grids B & D will have a roller shade. Due to the shape of that window (or fiberglass curtain wall), can you please let us know what the roller shade dimensions are? Also, will the roller shade be installed directly on the fiberglass frame?

A51 – For the roller shade dimensions refer to plan for window width, refer to window elevation on A202 and refer to sections A310 to A313 for locations. Depending on the location shown on the section, the roller shades will (in certain cases) be mounted directly onto the fiberglass frame.

Q52 – Under Annex “B” – Drawings, Sheet 1408-A-501 (with respect to interior window SC132) (det. 11) shows a steel frame coming with one glass. Sheet A2001 & A3000 also show clearly that SC132 is a steel frame coming with one glass. Sheet A3007; however, shows that interior window to be an aluminum frame coming with a sealed unit equipped with an internal horizontal blind. Can you please clarify the requirement for interior window SC132?

A52 – Refer to Addendum #3 for clarification.

Q53 – Under Annex “B” – Drawings, Sheet S001, there is a recommendation for primer 1-73a. This requires cleaning with steel brush. However, under Annex “A” – Specifications, Section 05 12 23, Article 2.4.2, calls for sand blasting. Can you please confirm the requirement?

A53 – Use a Primer 1-73a.



Royal Canadian Mounted Police

Gendarmerie royale du Canada

Q54 – There are three (3) Entry Canopies which are to be supplied with a standard primer. Since they will be covered, is this necessary?

A54 – Yes, all covered steel is primed and all exposed steel is hot dip galvanized

Q55 – Is the main floor steel, as well as, the steel below this level to be galvanized?

A55 – All covered steel is primed and all exposed steel is hot dip galvanized

Q56 – It is not possible to find the BESISTA bracing rods. There are no distributors in Canada or in Quebec, according to BESISTA. Can you please confirm the requirement?

A56 – Use the HALFEN Rod System instead, the same details apply with slight revisions, refer to the attached drawings & specification section 05 17 00. Halfen Representative: Bob Robinson
rrobinson91@cogeco.ca

**ALL OTHER TERMS AND CONDITIONS OF THE ITT REMAIN
UNCHANGED.**