

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving - PWGSC / Réception des soumissions
- TPSGC
11 Laurier St. / 11, rue Laurier
Place du Portage, Phase III
Core 0B2 / Noyau 0B2
Gatineau, Québec K1A 0S5
Bid Fax: (819) 997-9776

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Electrical & Electronics Products Division
11 Laurier St./11, rue Laurier
7B3, Place du Portage, Phase III
Gatineau, Québec K1A 0S5

Title - Sujet DOOR CONTROL-SPRINGHILL INSTITUTION	
Solicitation No. - N° de l'invitation 21120-166580/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client 21120-166580	Date 2015-07-28
GETS Reference No. - N° de référence de SEAG PW-\$\$HN-445-67507	
File No. - N° de dossier hn445.21120-166580	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-08-26	Time Zone Fuseau horaire Eastern Daylight Saving Time EDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ladouceur, Joanne M.	Buyer Id - Id de l'acheteur hn445
Telephone No. - N° de téléphone (819) 420-0340 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This amendment 003 is raised to provide the minutes of the site visite as follows:

=====

INSERT: *July 15, 2015 @ 10:00am - The Bidders Conference was held at Springhill Institution.*

The following documents were provided to all prospective bidders that attended the Bidders Conference:

Paper copies of the Living Unit and RRC Floor Plans, a screen shot of the building 52 Door Control User Interface, including and Lighting and Power.

Site Visit included viewing of the following Living Units and their associated Equipment Rooms:

Living Unit # 50, 51, 52 (mechanical room only for unit 51), 57 & 58 and the Regional Reception Centre, Building 5.

Actions:

CSC to provide photos of door control panels for each living unit. Response: **Send your request to joanne.m.ladouceur@pwgsc-tpsgc.gc.ca to receive the ZIP file containing the images.**

PWGSC to upload ES and Appendices documents Response: 07/20 - Documents are now up on buyandsell.gc.ca and are available for download

Respond to the following 4 questions

Questions Asked:

1) Is the successful Bidder to take on the warranty of the existing equipment?

Answer: The warranty has expired. This is a non-issue.

2) When does the warranty commence? Please define if it will be upon full acceptance by range? By living unit? etc.

Answer: Immediately following satisfactory completion of the ATP, provision of all training, supply of documentation and spares and the completed Handover form

3) Can an extension of two weeks be provided?

Answer: Amendment 002 has been issued to address this request.

4) Can the inmates be transferred to one of the other living unit to allow work to be completed.

Answer: no, work must be completed as per STR 4.1.6.1 and 4.1.6.2 installation section .

Ensure that at no time any entire living unit is without an operating Door control and monitoring system. Ensure that the changeover from the existing system to the new system in any building must be done in stages i.e. one range at a time.

=====

All other terms and conditions remain unchanged.