



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A:
Bid Receiving/Réception des
sousmissions**

**RCMP / GRC
Procurement & Contracting services
c/o Commissionaires, F Division
6101 Dewdney Avenue
Regina, SK S4P 3K7**

**Facsimile Number for Amendments:
(306) 780-5232**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les memes.

Comments - Commentaries

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Facsimile No. - No de télécopieur:

Telephone No. - no de téléphone:

Title-Sujet Fit-up of Quonset Building, Innisfail, AB	
Solicitation No. - No. de l'invitation M5000-6-1086/A	Date 29 July 2015
Amendment No. - No modif. 04	
Client Reference No. - No. De Référence du Client 1003933	
GETS REFERENCE No. - No. de Référence de SEAG PW-15-00691531	
Solicitation Closes -L'invitation prend fin at - à 2 :00 pm Central Standard Time on - le 06 August 2015	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: Bonny Manz, Senior Contracting Officer	
Telephone No. - No de téléphone (306) 780-3352	Fax No. - N° de FAX: (306) 780-5232
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Royal Canadian Mounted Police Police Dog Services Training Centre Highway 2, Exit 365 East Innisfail, AB T4G 1S8	
This document contains a PERSONNEL SECURITY Clearance requirement	
Delivery Required - Livraison exigée: 12 weeks from award	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	
(Please sign and return cover page with bid proposal./ Signez s'il vous plaît et la page de couverture de retour avec la proposition d'offre.)	



This amendment is raised to address the following:

Question 4: Where is the water service to come from? What distance is it, and where is the tie in location?

Answer 4: The water service is approximately 102 m from the quonset to an existing future 50mm (item #12) as indicated on the attached PDF's. M 1 on water distribution PDF.

Question 5: Will this require a ground grid for the new main service? Example 3 x 10' grnd rods with 3/0 bare copper connecting the rods and to the new main disconnect.

Answer 5: A ground grid is required. The grid as described here is acceptable.

Question 6: If there is a ground grid where would it be located? Typically would be just outside the electrical room but it may interfere with the septic field.

Answer 6: The grid can be installed outside of the electrical room. It can move depending on location of other services.