

**Part 1        General****1.1        REFERENCES**

- .1 American Society for Testing and Materials International (ASTM)
  - .1 ASTM C335-04, Standard Test Method for Steady State Heat Transfer Properties of Horizontal Pipe Insulation.
  - .2 ASTM C449/C449M-00, Standard Specification for Mineral Fiber-Hydraulic-Setting Thermal Insulating and Finishing Cement.
  - .3 ASTM C547-2003, Mineral Fiber Pipe Insulation.
- .2 Canadian General Standards Board (CGSB)
  - .1 CGSB 51-GP-52Ma-89, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.
- .3 Department of Justice Canada (Jus)
  - .1 Canadian Environmental Assessment Act (CEAA), 1995, c. 37.
  - .2 Canadian Environmental Protection Act (CEPA), 1999, c. 33.
  - .3 Transportation of Dangerous Goods Act (TDGA), 1992, c. 34.
- .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
  - .1 Material Safety Data Sheets (MSDS).
- .5 Manufacturer's Trade Associations
  - .1 Thermal Insulation Association of Canada (TIAC): National Insulation Standards (Revised 2004).
- .6 Underwriters' Laboratories of Canada (ULC)
  - .1 CAN/ULC-S102-03, Surface Burning Characteristics of Building Materials and Assemblies.

**1.2        DEFINITIONS**

- .1 For purposes of this section:
  - .1 "CONCEALED" - insulated mechanical services in suspended ceilings and non-accessible chases and furred-in spaces.
  - .2 "EXPOSED" - will mean "not concealed" as specified.
- .2 TIAC ss:
  - .1 CRF: Code Rectangular Finish.
  - .2 CPF: Code Piping Finish.

**1.3 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
    - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
- .3 Shop Drawings:
  - .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
- .4 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
  - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
  - .2 Instructions: submit manufacturer's installation instructions.
    - .1 Departmental Representative will make available 1 copy of systems supplier's installation instructions.

**1.4 QUALITY ASSURANCE**

- .1 Qualifications:
- .2 Installer: specialist in performing work of this Section, qualified to standards.
- .3 Health and Safety:
  - .1 Do construction occupational health and safety in accordance with Section 01 35 29 - Health and Safety Requirements.

**1.5 DELIVERY, STORAGE AND HANDLING**

- .1 Packing, shipping, handling and unloading:
  - .1 Deliver, store and handle in accordance with manufacturer's written instructions.
  - .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name.
- .2 Storage and Protection:
  - .1 Protect from weather, construction traffic.
  - .2 Protect against damage.
  - .3 Store at temperatures and conditions required by manufacturer.

- .3 Waste Management and Disposal:
  - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
  - .2 Place excess or unused insulation and insulation accessory materials in designated containers.
  - .3 Divert unused metal materials from landfill to metal recycling facility approved by Departmental Representative.
  - .4 Dispose of unused adhesive material at official hazardous material collections site approved by Departmental Representative.

## **Part 2 Products**

### **2.1 FIRE AND SMOKE RATING**

- .1 In accordance with CAN/ULC-S102.
  - .1 Maximum flame spread rating: 25.
  - .2 Maximum smoke developed rating: 50.

### **2.2 INSULATION**

- .1 Mineral fibre specified includes glass fibre, rock wool, slag wool.
- .2 Thermal conductivity ("k" factor) not to exceed specified values at 24 degrees C mean temperature when tested in accordance with ASTM C335.
- .3 TIAC Code A-3: rigid moulded mineral fibre with factory applied vapour retarder jacket.
  - .1 Mineral fibre: to CAN/ULC-S702 and ASTM C547.
  - .2 Maximum "k" factor: to CAN/ULC-S702 and ASTM C547.

### **2.3 INSULATION SECUREMENT**

- .1 Tape: self-adhesive, aluminum, reinforced, 50 mm wide minimum.
- .2 Contact adhesive: quick setting.
- .3 Canvas adhesive: washable.
- .4 Tie wire: 1.5 mm diameter stainless steel.
- .5 Bands: stainless steel, 19 mm wide, 0.5 mm thick.

### **2.4 CEMENT**

- .1 Thermal insulating and finishing cement:
  - .1 Air drying on mineral wool, to ASTM C449/C449M.

### **2.5 VAPOUR RETARDER LAP ADHESIVE**

- .1 Water based, fire retardant type, compatible with insulation.

**2.6 INDOOR VAPOUR RETARDER FINISH**

- .1 Vinyl emulsion type acrylic, compatible with insulation.

**Part 3 Execution****3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

**3.2 PRE-INSTALLATION REQUIREMENT**

- .1 Pressure testing of piping systems and adjacent equipment to be complete, witnessed and certified.
- .2 Surfaces clean, dry, free from foreign material.

**3.3 INSTALLATION**

- .1 Install in accordance with TIAC National Standards.
- .2 Apply materials in accordance with manufacturers instructions and this specification.
- .3 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes.
  - .1 Install hangers, supports outside vapour retarder jacket.
- .4 Supports, Hangers:
  - .1 Apply high compressive strength insulation, suitable for service, at oversized saddles and shoes where insulation saddles have not been provided.

**3.4 PIPING INSULATION SCHEDULES**

- .1 TIAC Code: A-3.
  - .1 Securements: Tape or SS bands at 300 mm on centre.
  - .2 Seals: VR lap seal adhesive, VR lagging adhesive.
  - .3 Installation: TIAC Code: 1501-C.
- .2 Thickness of insulation as listed.
  - .1 TIAC code A-3, rain water piping over a distance of 3m (10') from underside of roof in heated space to be 38 mm on all pipe sizes.

**3.5 CLEANING**

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

**END OF SECTION**