

**Part 1            General**

**1.1                RELATED REQUIREMENTS**

- .1        Section 01 52 00 - Construction facilities.
- .2        Section 01 56 00 - Temporary barriers and enclosures.

**1.2                ACTION AND INFORMATIONAL SUBMITTALS**

- .1        Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.

**1.3                INSTALLATION AND REMOVAL**

- .1        Provide temporary utilities controls in order to execute work expeditiously.
- .2        Remove from site all such work after use.

**1.4                TEMPORARY POWER AND LIGHT**

- .1        Provide and pay for temporary power during construction for temporary lighting and operating of power tools.
- .2        Provide and maintain temporary lighting throughout project. Ensure level of illumination on all floors and stairs is not less than [10] lx.
- .3        The Contractor will be allowed to tap into the electrical service panel located in the Transport Canada building only for the needs of the site offices. The connection must be performed by a licensed electrician in accordance with the Canadian Electrical Code. Pay all costs of connection and disconnection.
- .4        The electrical installations set up by the Contractor must comply with applicable standards, codes and regulations.

**1.5                TEMPORARY COMMUNICATION FACILITIES**

- .1        Provide and pay for temporary telephone, fax, Internet link, printers with scanner, hook up lines and equipment necessary for own use and that of the Departmental Representative.

**1.6                FIRE PROTECTION**

- .1        Provide and maintain temporary fire protection equipment during performance of Work required by insurance companies having jurisdiction and by governing codes, regulations and bylaws.
- .2        Burning rubbish and construction waste materials is not permitted on site.

**Part 2            Products**

**2.1                NOT USED**

.1            Not Used.

**Part 3            Execution**

**3.1                NOT USED**

.1            Not Used.

**END OF SECTION**