

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving - PWGSC / Réception des soumissions**  
**- TPSGC**  
**11 Laurier St. / 11, rue Laurier**  
**Place du Portage, Phase III**  
**Core 0B2 / Noyau 0B2**  
**Gatineau, Québec K1A 0S5**  
**Bid Fax: (819) 997-9776**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Fuel & Construction Products Division**  
**11 Laurier St./11, rue Laurier**  
**7A2, Place du Portage, Phase III**  
**Gatineau, Québec K1A 0S5**

<b>Title - Sujet</b> HEATING BOILERS	
<b>Solicitation No. - N° de l'invitation</b> U6800-163691/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> U6800-163691	<b>Date</b> 2015-08-11
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$\$HL-659-67630	
<b>File No. - N° de dossier</b> hl659.U6800-163691	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2015-08-24</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Eastern Daylight Saving Time EDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Van Tassel, Stella	<b>Buyer Id - Id de l'acheteur</b> hl659
<b>Telephone No. - N° de téléphone</b> (819) 956-4398 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**Amendment number 003 to Request for Proposal (RFP) U6800-163691/A which closes August 18, 2015 at 2:00 p.m. is raised to:**

- 1) Amend the closing date. The new closing date is **August 24, 2015 at 2:00 p.m.**
- 2) Delete the original Annex B - Pricing Table and replace with the attached Annex B - Pricing Table which reflects the change made to the number of control units, now two (2) units instead of one (1) unit.
- 3) Amend the Annex A - Purchase Description as follows:

## **PURCHASE DESCRIPTION FOR HEATING BOILERS**

### **SECTION 1: GENERAL**

Paragraph 1.1.1.1

Replace: "one (1) control unit" with **two (2) control units**.

### **SECTION 2: PRODUCTS**

Paragraph 2.2.1.1.1

Add: The gas fired hot water condensing heating boiler must be fabricated of high grade stainless steel and titanium (**SA240-316Ti**).

Paragraph 2.2.1.1.3

Remove: **polypropylene (PPs)**.

Paragraph 2.2.1.1.4

Add new paragraph number 4: **The boiler manufacturer must have certified common venting option for venting for specified boilers with Category IV venting. Boiler manufacturer must have CSA approved installation manual detailing common venting installation requirements.**

### **SECTION 2.2: CONSTRUCTION**

Paragraph 2.2.2.6

Add: The burner **must be sealed combustion and** must be capable of operating at natural gas pressures **from 0.996 to 3.487 KPa** (4 up to 14" W.C.).

Paragraph 2.2.2.9

Add new paragraph number 9: **The boiler overall dimensions must not be larger than; 1852 mm (73") L, 930 mm (36-1/2") W, 1676 mm (66") H.**

Paragraph 2.2.2.10

Add new paragraph number 10: **The burner must be fully enclosed within the casing of the boiler jacket to reduce ambient noise level.**

### **SECTION 2.4: CONTROL UNIT**

Paragraph 2.4

Replace: "CONTROL UNIT (QUANTITY OF 1)" with **CONTROL UNIT (QUANTITY OF 2)**.

Solicitation No. - N° de l'invitation

U6800-163691/A

Amd. No. - N° de la modif.

003

Buyer ID - Id de l'acheteur

hl659

Client Ref. No. - N° de réf. du client

U6800-163691

File No. - N° du dossier

hl659U6800-163691

CCC No./N° CCC - FMS No/ N° VME

---

Paragraph 2.2.4.1

Replace: "two (2) boilers" in a system with **one (1) boiler** in a system.

**The changes in the tender document are effective immediately. This addendum will form part of the contract documents.**

**All other terms and conditions of the Request for Proposal remain unchanged.**

## ANNEX B – PRICING TABLE

### Gas Fired Heating Boilers and Components (Firm Quantity)

The Bidder must provide a unit cost for a quantity of two (2) Gas Fired Heating Boilers, two (2) Control Unit, one (1) Low Loss Header and two (2) circular pumps in accordance with Annex “A” - Purchase Description – Gas Fired Heating Boilers and components.

A	B		C	D	E
Item	Description	Annex A reference – page and section	Quantity	Firm Price per unit (Bidder to complete)	Extended Price excluding taxes - (sum of column C X column D - Bidder to complete -)
1.	Two (2) Gas Fired Heating Boilers*	Page 3 2.1, 2.2, 2.3	2	\$ _____	\$ _____
2.	Two (2) Control Units*	Page 4, 5, 6 & 7 2.4, 2.6	1	\$ _____	\$ _____
3.	One (1) Low Loss Header*	Page 7 2.5	1	\$ _____	\$ _____
4.	Two (2) Circular Pumps*	Page 7 2.6.5	2	\$ _____	\$ _____
5.	Provision of assistance during installation, guidance and assistance during start-up and commissioning and training of operators (including training material).	Page 8 2.8	1	\$ _____	\$ _____
		Total price excluding taxes			\$ _____

**\*Pricing for items 1 to 5 above must include** costs for delivery to (and travel for item 5) 3701 Carling Avenue, Ottawa, ON as well as warranty, as outlined in Annex “A” - Purchase Description – Gas Fired Heating Boilers and components.