



Fisheries and Oceans  
Canada

Pêches et Océans  
Canada

Materiel and Procurement Services  
200 Kent Street, Station 9W071  
Ottawa, Ontario  
K1A 0E6

**FP802-150086**

**August 10, 2015**

**Subject: Invitation to Tender: FP802-150086**

**Title: Mission Small Craft Harbour Electrical Reconstruction, Mission Harbour, BC**

**ADDENDUM: NO. 2**

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#2) is hereby issued.

**Department of Fisheries and Oceans**

**Bid Closing Date: August 11, 2015**  
**Time: 14:00 Hours (2:00 pm) (EST)**  
**File No: FP802-150086**

**Please note: See Invitation to Tender Rev. 2**

---

Q1 Electrical Specifications - Section 26 24 17.02 indicated Item 2.1.1 – TRC panelboards to be 400amp rated, while Electrical Drawings E002, Detail 3 – New Single Line showed TRC panelboards to be 225amp rated.

Which one is correct?

A1 The TRC panelboard should be specified as 400 Amp as per the Specifications Section 26 24 17.02 Item 2.1.1.

Thank you,

**Lara Arsene**  
Senior Contracting Officer,  
Materiel and Procurement Services  
Fisheries and Oceans Canada,  
200 Kent Street, Station 9S021  
Ottawa, ON K1A 0E6  
Tel: (613) 949-9160  
Email: [lara.arsene@dfo-mpo.gc.ca](mailto:lara.arsene@dfo-mpo.gc.ca)