

- MECHANICAL WORK:** x
- REMOVE SECTIONS OF SUPPLY AND RETURN AIR DUCTWORK IN EXISTING MECHANICAL ROOM AT WALL TO ALLOW FOR OPENING SEALING OF DUCTWORK. OPENINGS IN MECHANICAL ROOM WALL CREATED BY REMOVAL OF DUCTWORK SHALL BE SEALED IN KEEPING WITH STANDARDS OF SPECIFICATIONS DURING ASBESTOS ABATEMENT WORK.
 - ALL EXISTING PERIMETER ROUPANT HEATERS SHALL BE SEALED AND KEPT CLEAN IN KEEPING WITH STANDARDS OF SPECIFICATIONS DURING ASBESTOS ABATEMENT WORK.
 - SUPPLY AND RETURN AIR DUCTWORK, BRISSES AND RETURN AIR GRILLES SHALL BE REMOVED AS INDICATED. NOTE THAT RETURN AIR GRILLES ARE INSTALLED IN BLUHEAD.
 - REMOVING ALL EXISTING SUPPLY AND RETURN AIR DUCTWORK SHALL BE IN KEEPING WITH STANDARDS OF SPECIFICATIONS DURING ASBESTOS ABATEMENT WORK.
 - FIRE HOSE CABINET SHALL BE SEALED AND KEPT CLEAN IN KEEPING WITH STANDARDS OF SPECIFICATIONS DURING ASBESTOS ABATEMENT WORK.

ARCHITECTURAL NOTE:

- PC250 CONSTRUCTION WALLS ASSOCIATED WITH OFFICE 222 AND ADJOINING ROOM ARE REMOVED BEFORE COMMENCEMENT OF ASBESTOS ABATEMENT WORK BY MRC.

