



Addenda N° 1

Date : 14 août 2015

Projet: Projet de modernisation des commandes

Les soumissionnaires doivent s'assurer que leurs propositions soient basées sur la version la plus récente des documents de soumission publiés et prennent en considération les informations ci-dessous, incluant toute information déjà publiée lors d'amendements ou Q&Rs antérieurs.

Les propositions ne respectant pas cette exigence seront rejetées.

1 Date de fermeture des soumissions

SUPPRIMER

L'invitation prend fin Mardi, Août 18, 2015, à 02:00 PM, HAE.

AJOUTER

L'invitation prend fin Mardi, Août 25, 2015, à 02:00 PM, HAE.

2 Annexe E – Spécifications technique et plans – Point 2.4 Minimum Requirements for new BAS including Fume Hood Controls (Deliverables)

SUPPRIMER

The BAS system must be a native BACnet system with WEB access capability. Acceptable products include Delta, Alerton, Automated Logic.

AJOUTER

The BAS system must be a native BACnet system with WEB access capability. Acceptable products include Delta, Alerton, Automated Logic and Trane.

Toutes les autres conditions et exigences demeurent inchangées.