



Parks
Canada

Parcs
Canada



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

INVITATION TO TENDER

APPEL D'OFFRES

AMENDMENT / MODIFICATION

002

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Johnston Canyon Rock Stabilization Banff National Park		
Solicitation No. - No. de l'invitation 5P420-15-5168/A		Date: August 14, 2015
GETS Reference No. - No de reference de SEAG PW-15-00694494		Amendment No. - N° de la modif. 002
Solicitation Closes:		
at - à 02:00 PM	on - le August 21, 2015	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Nathaniel Pahl		
Telephone No. - No de téléphone (403) 292-4572		Fax No. - No de FAX: (403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name

Address - Adresse

Name of person authorized to sign on behalf of the Vendor/Firm
Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur

Titale - Titre

Telephone No. - N° de telephone: _____

Facsimile No. - N° de télécopieur: _____

Signature

Date

Amendment 2

This amendment is issued to answer questions from bidders at the mandatory site visit and make changes to the tender documents.

The solicitation closing date has been amended. The new closing date is **August 21 @ 2 PM MDT.**

A. Questions

Q1. The potential supplier at Mannix Pit and Niblock Pit, do they only supply asphalt?

A1. It is up to the contractor to source and supply asphalt and carry out paving.

Q2. What is the type and capacity of the helicopter supplied by parks for mobilization/demobilization?

A2. The contractor should contact Alpine Helicopters for the type and capacity of the helicopter provided.

Q3. Has the trail width been measured with respect to access?

A3. It is the responsibility of the contractor to measure the trail width for access.

Q4. Will hot work permits be required?

A4. It is the contractor's responsibility to get hot permits for required work.

Q5. Does the scaled and dead fall material get disposed of over the side of the trail?

A5. Yes the scaled and dead fall material should be disposed of over the side of the trail. Efforts should be made to limit the amount of material entering the water course.

Q6. Are the walls to be constructed using dry stack methods or with mortar?

A6. Walls will be constructed using Type S cement mortar. The contractor needs to forward the supplier information to the Departmental Representative.

Q7. Is there a specific manufacturer of the railings?

A7. It is up to the contractor to provide and install railings similar to the railing currently on site.

Q8. Which of the railings on site are we following (for bidding purposes)?

A8. For the purposes of bidding, where new railing is specified generally 3 horizontal bar railing shall be installed. Should additional horizontal bars be required this would be considered an extra item.

Q9. Is the expanded metal mesh to be welded or bolted to the railings?

A9. The galvanized expanded mesh shall be bolted to the railing as per design drawing Railing Infill Panels of the tender package.

Q10. Will additional trees be removed during the scaling program?

A10. Yes, the departmental representative will work with the contractor to identify any additional trees and deadfall material requiring removal.

Q11. What is the specification for the paint for the railings?

A11. The paint is to be non-leaded exterior metal paint with the color to match the existing paint at the location. Painting is required at locations of bare metal such as welds, damage to the paint from moving the railing and newly installed components of the railing. The contractor needs to forward the supplier information to the Departmental Representative.

Q12. Can the concrete panels on the cat walks be sourced from any supplier?

A12. Yes, the concrete panels on the elevated cat walks can be sourced from any supplier.

Q13. What is the capacity of the helicopter provided by Parks Canada for mobilization and demobilization?

A13. Contractor should contact Alpine Helicopters for capacity of the helicopter to be provided.

Q14. Can ATVs be used on the elevated cat walks?

A14. Weight limits of the elevated cat walks and the trail width will dictate site access.

Q15. How many hours of helicopter time are provided by parks in the contract?

A15. 8 hours of helicopter time has been provided in the contract by Parks Canada for mobilization and demobilization activities only.

Q16. Where does the helicopter time start from?

A16. Helicopter time starts from the laydown area in the Parks Canada parking lot.

Q17. Where the locations of the existing railing, and what are the number of horizontal bars at these locations?

A17. A table will be provided in the addendum providing the location, length and number of horizontal bars at each location along the trail.

Q18. Why is the removal and reinstallation of the railing along the scaling sections included in the specifications?

A18. The removal of the railing from areas of scaling where included in the specifications to make the risk equal from all bidders. This allows for Parks Canada to take on some of the cost associated with the protection of the elevated catwalks. We encourage the contractor to protect the catwalk during scaling. We are looking for a unit cost for the removal and reinstallation of the existing railing.

B. Mandatory Site Visit Attendees

<u>Name</u>	<u>Company</u>
Jim Guinn	Mountain Rock
Mike Whitaker	Bat Construction
Corry Goumans	Pacific Blasting
Todd Miller	Emil Anderson Construction
Clint Herman	Iron Clad Earthworks
Peter Louvros	Abbott Shoring
Gerard Millar	PCL
Jerry Wong	PCL
Graham Tutt	Global Rock Works
Mark Boehnisch	Guenthers
Trevor Haddon	Trevcon Enterprises Ltd.
Tom Falladown	Big Rock Construction

C. Specifications

The following itemizes changes to the Contract Specifications:

Section 02 21 00 Allowances

Part 1 Clause 1.3.1

The value of the Contract Price Prime Cost Sum has increased from \$75,000 to \$100,000.

Section 01 29 01 Site Occupancy

Part 1 Clause 1.3.3

The maximum lease fee for site occupancy past the construction deadline that the Contractor shall pay Parks Canada has been increased from \$15,000 to \$30,000.

Part 1 Clause 1.3.4

The maximum lease fee for completion of work prior to the construction deadline that Parks Canada shall pay the Contract has been increased from \$15,000 to \$30,000.

Section 05 52 00 Hand Railings

Part 1 Clause 1.1

Removal and replacement of railings of the purposes of trimming and rock scaling.

In this instance the word replacement can be used interchangeably with reinstallation.

All other terms and conditions remain unchanged.