

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
B3J 1T3
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
B3J 3C9
Nova Scot

Title - Sujet Shielded Room	
Solicitation No. - N° de l'invitation W355B-161502/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client W355B-16-1502	Date 2015-08-17
GETS Reference No. - N° de référence de SEAG PW-\$HAL-309-9563	
File No. - N° de dossier HAL-5-75015 (309)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-08-20	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: MacNeil, Blaine A.	Buyer Id - Id de l'acheteur hal309
Telephone No. - N° de téléphone (902) 496-5180 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 3

Please note the following Q & A's:

1/ We will need to know the working load for the floor.

Floor Panels:

.1 Uniformly distributed load of 283.5 kg, with a maximum top surface deflection of 1.02 mm and a permanent set less than .254 mm.

.2 Concentrated load of 1,134 kg applied over an area of 25 x 25 mm at any location with a maximum top surface deflection of 2.54 mm and a permanent set less than .254 mm.

.3 Rolling loads: Solid bare panels when supported on actual understructure shall be able to withstand the following rolling loads at any location on the panel without developing a local or beam surface deformation greater than 1.02 mm.

.1 Wheel 1: 75 mm diameter x 46 mm wide, 907 kg., 10 passes.

.2 Wheel 2: 150 mm diameter x 38 mm wide, 725 kg., 10,000 passes.

2/ Floor will need to be removed to allow for the room and the working space around the room for installation.

FMFCS will remove.

3/ Who is responsible for removing and replacing the floor?

FMFCS

4/ The freight elevator is approx. 16 feet deep. If we bring the 16 foot pieces up in the elevator, can the elevator be captured for the duration of the unloading (or will we be restricted to holding the elevator to certain amount of time?

Yes, we will coordinate to provide elevator access to contractor as required.

5/ We need to know the exact difference between the sub floor and the floor?

250mm from slab to top of floor tile.

6/ can our trucks be parked inside the gates during construction and testing?

Yes

7/ Do the hot permits for electrical etc. come from the dockyard?

Yes, although final electrical connections to shielded room will be made by FMFCS and should not be an issue

8/ Can we weld inside the room (are their special restrictions for welding/electrical on DND property)?

Hot work permit will be required from CFB Halifax fire dept. Contractor will be required to apply directly

9/ You ask for a ramp for access to the room. What weight load capacity would you need for the ramp?

500kg capacity.

10/ You ask for a reversible door. Not sure what is meant by that?"

Remove "reversible" from the description. Doors shall be outswing with left hand hinge.

All other terms and conditions remain unchanged.