



NOTE:
 - RESIDENTIAL CROSSING TO BE MIN. 130mm THICK.
 LANE OR COMMERCIAL CROSSING TO BE MIN.
 180mm THICK.



City of Lethbridge
 INFRASTRUCTURE

**CROSSING THROUGH COMBINED SIDEWALK
 ROLLED CURB AND GUTTER**

REVI: CURB RADII TO 20. DI FROM TOP
 OF CROSSING TO SIDEWALK 60

DRAWN jrg

CHECKED

APPROVED

SCALE N.T.S.

DATE 99/05/03

REV. DATE 99/12/14

DWG NO

STR_14_0