



- NOTE:
- ALL DIMENSIONS ARE IN MILLIMETERS
 - ALL VALVES LEFT TURN TO OPEN (COUNTER-CLOCKWISE) FOR MAIN SIZES 150mm TO 300mm
 - CONCRETE SHALL OBTAIN A MINIMUM COMPRESSIVE STRENGTH OF 30 MPa @ 28 DAYS. ALL CEMENT TO BE TYPE 50 (SULPHATE RESISTANT).

REVISED	<div><div>CITY OF <i>Lethbridge</i> INFRASTRUCTURE SERVICES</div></div>	DRAWN	P.R.A.
		CHECKED	
		APPROVED	
		SCALE	N.T.S.
		DATE	95/05/11
	STANDARD GATE VALVE INSTALLATION	DWG NO	W-07