



Scale: Horiz. 1:500
Vert. 1:50

PRELIMINARY
NOT FOR CONSTRUCTION

WATERMAIN DATA				
STATION	REF.	INVERT	DESCRIPTION	REMARKS
24+264.7	V3	1283.573	150mm GATE VALVE	
24+265.6	F4	1283.554	150 x 150 x 150 TEE	
24+266.6	V5	1283.533	150mm GATE VALVE	
24+303.4	DV1		LOCATE, CUT & CONNECT DRAIN VALVE IN CHAMBER	
24+319.9	H03	1282.787	HYDRANT #33, VALVE AND TEE	
24+340.2	DV2		LOCATE, CUT & CONNECT DRAIN VALVE IN CHAMBER	
24+399	DV3		LOCATE, CUT & CONNECT DRAIN VALVE IN CHAMBER	
24+437.7	DV4		LOCATE, CUT & CONNECT DRAIN VALVE IN CHAMBER	
24+485.2	V10	1280.709	150mm GATE VALVE	
24+486.3	H34	1280.698	HYDRANT #34, VALVE AND TEE	
35+002.6	V4	1283.567	150mm GATE VALVE	
35+004.5	F19	1283.585	5" BEND	



Consultant's Name
Nom de l'expert-conseil
Amec Foster Wheeler
Environment & Infrastructure
469 - 40th Street South
Lethbridge, Alberta CANADA T1J 4M1
Tel. (403) 329-1467
Fax (403) 327-4938

Eng. Stamp
Sceau de l'ingénieur
B. ZACHER
PROFESSIONAL ENGINEER (L.B.E.T.A.)
P. ENG. DATE

DO NOT SCALE DRAWINGS

Revision/Revision	Description/Description	Date/Date
5		
4		
3		
2	100% DESIGN COMPLETION	07/13/18
1	75% DESIGN COMPLETION	07/01/18
0	50% DESIGN COMPLETION	05/17/18

Client/client
Parks Canada / L'Agence Parcs Canada
Western and Northern Region / Ouest et Nord du Canada

Project title/Titre du projet
WATERTON TOWNSITE MUNICIPAL INFRASTRUCTURE UPGRADES PHASE A AND B
WATERTON NATIONAL PARK ALBERTA

Approved by/Approuvé par
B. ZACHER

Designed by/Concepté par
B. JOHNSON

PWGSC Project Manager/Administrateur de Projets TPSGC
M. BURKE

PWGSC, Architectural and Engineering Resources Manager/ Ressources Architectural et de Directeur d'Ingénierie, TPSGC
J. LAMBE

Client/client
J. LAMBE

Drawing title/Titre du dessin
NEW UTILITIES EVERGREEN AVENUE SOUTH PLAN PROFILE
Sta. 24+280 to Sta. 24+540

Project No./No. du projet R.075721.001	Sheet/Feuille C15 OF 41	Revision no./La Révision no. 2
--	--------------------------------------	--



- NOTES:
1. ALL HOUSES, BATHROOMS AND KITCHEN SHELTER WATER AND SANITARY SERVICES REQUIRE RECONNECTION UNLESS OTHERWISE DIRECTED BY THE DEPARTMENTAL REPRESENTATIVE. THIS SHALL INCLUDE A NEW CURB STOP.
 2. ALL WATER INSTALLATIONS SHALL BE IN ACCORDANCE WITH SPECIFICATION SECTION 33 11 16.
 3. ALL SANITARY INSTALLATIONS SHALL BE IN ACCORDANCE WITH SPECIFICATION SECTION 33 31 13.
 4. HISTORIC FILES SHOW EXISTING WATER AND SANITARY SERVICES ARE LOCATED IN A COMMON TRENCH FOR ALL HOUSES EXCEPT WHERE SANITARY SERVICE SHOWN AND LOT MARKED WITH Δ .