



PIPE SIZE	MAX SIZE OF OUTLET ALLOWED WITH CL 150 AC PIPE		MAX SIZE OF OUTLET WITH PVC PIPE CL 150 (SDR.18)	
	CORPORATION STOP ONLY	CORP STOP WITH SERVICE SADDLE	CORPORATION STOP ONLY	CORP STOP WITH SERVICE SADDLE
100	-	25	20	50
150	-	37	25	50
200	-	50	25	50
250	-	50	25	50
300	-	50	25	50
350	-	50	25	50
400	-	50	25	50

NOTES:

1. CORPORATION STOPS TO BE STAGGERED AND AT LEAST 400 mm APART.
2. CORPORATION STOPS TO BE 300 mm MIN. FROM END OF PIPE SECTION.
3. USE AWWA THREAD FOR ALL DIRECT TAPS & SERVICE SADDLE CONNECTIONS
4. FOR CONNECTIONS IN EXISTING AREAS, HORIZONTAL GOOSENECK TO BE FORMED IF DEPTH IS LESS THAN 1500 mm
5. TRACER WIRE SHALL BE INSTALLED IN CUL-DE-SACS AND WHERE SPECIFIED BY THE CITY ENGINEER.

REVISED	 <div>CITY OF <i>Lethbridge</i> INFRASTRUCTURE SERVICES</div>	DRAWN	P.R.A.
DEC 15, 2005		CHECKED	
		APPROVED	
		SCALE	N.T.S.
		DATE	97/03/11
	STANDARD FOR 20mm & 25mm WATER SERVICE	DWG NO	W-02