

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions  
Travaux publics et Services gouvernementaux  
Canada**  
**1713 Bedford Row**  
**Halifax, N.S./Halifax, (N.É.)**  
**B3J 1T3**  
**Bid Fax: (902) 496-5016**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Atlantic Region Acquisitions/Région de l'Atlantique  
Acquisitions  
1713 Bedford Row  
Halifax, N.S./Halifax, (N.É.)  
B3J 3C9  
Nova Scot

<b>Title - Sujet</b> Shielded Room	
<b>Solicitation No. - N° de l'invitation</b> W355B-161502/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> W355B-16-1502	<b>Date</b> 2015-08-17
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$HAL-309-9563	
<b>File No. - N° de dossier</b> HAL-5-75015 (309)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-08-20</b>	<b>Time Zone</b> Fuseau horaire Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> MacNeil, Blaine A.	<b>Buyer Id - Id de l'acheteur</b> hal309
<b>Telephone No. - N° de téléphone</b> (902) 496-5180 ( )	<b>FAX No. - N° de FAX</b> (902) 496-5016
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

## Amendment #4

### More Q&A:

- Raised floor looked to be 12 inches RF room floor requested is 10 inches, is this correct? If not, what is the precise measurement of the existing raised floor?

Existing raised floor is 250mm to top of tile. New RF room floor to match existing height.

- Standard doorsill is 1 1/2 inches, with room sitting on the subfloor is this still to be at 1' 1 3/4"?

Bottom of sill to be flush with top of raised floor panels.

- What is meant by reversible door?

Already answered.

- Two feet of flooring and support structure complete with mechanical systems around RF room require removal - who is responsible for removal and installation?  
FMFCS

- Is cutting and welding allowed in area of assembly?

Yes, with proper permits as required by CFB Halifax Fire Dept.

- What tickets are required by yard, i.e. welding & cutting and are these provided by the yard? Can these be acquired before installation starts?

Contractor will be required to apply to Base Fire Dept. for hot work permits.

- Looks to be only 6 inches above ceiling tiles before sprinklers and other mechanical systems possibly interfere, who is responsible for decommissioning and recommissioning of the systems?

FMFCS will make final power, air, sprinkler, and fire alarm connections.

- There is multiple 24 ft beams required. Is there any access for these beams, if not can a window be removed and who is responsible for the costs?  
Elevator is 8'x16'. It will not allow 24' beam. Contractor responsible for all costs associated with installation of the room.

Solicitation No. - N° de l'invitation

W355B-161502/A

Client Ref. No. - N° de réf. du client

W355B-16-1502

Amd. No. - N° de la modif.

004

File No. - N° du dossier

HAL-5-75015

Buyer ID - Id de l'acheteur

hal309

CCC No./N° CCC - FMS No/ N° VME

- 
- Two lifts are required weighing 2600 lbs a piece, can the flooring system support these lifts?

Floor specifications as indicated in previous question group.

All other terms and conditions remain unchanged.