

**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:**  
Regional Manager/Real Property  
Contracting/PWGSC  
Ontario Region, Tendering Office  
12th Floor, 4900 Yonge Street  
Toronto, Ontario  
M2N 6A6  
Ontario

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

**Vendor/Firm Name and Address**  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**  
Regional Manager/Real Property Contracting/PWGSC  
Ontario Region, Tendering Office  
12th Floor, 4900 Yonge Street  
Toronto, Ontario  
M2N 6A6  
Ontario

<b>Title - Sujet</b> Roof Railing & Lighting Rod Install	
<b>Solicitation No. - N° de l'invitation</b> 23240-160318/A	<b>Amendment No. - N° modif.</b> 005
<b>Client Reference No. - N° de référence du client</b> 23240-160318	<b>Date</b> 2015-08-18
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWL-039-2030	
<b>File No. - N° de dossier</b> PWL-5-38058 (039)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-08-25</b>	<b>Time Zone</b> Fuseau horaire Eastern Daylight Saving Time EDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Hassell, Bob	<b>Buyer Id - Id de l'acheteur</b> pwl039
<b>Telephone No. - N° de téléphone</b> (416) 590-8270 ( )	<b>FAX No. - N° de FAX</b> (416) 512-5862
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Natural Resources Canada 580 Booth Street Ottawa, Ontario K1A 0E4	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> Raison sociale et adresse du fournisseur/de l'entrepreneur	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

## QUESTIONS AND ANSWERS

### Question 2 :

With reference to drawing A1, there is a single post detailed to be installed adjacent to existing building structure (4 locations). Typically on previous installations there is single post with rail extensions to allow for the installation of the swaged cable ends. See attached previous detail. Please advise if we are to use as single post detail or if a single post with rail extensions is desired.(see attached drawing)

### Answer 2:

Provide new end post as per attached sketch SK1 (typical 4 locations) where roof railing system ends at adjacent buildings to allow for installation of swaged cable ends.

### Question 3:

Please provide a list of attendees of the site meeting on Monday, Aug 10.

### Answer 3:

The attendee list will be posted on BuyandSell

### Question 4:

dwg A1 refers to Dwg M2 (see DWG M2), is this drawing available

### Answer 4:

The reference "M2" is an error. Please substitute "SEE DWG. A2" in place of "SEE DWG. M2"

### Question 5:

please provide Specifications for the lightning rod system, more specifically make and model of the new lightning rods to be installed.

### Answer 5:

NRCan does not require and will not specify a specific manufacturer. It is the vendor's responsibility to source a sub-contractor and supplier sufficiently knowledgeable and qualified to provide and install the basic components required to make the changes to the system as designed on the drawings in a manner acceptable to the authority having jurisdiction.