

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 26 05 00 - Common Work Results - Electrical.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International).
 - .1 CAN/CSA-C22.2 No.18, Outlet Boxes, Conduit Boxes, Fittings and Associated Hardware.
 - .2 CSA C22.2No.65, Wire Connectors.
 - .1 CSA C22.2 n° 41, Equipment Grounding and Bonding.
 - .2 Manufacturers Association of Electrical and Electronic Equipment of Canada (EEMAC).
 - .1 EEMAC 1Y 2, Connectors and Terminals Crossing Aluminum Adapters (rated 1,200 A).
 - .3 National Electrical Manufacturers Association (NEMA).

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Pressure type wire connectors to: CSA C22.2 No. 65, with current carrying parts of copper sized to fit copper conductors according to the requirements of this project.
 - .2 Fixture type splicing connectors conform to CSA C22.2 No. 65, with current carrying parts of copper sized to fit copper conductors 10 AWG or less.
 - .3 Clamps or connectors for armoured cable.flexible conduit, as required, in accordance with standard CAN/CSA C22.2 No. 18.
-

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Remove insulation carefully from ends of conductors and:
 - .1 Install mechanical pressure type connectors and tighten screws with appropriate compression tool recommended by manufacturer. Installation shall meet secureness tests in accordance with CSA C22.2 No. 65.
 - .2 Install fixture type connectors and tighten. Replace insulating cap.
 - .3 Install bushing stud connectors in accordance with EEMAC 1Y 2.
 - .4 If needed, make the grounding and bonding in accordance with CSA C22.2 No. 41.

END OF SECTION
