

SANDY BAY RCMP  
DETACHMENT

FUEL STORAGE AND  
DISPENSING SYSTEM

GENERAL NOTES

1. ALL CONSTRUCTION AND MATERIALS TO BE IN ACCORDANCE WITH THE CONTRACT DOCUMENTS, SPECIFICATIONS AND AS SHOWN ON THESE DRAWINGS.
2. PERFORM WORK IN ACCORDANCE WITH THE MOST RECENT EDITIONS OF: NATIONAL BUILDING CODE, NATIONAL FIRE CODE, CGME, CEPA AND CANCSA-B139. STORAGE TANK TO CANULC-5001-14.
3. CEPA REGULATIONS REQUIRE ALL PETROLEUM INSTALLATION AND DECOMMISSIONING TO BE COMPLETED BY A CERTIFIED PETROLEUM INSTALLER REGISTERED IN THE PROVINCE OF SASKATCHEWAN.
4. LOCATION OF ALL EXISTING SERVICES, FEATURES AND APPURTENANCES SHOWN ON THE DRAWINGS ARE TO BE CONSIDERED APPROXIMATE ONLY. VERIFY ALL LOCATIONS IN THE FIELD PRIOR TO CONSTRUCTION.
5. CONTRACTOR TO OBTAIN ALL REQUIRED PERMITS.
6. CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR CONSTRUCTION MEANS, METHODS, TECHNIQUES, SEQUENCES AND PROCEDURES AND CO-ORDINATING THE VARIOUS PARTS OF THE WORK.
7. DISPOSE OF ALL EXCAVATED MATERIAL UNSUITABLE FOR REUSE AT A SUITABLE OFF-SITE DISPOSAL AREA, IN ACCORDANCE WITH ALL APPLICABLE REGULATIONS.
8. ANY DAMAGE TO EXISTING SERVICES OR UTILITIES SHALL BE REINSTATED TO AS-FOUND OR BETTER CONDITION.
9. ALL SITES AFFECTED BY CONSTRUCTION SHALL BE RESTORED TO AS FOUND OR BETTER CONDITION.
10. CAREFULLY RELOCATE EXISTING LANDSCAPE FEATURES AND SITE FEATURES TO ACCOMMODATE CONSTRUCTION WORK. ALL SUCH ITEMS SHALL BE REPLACED TO ORIGINAL OR BETTER CONDITION, TO THE APPROVAL OF THE CONTRACT ADMINISTRATOR.
11. ALL DEBRIS AND EQUIPMENT FROM DEMOLITION AND CONSTRUCTION TO BE DISPOSED OF AT AN OFFSITE LOCATION APPROVED BY THE CONTRACT ADMINISTRATOR.


drawing index			
title	dwg no.	rev.	sht no.
COVER SHEET	G101	2	1
SITE PLAN, TANK AND PIPING DETAILS	M101	2	2
ELECTRICAL	E101	2	3

LOCATION PLAN



SITE PLAN






Public Works and  
Government Services  
Canada

Travaux publics et  
Services gouvernementaux  
Canada

REAL PROPERTY SERVICES  
Western Region  
SERVICES IMMOBILIERS  
Région de l'Ouest



SUITE 400-401 GARBALLY ROAD  
VICTORIA BRITISH COLUMBIA CANADA V8T 9M3  
TEL: 250-384-5510 | FAX: 250-386-2844 | WWW.WSPGROUP.COM  
141-24873-00

5		
4		
3		
2	ISSUED FOR TENDER	2015/02/27
1	ISSUED FOR 99% CLIENT REVIEW	2015/01/30
0	ISSUED FOR 50% CLIENT REVIEW	2014/12/22
Revision/ Révision	Description/Description	Date/Date

Client/client

RCMP  
PWGSC

Project title/Titre du projet

RCMP SANDY BAY, SK

FUEL STORAGE AND  
DISPENSING SYSTEM

Consultant Signature Box Only

Designed by/Concept par  
DMH

Drawn by/Dessiné par  
SG

PWGSC Project Manager/Administrateur de Projets TPSGC  
Laura Barz

PWGSC Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architectural et de génie, TPSGC

Drawing title/Titre du dessin

COVER SHEET

Project No./No. du projet  
R.073302.001

Sheet/Feuille  
G101  
1 OF 3

Revision no./  
La Révision  
no.  
2

PWGSC – B1 – 1000X707

0 10 20 30 40 50 60 70 80 90 100mm

DM5XXXXX