



Matériel and Procurement Services  
200 Kent Street, Station 9W087  
Ottawa, Ontario  
K1A 0E6

**FP802-150109**

**August 21, 2015**

**Subject: Invitation to Tender: FP802-150109**

**Title: LightStation Restoration in New Ferolle, NL**

**ADDENDUM: NO. 1**

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#1) is hereby issued.

**Department of Fisheries and Oceans**

**Bid Closing Date: September 1, 2015**

**Time: 14:00 Hours (2:00 pm) Eastern Daylight Time (EDT)**

**File No: FP802-150109**

- 
- Q1 How much Belzona 1111 Super Metal Paste Grade Metallic Filler is to be carried in Bid price for filling pitted areas of cast iron dome?
- A1 5 kg package to be assumed
- Q2 Where is the lead paint located?
- A2 Paint concentrations exceeding 90mg/kg have been noted on the concrete portion of the tower, as noted in the specifications.
- Q3 Is there lead paint on the dome?
- A3 The concentration of lead in paint on the dome is less than 90mg/kg. The laboratory results are appended to the specifications.
- Q4 Are certified cheques acceptable in lieu of bonding?
- A4 Yes, if you are putting in a bid, a certified cheque is acceptable in lieu of bonding.
- Q5 What is the requirement for scaffolding?
- A5 Engineering/stamped drawing as noted in the tender documents.

Thank you,

**Nancy L. Stanford**

Senior Contracting Officer,  
Materiel and Procurement Services

Fisheries and Oceans Canada,

200 Kent Street, Station 9W087

Ottawa, ON K1A 0E6

Tel: (613) 991-1550

Email: [nancy.stanford@dfo-mpo.gc.ca](mailto:nancy.stanford@dfo-mpo.gc.ca)