



ADDENDA / ADDENDUM N° 2

**« Réaménagement des clôtures déterminant les zones
d'opérations »**

“Reorganization of fences separating the operation zones”

**ÉTABLISSEMENT CENTRE FÉDÉRAL DE FORMATION/
FEDERAL TRAINING CENTER INSTITUTION**

N° de dossier / File # : 21301-16-2210542

Section 32 31 13

2.1 OSSATURE MÉTALLIQUE

.1.1.5 Les poteaux d'angle et de barrière doivent avoir un diamètre extérieur minimal de 143.3mm et une densité de 21Kg/m.

REPLACÉ PAR

.1 .1.5 Les poteaux d'angle et de barrière doivent avoir un diamètre extérieur minimal de **114.3mm** et une densité de **15.92Kg/m**.

Disjoncteurs dans le panneau 600V des barrières motorisées : EDB36015 SquareD 600V 15A (par nous).

Toutes autres clauses et conditions demeurent inchangées.

Section 32 31 13

2.1 METALLIC FRAMEWORK

.1.1.5 The corner and gate posts must have a minimum outside diameter of 143.3mm and a density of 21kg/m.

REPLACED BY

.1 .1.5 The corner and gate posts must have a minimum outside diameter of **114.3mm** and a density of **15.92kg/m**.

Breakers in the 600V panel of the motorized gates : EDB36015 SquareD 600V 15A (by us).

All other terms and conditions remain unchanged.