

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Authority, Darlene Reay, either by facsimile or by e-mail at:
darlene.reay@pwgsc.gc.ca.

Vendor/Firm Name and Address

**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Asphalt Resurfacing, Fundy	
Solicitation No. - N° de l'invitation EC015-160881/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client R.076566.002	Date 2015-08-28
GETS Reference No. - N° de référence de SEAG PW-\$PWB-021-3675	
File No. - N° de dossier PWB-5-38055 (021)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-09-03	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Reay, Darlene	Buyer Id - Id de l'acheteur pwb021
Telephone No. - N° de téléphone (902) 566-7518 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Addendum # 1
August 28, 2015

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY. THIS ADDENDA SHALL FORM PART OF THE CONTRACT DOCUMENTS.

Question # 1

We are looking for a few clarifications on item 8 w-beam guide rail for the above noted contract. Section 34 71 13.25 of the specifications makes reference or seems to imply that new w-beam guide rail is to be supplied and installed as part of this contract. On drawing C-1 of the documents, there is a note on the detail named "Typical Section For Guide Rail Post Replacement" clearly indicating the "existing w-beam to be salvaged and reinstalled". We would also like to know if there are existing delineators to be salvaged and reinstalled or if we are to supply and install "new reflective strips immediately under the rail" as indicated in section 3.03.9 of the w-beam guide rail specification. If the latter is the case, what are these reflective strips?

Answer # 1

Contractor is to salvage existing W-Beam and reinstalled as per detail on drawings. Contractor is to supply and install new delineators at the locations indicated on the drawings. New Reflective strips are not required on this contract.