

Solicitation No. - N° de l'invitation

EC015-160696/B

Client Ref. No. - N° de réf. du client

R.073048.001

Amd. No. - N° de la modif.

002

File No. - N° du dossier

PWD-5-38092

Buyer ID - Id de l'acheteur

pwd009

CCC No./N° CCC - FMS No/ N° VME

AMENDMENT # 2

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY.
THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

GENERAL QUESTIONS:

Item 1 Q: Supply specification/drawings for the heater which is to be relocated. Is this heater supplied by hot water or Glycol? Will any inspection/testing need to be completed on the piping after relocation.

A: The heater is supplied by hot water. An inspection will not be required after relocation.

Item 2 Q: Will load testing be required for the new monorail?

A: Yes, load testing will be required

Item 3 Q: Will we be able to use facilities at the Wabush Airport (i.e. Washrooms and lunchrooms?)

A: Yes, the contractor will have access to site facilities including the washrooms and the lunchroom while on site.

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.
