


REMARKS	POWER: 120/240, 1P, 3W				PANEL: BREAKER PANEL				SYM. I.C.: 22,000 AMPS			
	No. Of CCTS.: 12				LOCATION: LIFT STATION				MAINS: 30 AMPS			
					FED FROM: SPLITTER				ENTER AT: MTG.			
	DESIGNATION		LOAD		CIR.			CIR.	LOAD		DESIGNATION	
	PH	A PH B	No.	BKR	No.			PH	A PH B			
GFI	INTERIOR LIGHTS		1	15A	1	15A	2	EXTERIOR LIGHTS		GFI		
	RECEPTACLES			3 15A	1	15A	4	RECEPTACLES				
	SPARE			5 15A	1	15A	6	SPARE				
	SPACE			7			8	SPACE				
	SPACE			9			10	SPACE				
	SPACE			11			12	SPACE				
PHASE A - TOTAL					SOURCE: _____							
PHASE B - TOTAL					FEEDER: _____							
TOTAL LOAD: _____ KW. _____ AMP.					_____							
REMARKS: ① NEMA 4X ENCLOSURE ② TYPICAL FOR BOTH LIFT STATION BUILDINGS												

 Public Works and
Government Services
Canada

Travaux Publics et
Services gouvernementaux
Canada

CBCL 60
CBCL LIMITED
Consulting Engineers
ISO 9001 CERTIFIED

NOTES:

1. ALL WORK TO BE COORDINATED WITH THE DEPARTMENTAL REPRESENTATIVE.
2. REFER TO SPECIFICATION SECTION 26 90 00 FOR CONTROL PANEL.

0	ISSUED FOR TENDER	JULY 2015
B	ISSUED FOR 80% REVIEW	JULY 2015
revisions		date

project	project
---------	---------

PARKS CANADA
CAVENDISH/BRACKLEY
SEWAGE PUMP STATION
UPGRADES

drawing	dessin
---------	--------

CAVENDISH CAMPGROUND
MODIFIED SEWAGE PUMP
STATION UPGRADE
MISCELLANEOUS
DETAILS

designed	HICK	conçu
----------	------	-------

date JULY 2015

drawn D. ABREY dessin

date JULY 2015

approved	approuvé
----------	----------

date _____

Tender 1071 Soumission

PWGSC Project Manager *[Signature]* Administrateur de projets TPSGC

project number	no. du projet
----------------	---------------

R.075015.001

CBCL DRAWING No. 152618_M-E_CAVENDISH

E-DRM/GDD-E: 526316 Version 1