

Part 1 General

1.1 SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Shop drawings to show:
 - .1 Mounting arrangements.
 - .2 Operating and maintenance clearances.
- .3 Shop drawings and product data accompanied by:
 - .1 Detailed drawings of bases, supports, and anchor bolts.
 - .2 Acoustical sound power data, where applicable.
 - .3 Points of operation on performance curves.
 - .4 Manufacturer to certify current model production.
 - .5 Certification of compliance to applicable codes.
- .4 In addition to transmittal letter referred to in Section 01 33 00 - Submittal Procedures: use MCAC "Shop Drawing Submittal Title Sheet". Identify section and paragraph number.
- .5 Closeout Submittals:
 - .1 Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
 - .2 Operation and maintenance manual approved by, and final copies deposited with, Departmental Representative before final inspection.
 - .3 Operation data to include:
 - .1 Control schematics for systems including environmental controls.
 - .2 Description of systems and their controls.
 - .3 Description of operation of systems at various loads together with reset schedules and seasonal variances.
 - .4 Operation instruction for systems and component.
 - .5 Description of actions to be taken in event of equipment failure.
 - .6 Valves schedule and flow diagram.
 - .7 Colour coding chart.
 - .4 Maintenance data to include:
 - .1 Servicing, maintenance, operation and trouble-shooting instructions for each item of equipment.
 - .2 Data to include schedules of tasks, frequency, tools required and task time.
 - .5 Performance data to include:
 - .1 Equipment manufacturer's performance datasheets with point of operation as left after commissioning is complete.
 - .2 Equipment performance verification test results.
 - .3 Special performance data as specified.
 - .4 Testing, adjusting and balancing reports as specified in Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.

-
- .6 Approvals:
 - .1 Submit two (2) copies of draft Operation and Maintenance Manual to Departmental Representative for approval. Submission of individual data will not be accepted unless directed by Departmental Representative.
 - .2 Make changes as required and re-submit as directed by Departmental Representative .
 - .7 Additional data:
 - .1 Prepare and insert into operation and maintenance manual additional data when need for it becomes apparent during specified demonstrations and instructions.
 - .8 Site records:
 - .1 Departmental Representative will provide one (1) set of reproducible mechanical drawings. Provide sets of white prints as required for each phase of work. Mark changes as work progresses and as changes occur. Include changes to existing mechanical systems, control systems and low voltage control wiring.
 - .2 Transfer information weekly to reproducibles, revising reproducibles to show work as actually installed.
 - .3 Use different colour waterproof ink for each service.
 - .4 Make available for reference purposes and inspection.
 - .9 As-built drawings:
 - .1 Prior to start of Testing, Adjusting and Balancing for HVAC, finalize production of as-built drawings.
 - .2 Identify each drawing in lower right hand corner in letters at least 12 mm high as follows: - "AS BUILT DRAWINGS: THIS DRAWING HAS BEEN REVISED TO SHOW MECHANICAL SYSTEMS AS INSTALLED" (Signature of Contractor) (Date).
 - .3 Submit to Departmental Representative for approval and make corrections as directed.
 - .4 Perform testing, adjusting and balancing for HVAC using as-built drawings.
 - .5 Submit completed reproducible as-built drawings with Operating and Maintenance Manuals.
 - .10 Submit copies of as-built drawings for inclusion in final TAB report.

1.2 MAINTENANCE

- .1 Furnish spare parts in accordance with Section 01 78 00 - Closeout Submittals.

Part 2 Products

2.1 NOT USED

Part 3 Execution

3.1 CLEANING

- .1 Clean interior and exterior of all systems including strainers. Vacuum interior of ductwork.

3.2 DEMONSTRATION

- .1 Departmental Representative will use equipment and systems for test purposes prior to acceptance. Supply labour, material, and instruments required for testing.
- .2 Trial usage to apply to following equipment and systems:
 - .1 Exhaust fan.
 - .2 Forced air unit heater.
- .3 Supply tools, equipment and personnel to demonstrate and instruct operating and maintenance personnel in operating, controlling, adjusting, trouble-shooting and servicing of all systems and equipment during regular work hours, prior to acceptance.
- .4 Use operation and maintenance manual, as-built drawings, and audio visual aids as part of instruction materials.
- .5 Instruction duration time requirements as specified in appropriate sections.
- .6 Departmental Representative may record these demonstrations on video tape for future reference.

3.3 PROTECTION

- .1 Protect equipment and systems openings from dirt, dust, and other foreign materials with materials appropriate to system.

END OF SECTION

Part 1 General

1.1 REFERENCES

- .1 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-1.181-99, Ready-Mixed Organic Zinc-Rich Coating.

Part 2 Products

2.1 NOT USED

- .1 Not Used.

Part 3 Execution

3.1 CONNECTIONS TO EQUIPMENT

- .1 In accordance with manufacturer's instructions unless otherwise indicated.
- .2 Use valves and either unions or flanges for isolation and ease of maintenance and assembly.
- .3 Use double swing joints when equipment mounted on vibration isolation and when piping subject to movement.

3.2 CLEARANCES

- .1 Provide clearance around systems, equipment and components for observation of operation, inspection, servicing, maintenance, and as recommended by manufacturer.
- .2 Provide space for disassembly, removal of equipment, and components as recommended by manufacturer or as indicated (whichever is greater) without interrupting operation of other system, equipment, and components.

3.3 DRAINS

- .1 Install piping with grade in direction of flow except as indicated.
- .2 Install drain valve at low points in piping systems, at equipment and at section isolating valves.
- .3 Pipe each drain valve discharge separately to above floor drain. Discharge to be visible.
- .4 Drain valves: NPS 3/4 gate or globe valves unless indicated otherwise, with hose end male thread, cap and chain.

3.4 AIR VENTS

- .1 Install manual air vents at high points in piping systems.
- .2 Install isolating valve at each automatic air valve.

- .3 Install drain piping to approved location and terminate where discharge is visible.

3.5 DIELECTRIC COUPLINGS

- .1 General: Compatible with system, to suit pressure rating of system.
- .2 Locations: Where dissimilar metals are joined.
- .3 NPS 2 and under: isolating unions or bronze valves.
- .4 Over NPS 2: Isolating flanges.

3.6 PIPEWORK INSTALLATION

- .1 Screwed fittings jointed with Teflon tape.
- .2 Protect openings against entry of foreign material.
- .3 Install to isolate equipment and allow removal without interrupting operation of other equipment or systems.
- .4 Assemble piping using fittings manufactured to ANSI standards.
- .5 Saddle type branch fittings may be used on mains if branch line is no larger than half the size of main.
 - .1 Hole saw (or drill) and ream main to maintain full inside diameter of branch line prior to welding saddle.
- .6 Install exposed piping, equipment, rectangular cleanouts and similar items parallel or perpendicular to building lines.
- .7 Install concealed pipework to minimize furring space, maximize headroom, conserve space.
- .8 Slope piping, except where indicated, in direction of flow for positive drainage and venting.
- .9 Install, except where indicated, to permit separate thermal insulation of each pipe.
- .10 Group piping wherever possible and as indicated.
- .11 Ream pipes, remove scale and other foreign material before assembly.
- .12 Use eccentric reducers at pipe size changes to ensure positive drainage and venting.
- .13 Provide for thermal expansion as indicated.
- .14 Valves:
 - .1 Install in accessible locations.
 - .2 Remove interior parts before soldering.
 - .3 Install with stems above horizontal position unless otherwise indicated.
 - .4 Valves accessible for maintenance without removing adjacent piping.
 - .5 Install globe valves in bypass around control valves.
 - .6 Use gate valves at branch take-offs for isolating purposes except where otherwise
- .15 Check Valves:

- .1 Install silent check valves on discharge of pumps and elsewhere as indicated.
- .2 Install swing check valves in horizontal lines on discharge of pumps and elsewhere as indicated.

3.7 SLEEVES

- .1 General: Install where pipes pass through masonry, concrete structures, fire rated assemblies, and elsewhere as indicated.
 - .1 Provide Fab Pipe Inc. Ductile Iron Wall Sleeves (or approved equivalent), as indicated on mechanical drawing.
 - .1 Sleeves fabricated from ductile iron pipe conforming to ANSI/AWWA C151/A21.51, nominal wall thickness dimensions conforming to Class 53.
 - .2 Wall collars fabricated from ductile iron conforming to ASTM A536 to dimensions referenced in ANSI/AWWA C115/A21.15 Appendix C.
 - .3 Collars attached to sleeves using automatic arc welding as per ANSI/AWWA C115/A21.15 Appendix C and NAPF 700.
 - .4 Coatings and Linings:
 - .1 Ductile iron wall sleeves are to be finished with bituminous coating and lining per ANSI/AWWA C151.A21.51.
- .2 Sizes: 6 mm minimum clearance between sleeve and non-insulated pipe or between sleeve and insulation.
- .3 Installation:
 - .1 Concrete, masonry walls, concrete floors on grade: Terminate flush with finished surface.
 - .2 Other floors: Terminate 25 mm (minimum) above finished floor.

3.8 PREPARATION FOR FIRESTOPPING

- .1 Non-insulated unheated pipes not subject to movement: No special preparation.
- .2 Non-insulated heated pipes subject to movement: Wrap with non-combustible smooth material to permit pipe movement without damaging firestopping material or installation.
- .3 Insulated pipes and ducts: Ensure integrity of insulation and vapour barriers.

3.9 FLUSHING OUT OF PIPING SYSTEMS

- .1 Preparatory to acceptance, clean and refurbish equipment and leave in operating condition, including replacement of filters in piping systems.

3.10 PRESSURE TESTING OF EQUIPMENT AND PIPEWORK

- .1 Advise Departmental Representative forty-eight (48) hours minimum prior to performance of pressure tests.
- .2 Pipework: Test as specified in relevant sections of Division 22 and 23.

- .3 Maintain specified test pressure without loss for four (4) hours minimum unless specified for longer period of time in relevant sections of Division 22 and 23.
- .4 Prior to tests, isolate equipment and other parts that are not designed to withstand test pressure or media.
- .5 Conduct tests in presence of Departmental Representative.
- .6 Pay costs for repairs or replacement, retesting, and making good. Departmental Representative to determine whether repair or replacement is appropriate.
- .7 Insulate or conceal work only after approval and certification of tests by Departmental Representative.

END OF SECTION

Part 1 General

1.1 SUMMARY

- .1 Section Includes:
 - .1 Bronze - valves.
- .2 Sustainable requirements for construction and verification.
 - .1 Not used.

1.2 REFERENCES

- .1 American National Standards Institute (ANSI)/ American Society of Mechanical Engineers (ASME).
 - .1 ANSI/ASME B1.20.1-2003 (R2001), Pipe Threads, General Purpose (Inch).
 - .2 ANSI/ASME B16.18-2001, Cast Copper Alloy Solder Joint Pressure Fittings.
- .2 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM A276-04, Specification for Stainless Steel Bars and Shapes.
 - .2 ASTM B62-02, Specification for Composition Bronze or Ounce Metal Castings.
 - .3 ASTM B283-99a, Specification for Copper and Copper Alloy Die Forgings (Hot-Pressed).
 - .4 ASTM B505/B505M-02, Specification for Copper-Base Alloy Continuous Castings.
- .3 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS).
 - .1 MSS-SP-25-2008, Standard Marking System for Valves, Fittings, Flanges and Unions.
 - .2 MSS-SP-80-2003, Bronze Gate Globe, Angle and Check Valves.
 - .3 MSS-SP-110-1996, Ball Valves, Threaded, Socket-Welding, Solder Joint, Grooved and Flared Ends.
- .4 American National Standards Institute (ANSI) / National Sanitation Foundation (NSF).
 - .1 ANSI/NSF-2014, Drinking Water System Components – Health Effects.

1.3 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data: Submit WHMIS MSDS - Material Safety Data Sheets in accordance with Section 02 61 33 - Hazardous Materials.
 - .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Submit data for valves specified in this section.
- .3 Closeout Submittals:
 - .1 Submit maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 QUALITY ASSURANCE

- .1 Not used

1.5 DELIVERY STORAGE AND DISPOSAL

- .1 Not used.

1.6 MAINTENANCE

- .1 Extra Materials:
- .2 Furnish following spare parts:
 - .1 Valve seats: One (1) for every ten (10) valves each size. Minimum one (1).
 - .2 Discs: One (1) for every ten (10) valves, each size. Minimum one (1).
 - .3 Stem packing: One (1) for every ten (10) valves, each size. Minimum one (1).
 - .4 Valve handles: Two (2) of each size.
 - .5 Gaskets for flanges: One for every ten (10) flanged joints.

Part 2 Products

2.1 MATERIALS

- .1 Sustainable Requirements:
 - .1 Not used.
- .2 Valves:
 - .1 Except for specialty valves, to be single manufacturer.
 - .2 All products to have CRN registration numbers.
 - .3 All valve assemblies shall be certified to ANSI/NSF-61 for use with potable drinking water.
- .3 End Connections:
 - .1 Connection into adjacent piping/tubing:
 - .1 Steel pipe systems: Screwed ends to ANSI/ASME B1.20.1.
 - .2 Copper tube systems: Solder ends to ANSI/ASME B16.18.
- .4 Lockshield Keys:
 - .1 Where lockshield valves are specified, provide ten (10) keys of each size: malleable iron cadmium plated.
- .5 Gate Valves:
 - .1 Requirements common to gate valves, unless specified otherwise:
 - .1 Standard specification: MSS SP-80.
 - .2 Bonnet: union with hexagonal shoulders.
 - .3 Connections: screwed with hexagonal shoulders.
 - .4 Inspection and pressure testing: to MSS SP-80. Tests to be hydrostatic.
 - .5 Packing: non-asbestos.
 - .6 Handwheel: non-ferrous.

-
- .7 Handwheel Nut: bronze to ASTM B62.
 - .2 NPS 2 and under, non-rising stem, solid wedge disc, Class 125
 - .1 Body: with long disc guides, screwed bonnet with stem retaining nut.
 - .2 Operator: Handwheel.
 - .3 NPS 2 and under, non-rising stem, solid wedge disc, Class 150:
 - .1 Body: with long disc guides, screwed bonnet with stem retaining nut.
 - .2 Operator: Handwheel.
 - .4 NPS 2 and under, rising stem, split wedge disc, Class 125:
 - .1 Body: with long disc guides, screwed bonnet.
 - .2 Disc: split wedge, bronze to ASTM B283, loosely secured to stem.
 - .3 Operator: Handwheel.
 - .5 NPS 2 and under, rising stem, solid wedge disc, Class 125:
 - .1 Body: with long disc guides, screwed bonnet.
 - .2 Operator: Handwheel.
 - .6 NPS 2 and under, rising stem, solid wedge disc, Class 150:
 - .1 Body: with long disc guides, screwed union bonnet.
 - .2 Operator: Handwheel.
 - .6 Globe Valves:
 - .1 Requirements common to globe valves, unless specified otherwise:
 - .1 Standard specification: MSS SP-80.
 - .2 Bonnet: union with hexagonal shoulders.
 - .3 Connections: screwed with hexagonal shoulders.
 - .4 Pressure testing: to MSS SP-80. Tests to be hydrostatic.
 - .5 Stuffing box: threaded to bonnet with gland follower, packing nut, high-grade non-asbestos packing.
 - .6 Handwheel: non-ferrous.
 - .7 Handwheel Nut: bronze to ASTM B62.
 - .2 NPS 2 and under, composition disc, Class 125:
 - .1 Body and bonnet: screwed bonnet.
 - .2 Disc and seat: renewable rotating disc of composition to suit service conditions, re-grindable bronze seat, loosely secured to bronze stem to ASTM B505.
 - .3 Operator: Handwheel.
 - .3 NPS 2 and under, composition disc, Class 150:
 - .1 Body and bonnet: union bonnet.
 - .2 Disc and seat: renewable rotating PTFE disc in easily removable disc holder, re-grindable bronze seat, loosely secured to bronze stem to ASTM B505.
 - .3 Operator: Handwheel.
 - .4 NPS 2 and under, plug disc, Class 150, screwed ends:
 - .1 Body and bonnet: union bonnet.

-
- .2 Disc and seat ring: tapered plug type with disc stem ring of AISI S420 stainless steel to ASTM A276, loosely secured to stem.
 - .3 Operator: Handwheel.
 - .5 Angle valve, NPS 2 and under, composition disc, Class 150:
 - .1 Body and bonnet: union bonnet.
 - .2 Disc and seat: renewable rotating PTFE disc in slip-on easily removable disc holder having integral guides, re-grindable bronze seat, loosely secured to stem.
 - .3 Operator: Handwheel.
 - .7 Check Valves:
 - .1 Requirements common to check valves, unless specified otherwise:
 - .1 Standard specification: MSS SP-80.
 - .2 Connections: screwed with hexagonal shoulders.
 - .2 NPS 2 and under, swing type, bronze disc, Class 125:
 - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
 - .2 Disc and seat: renewable rotating disc, two-piece hinge disc construction; seat: re-grindable.
 - .3 NPS 2 and under, swing type, bronze disc:
 - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
 - .2 Disc and seat: renewable rotating disc, two-piece hinge disc construction; seat: re-grindable.
 - .4 NPS 2 and under, swing type, composition disc, Class 200:
 - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
 - .2 Disc: renewable rotating disc of number 6 with composition to suit service conditions, bronze two-piece hinge disc construction.
 - .5 NPS 2 and under, horizontal lift type, composition disc, Class 150:
 - .1 Body: with integral seat, union bonnet ring with hex shoulders, cap.
 - .2 Disc: renewable, with composition to suit service conditions, rotating disc in disc holder having guides top and bottom, of bronze to ASTM B62.
 - .6 NPS 2 and under, vertical lift type, bronze disc, Class 125:
 - .1 Disc: rotating disc having guides top and bottom, disc guides, retaining rings.
 - .8 Silent Check Valves:
 - .1 NPS 2 and under:
 - .1 Body: cast high tensile bronze to ASTM B62 with integral seat.
 - .2 Pressure rating: Class 125.
 - .3 Connections: screwed ends to ANSI B1.20.1 and with hex. shoulders.
 - .4 Disc and seat: renewable rotating disc.
 - .5 Stainless steel spring, heavy duty.

- .6 Seat: re-grindable.
- .9 Ball Valves:
 - .1 NPS 2 and under:
 - .1 Body and cap: cast high tensile bronze to ASTM B62.
 - .2 Pressure rating: Class 125.
 - .3 Connections: Screwed ends to ANSI B1.20.1 and with hexagonal shoulders.
 - .4 Stem: tamperproof ball drive.
 - .5 Stem packing nut: external to body.
 - .6 Ball and seat: replaceable stainless steel, solid ball and teflon seats.
 - .7 Stem seal: TFE with external packing nut.
 - .8 Operator: removable lever handle.

Part 3 Execution

3.1 INSTALLATION

- .1 Install rising stem valves in upright position with stem above horizontal.
- .2 Remove internal parts before soldering.
- .3 Install valves with unions at each piece of equipment arranged to allow servicing, maintenance, and equipment removal.

3.2 VERIFICATION

- .1 Not used.

END OF SECTION

Part 1 General

1.1 SUMMARY

- .1 Section Includes:
 - .1 Valves, gate and check.

1.2 REFERENCES

- .1 American National Standards Institute (ANSI)/American Society of Mechanical Engineers (ASME).
 - .1 ANSI/ASME B16.1-1998, Cast Iron Pipe Flanges and Flanged Fittings.
- .2 American Society for Testing and Materials International (ASTM).
 - .1 ASTM A49-01, Specification for Heat-Treated Carbon Steel Joint Bars.
 - .2 ASTM A126-95(2001), Specification for Gray Iron Castings for Valves, Flanges, and Pipe Fittings.
 - .3 ASTM B62-93, Specification for Composition Bronze or Ounce Metal Castings.
- .3 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS).
 - .1 MSS SP-70-2006, Cast Iron Gate Valves, Flanged and Threaded Ends.
 - .2 MSS SP-71-2005, Grey Iron Swing Check Valves, Flanged and Threaded Ends.
 - .3 MSS SP-85-2002, Cast Iron Globe and Angle Valves, Flanged and Threaded Ends.
- .4 American National Standards Institute (ANSI) / National Sanitation Foundation (NSF).
 - .1 ANSI/NSF-2014, Drinking Water System Components – Health Effects.

1.3 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data: submit WHMIS MSDS - Material Safety Data Sheets in accordance with Section 02 61 33 - Hazardous Materials.
 - .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Submit data for valves specified in this section.
- .3 Closeout Submittals:
 - .1 Submit maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

Part 2 Products

2.1 MATERIAL

- .1 Valves:
 - .1 Except for specialty valves, to be of single manufacturer.

-
- .2 All valve assemblies shall be certified to ANSI/NSF-61 for use with potable drinking water.
 - .2 Standard specifications:
 - .1 Gate valves: MSS SP-70.
 - .2 Check valves: MSS SP-71.
 - .3 Requirements common to valves, unless specified otherwise:
 - .1 Body, bonnet: cast iron to ASTM B209 Class B.
 - .2 Connections: flanged ends plain face with 2 mm raised face with serrated finish to ANSI B16.1.
 - .3 Inspection and pressure testing: to MSS SP-82.
 - .4 Bonnet gasket: non-asbestos.
 - .5 Stem: to have precision-machined Acme or 60 degrees V threads, top screwed for handwheel nut.
 - .6 Stuffing box: non-galling two-piece ball-jointed packing gland, gland bolts and nuts.
 - .7 Gland packing: non-asbestos.
 - .8 Handwheel: Die-cast aluminum alloy to ASTM B85 or malleable iron to ASTM A49. Nut of bronze to ASTM B62.
 - .9 Identification tag: with catalogue number, size, other pertinent data.
 - .4 All products to have CRN registration numbers.

2.2 GATE VALVES

- .1 NPS 2 1/2 - 8, non rising stem, inside screw, bronze trim, solid wedge disc:
 - .1 Body and multiple-bolted bonnet: with bosses in body and bonnet for taps and drains, full length disc guides designed to ensure correct re-assembly. Class 250.
 - .2 Disc: solid offset taper wedge, bronze to ASTM B62.
 - .3 Seat rings: renewable bronze to ASTM B62, screwed into body.
 - .4 Stem: bronze to ASTM B62.
 - .5 Disc: solid offset taper wedge, cast iron to ASTM A126 Class B, secured to wrought steel stem.
 - .6 Seat: Integral with body.
 - .7 Stem: wrought steel.
 - .8 Operator: Handwheel and chain manual gear – high installations
- .2 NPS 10 - 24, non rising stem, inside screw, bronze trim, solid wedge disc:
 - .1 Body and multiple-bolted bonnet: cast iron to ASTM A126 Class B for sizes up to NPS 14, Class C for sizes NPS 16 and over, with bosses in body and bonnet for taps and drains, full length disc guides designed to ensure correct re-assembly, body tie ribs between bonnet and end flanges.
 - .2 Pressure ratings: Class 250
 - .3 Disc: solid offset taper wedge, with bronze rings to ASTM B62 rolled into cast iron disc, secured to stem.
 - .4 Seat rings: renewable bronze to ASTM B62 screwed into body.
 - .5 Stem: bronze to ASTM B62.

- .6 Disc: solid offset taper wedge, cast iron secured to stem.
- .7 Seat: integral with body up to NPS 14, renewable nodular iron on other sizes.
- .8 Stem: wrought steel.
- .9 Operator: Handwheel and manual chain gear for high installation.

2.3 UNDERWRITERS APPROVED GATE VALVE

- .1 NPS 2 1/2 - 14, OS&Y:
 - .1 Approvals: UL and FM approved for fire service.
 - .2 UL and FM Label: on valve yoke.
 - .3 Body, Bonnet: cast iron to ASTM A126 Class B. Wall thicknesses to ANSI B16.1 and ULC 262 (B).
 - .4 Bonnet bushing, yoke sleeve: bronze, to FM requirements.
 - .5 Packing gland: bronze.
 - .6 Stem: manganese bronze. Diameter to ULC C-262 (B).
 - .7 Stuffing box dimensions, gland bolt diameter: to ULC C-262 (B).
 - .8 Bosses for bypass valve, drain: on NPS 4 and over.
 - .9 Disc: solid taper wedge. Up to NPS 3: bronze. NPS 4 and over: cast iron with bronze disc rings.
 - .10 Disc seat ring: self-aligning, Milwood undercut on NPS 3 - 12.
 - .11 Pressure rating:
 - .1 NPS 2-1/2 - 12: 1.7 Mpa CWP.
 - .2 NPS 14-1.2: 1.2 MPa CWP.
 - .12 Operator: Handwheel.
 - .13 Bypass: complete with union and NPS gate globe valve as Section 23 05 22 - Valves - Bronze, paragraph.

2.4 VALVE OPERATORS

- .1 Install valve operators as follows:
 - .1 Handwheel: on valves except as specified.
 - .2 Handwheel with chain operators: on valves installed more than 2400 mm above floor in mechanical equipment rooms.

2.5 CHECK VALVES

- .1 Swing check valves, Class 250:
 - .1 Body and bolted cover: with tapped and plugged opening on each side for hinge pin. Flanged ends: plain faced with smooth finish.
 - .1 Up to NPS 16: cast iron to ASTM A126 Class B.
 - .2 NPS 18 and over: cast iron to ASTM A126 Class C.
 - .2 Disc: rotating for extended life.
 - .1 Up to NPS 6: bronze to ASTM B 62.
 - .2 NPS 8 and over: bronze-faced cast iron.
 - .3 Seat rings: renewable bronze to ASTM B62 screwed into body.
 - .4 Hinge pin, bushings: renewable bronze to ASTM B62.
 - .5 Disc: A126 Class B, secured to stem, rotating for extended life.

-
- .6 Seat: cast iron, integral with body.
 - .7 Hinge pin: exelloy; bushings: malleable iron.
 - .8 Identification tag: fastened to cover.
 - .9 Hinge: galvanized malleable iron.
 - .2 Swing check valves, NPS 2 1/2 - 8 Class 250:
 - .1 Body and bolted cover: cast iron to ASTM A126 Class B with tapped and plugged opening on each side for hinge pin.
 - .2 Flanged ends: 2 mm raised face with serrated finish.
 - .3 Rating: 250 psi steam; 500 psi CWP.
 - .4 Disc: rotating for extended life.
 - .1 Up to NPS 3: bronze to ASTM B61.
 - .2 NPS 4 - 8: Iron faced with ASTM B61 bronze.
 - .5 Seat rings: renewable bronze to ASTM B61, screwed into body.
 - .6 Hinge pin, bushings: renewable, bronze to ASTM B61.
 - .7 Hinge: galvanized malleable iron.
 - .8 Identification tag: fastened to cover.

2.6 SILENT CHECK VALVES

- .1 Construction:
 - .1 Body: malleable or ductile iron with integral seat.
 - .2 Pressure rating: class 125, WP = 860 kPa.
 - .3 Connections: grooved ends.
 - .4 Disc: bronze or stainless steel renewable rotating disc.
 - .5 Seat: renewable, EPDM.
 - .6 Stainless steel spring, heavy duty.

Part 3 Execution

3.1 INSTALLATION

- .1 Install rising stem valves in upright position with stem above horizontal.

END OF SECTION

Part 1 General

1.1 SUMMARY

- .1 Section Includes:
 - .1 Seismic restraint systems for statically supported and vibration isolated equipment and systems; including equipment and systems, both vibration isolated and statically supported.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CSA G40.20/G40.21-04, General Requirements for Rolled or Welded Structural Quality Steel/Structural Quality Steel.
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .3 National Building Code of Canada (NBC) - 2010

1.3 DEFINITIONS

- .1 Priority Two (P2) Buildings: buildings in which life safety is of paramount concern. It is not necessary that P2 buildings remain operative during or after earthquake activity.
- .2 SRS: acronym for Seismic Restraint System.

1.4 SYSTEM DESCRIPTION

- .1 SRS fully integrated into, and compatible with:
 - .1 Noise and vibration controls specified elsewhere.
 - .2 Structural, mechanical, electrical design of project.
- .2 Systems, equipment not required to be operational during and after seismic event.
- .3 During seismic event, SRS to prevent systems and equipment from causing personal injury and from moving from normal position.
- .4 Designed by Professional Engineer, specializing in design of SRS and registered in Province of Ontario, Canada.

1.5 SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures .
- .2 Shop drawings: Submit drawings stamped and signed by Professional Engineer registered or licensed in Province of Ontario, Canada.
- .3 Submit design data including:
 - .1 Full details of design criteria.
 - .2 Working drawings (prepared to same standard of quality and size as documents forming these tender documents), materials lists, schematics, full specifications for components of each SRS to be provided.
 - .3 Design calculations (including restraint loads resulting from seismic forces in accordance with National Building Code, detailed work sheets, tables).

-
- .4 Separate shop drawings for each SRS and devices for each system, equipment.
 - .5 Identification of location of devices.
 - .6 Schedules of types of SRS equipment and devices.
 - .7 Details of fasteners and attachments to structure, anchorage loadings, attachment methods.
 - .8 Installation procedures and instructions.
 - .9 Design calculations including restraint loads to NBC and Supplement .
 - .10 Detailed work sheets, tables Simplified, Detailed work sheets, tables . Simplified, conservative assumptions may be acceptable .
 - .11 Detailed design of SRS including complete working drawings prepared to same standard of quality and size as Contract Documents , materials lists, design calculations, schematics, specifications.
 - .4 Submit additional copy of shop drawings and product data to Structural Engineer for review of connection points to building structure.
 - .5 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
 - .1 Departmental Representative will make available one (1) copy of systems supplier's installation instructions.
 - .6 Closeout Submittals:
 - .1 Provide maintenance data including monitoring requirements for incorporation into manuals specified in Section 01 78 00 - Closeout Submittals .

Part 2 Products

2.1 SRS MANUFACTURER

- .1 SRS from one manufacturer regularly engaged in SRS production.

2.2 GENERAL

- .1 SRS to provide gentle and steady cushioning action and avoid high impact loads.
- .2 SRS to restrain seismic forces in every direction.
- .3 Fasteners and attachment points to resist same load as seismic restraints.
- .4 SRS of Piping systems compatible with:
 - .1 Expansion, anchoring and guiding requirements.
 - .2 Equipment vibration isolation and equipment SRS.
- .5 SRS utilizing cast iron, threaded pipe, other brittle materials not permitted.
- .6 Attachments to RC structure:
 - .1 Use high strength mechanical expansion anchors.
 - .2 Drilled or power driven anchors not permitted.
- .7 Seismic control measures not to interfere with integrity of firestopping.

2.3 SRS FOR STATIC EQUIPMENT, SYSTEMS

- .1 Floor-mounted equipment, systems:
 - .1 Anchor equipment to equipment supports.
 - .2 Anchor equipment supports to structure.
 - .3 Use size of bolts scheduled in approved shop drawings.
- .2 Suspended equipment, systems:
 - .1 Use one or combination of following methods:
 - .1 Install tight to structure.
 - .2 Cross-brace in every direction.
 - .3 Brace back to structure.
 - .4 Slack cable restraint system.
 - .2 SCS to prevent sway in horizontal plane, "rocking" in vertical plane, sliding and buckling in axial direction.
 - .3 Hanger rods to withstand compressive loading and buckling.

2.4 SRS FOR VIBRATION ISOLATED EQUIPMENT

- .1 Floor mounted equipment, systems:
 - .1 Use one or combination of following methods:
 - .1 Vibration isolators with built-in snubbers.
 - .2 Vibration isolators and separate snubbers.
 - .3 Built-up snubber system approved by Departmental Representative, consisting of structural elements and elastomeric layer.
 - .2 SRS to resist complete isolator unloading.
 - .3 SRS not to jeopardize noise and vibration isolation systems. Provide 4-8 mm clearance between seismic restraint snubbers and equipment during normal operation of equipment and systems.
 - .4 Cushioning action: gentle and steady by utilizing elastomeric material or other means in order to avoid high impact loads.
- .2 Suspended equipment, systems:
 - .1 Use one or combination of following methods:
 - .1 Slack cable restraint system.
 - .2 Brace back to structure via vibration isolators and snubbers.

2.5 SLACK CABLE RESTRAINT SYSTEM (SCS)

- .1 Use elastomer materials or similar to avoid high impact loads and provide gentle and steady cushioning action.
- .2 SCS to prevent sway in horizontal plane, "rocking" in vertical plane, sliding and buckling in axial direction.
- .3 Hanger rods to withstand compressive loading and buckling.

2.6 SERVICE UTILITIES ENTRANCE INTO BUILDING

- .1 Provide flexibility to prevent breakage in the event of earthquake activity .

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Attachment points and fasteners:
 - .1 To withstand same maximum load that seismic restraint is to resist and in every direction.
- .2 Slack Cable Systems (SCS):
 - .1 Connect to suspended equipment so that axial projection of wire passes through centre of gravity of equipment.
 - .2 Use appropriate grommets, shackles, other hardware to ensure alignment of restraints and to avoid bending of cables at connection points.
 - .3 Piping systems: provide transverse SCS at 10 m spacing maximum, longitudinal SCS at 20 m maximum or as limited by anchor/slack cable performance.
 - .4 Small pipes may be rigidly secured to larger pipes for restraint purposes, but not reverse.
 - .5 Orient restraint wires on ceiling hung equipment at approximately 90 degrees to each other (in plan), tie back to structure at maximum of 45 degrees to structure.
 - .6 Adjust restraint cables so that they are not visibly slack but permit vibration isolation system to function normally.
 - .7 Tighten cable to reduce slack to 40 mm under thumb pressure. Cable not to support weight during normal operation.
- .3 Install SRS at least 25 mm from equipment, systems, services.
- .4 Miscellaneous equipment not vibration-isolated:
 - .1 Bolt through house-keeping pad to structure.
- .5 Co-ordinate connections with other disciplines.
- .6 Manufacturer's Field Services:
 - .1 Arrange with manufacturer's representative to review work of this Section and submit written reports to verify compliance with Contract Documents.
 - .2 Manufacturer's Field Services: consisting of product use recommendations and periodic site visits to review installation, scheduled as follows:
 - .1 After delivery and storage of Products.
 - .2 After preparatory work is complete but before installation commences.
 - .3 Twice during the installation, at 25 % and 60 % completion stages.
 - .4 Upon completion of installation.
 - .3 Submit manufacturer's reports to Departmental Representative within 3 days of manufacturer representative's review.
- .7 Inspection and Certification:
 - .1 SRS: inspected and certified by Seismic Engineer or Manufacturer upon completion of installation.

- .2 Provide written report to Departmental Representative with certificate of compliance.
- .8 Commissioning Documentation:
 - .1 Upon completion and acceptance of certification, hand over to Departmental Representative complete set of construction documents, revised to show "as-built" conditions.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

Part 1 General

1.1 SUMMARY

- .1 Section Includes:
 - .1 Materials and requirements for the identification of piping systems, ductwork, valves, and controllers, including the installation and location of identification systems.

1.2 REFERENCES

- .1 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-24.3-92 Identification of Piping Systems.

1.3 SUBMITTALS

- .1 Product Data:
- .2 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.

Part 2 Products

2.1 MANUFACTURER'S EQUIPMENT NAMEPLATES

- .1 Metal or plastic laminate nameplate mechanically fastened to each piece of equipment by manufacturer.
- .2 Lettering and numbers raised or recessed.
- .3 Information to include, as appropriate:
 - .1 Equipment: manufacturer's name, model, size, serial number, capacity.
 - .2 Motor: voltage, Hz, phase, power factor, duty, frame size.

2.2 SYSTEM NAMEPLATES

- .1 Colours:
 - .1 Hazardous: red letters, white background.
 - .2 Elsewhere: black letters, white background (except where required otherwise by applicable codes).
- .2 Construction:
 - .1 3 mm thick laminated plastic or white anodized aluminum, matte finish, with square corners, letters accurately aligned and machine engraved into core.
- .3 Sizes:

- .1 Conform to following table:

Size # mm	Sizes (mm)	No. of Lines	Height of Letters (mm)
1	10 x 50	1	3
2	13 x 75	1	5
3	13 x 75	2	3
4	20 x 100	1	8

Size # mm	Sizes (mm)	No. of Lines	Height of Letters (mm)
5	20 x 100	2	5
6	20 x 200	1	8
7	25 x 125	1	12
8	25 x 125	2	8
9	35 x 200	1	20

.2 Use maximum of 25 letters/numbers per line.

.4 Locations:

.1 Terminal cabinets, control panels: use size # 5 .

.2 Equipment in Mechanical Rooms: use size # 9 .

.5 Identification for PWGSC Preventive Maintenance Support System (PMSS):

.1 Use arrangement of Main identifier, Source identifier, Destination identifier.

.2 Equipment in Mechanical Room:

.1 Main identifier: size #9.

.2 Source and Destination identifiers: size #6.

.3 Terminal cabinets, control panels: size #5.

.3 Equipment elsewhere: sizes as appropriate.

2.3 EXISTING IDENTIFICATION SYSTEMS

.1 Apply existing identification system to new work.

.2 Where existing identification system does not cover for new work, use identification system specified this section.

.3 Before starting work, obtain written approval of identification system from Departmental Representative.

IDENTIFICATION OF PIPING SYSTEMS

.4 Identify contents by background colour marking, pictogram (as necessary), legend; direction of flow by arrows. To CAN/CGSB 24.3 except where specified otherwise.

.5 Pictograms:

.1 Where required: Workplace Hazardous Materials Information System (WHMIS) regulations.

.6 Legend:

.1 Block capitals to sizes and colours listed in CAN/CGSB 24.3.

.7 Arrows showing direction of flow:

.1 Outside diameter of pipe or insulation less than 75 mm: 100 mm long x 50 mm high.

.2 Outside diameter of pipe or insulation 75 mm and greater: 150 mm long x 50 mm high.

.3 Use double-headed arrows where flow is reversible.

.8 Extent of background colour marking:

.1 To full circumference of pipe or insulation.

- .2 Length to accommodate pictogram, full length of legend and arrows.
- .9 Materials for background colour marking, legend, arrows:
 - .1 Pipes and tubing 20 mm and smaller: waterproof and heat-resistant pressure sensitive plastic marker tags.
 - .2 Other pipes: pressure sensitive plastic-coated cloth vinyl with protective overcoating, waterproof contact adhesive undercoating, suitable for ambient of 100% RH and continuous operating temperature of 150 degrees C and intermittent temperature of 200 degrees C.

.10 Colours and Legends:

- .1 Where not listed, obtain direction from the Departmental Representative.
- .2 Colours for legends, arrows: to following table:

Background colour:	Legend, arrows:
Yellow	BLACK
Green	WHITE
Red	WHITE

- .3 Background colour marking and legends for piping systems:

Contents	Background colour marking	Legend
** Add design temperature		
++ Add design temperature and pressure		
Domestic cold water supply	Green	DOM. CWS
Sanitary	Green	SAN
Plumbing vent	Green	SAN. VENT
Fire protection water	Red	FIRE PROT. WTR

2.4 IDENTIFICATION DUCTWORK SYSTEMS

- .1 50 mm high stencilled letters and directional arrows 150 mm long x 50 mm high.
- .2 Colours: back, or co-ordinated with base colour to ensure strong contrast.

2.5 VALVES, CONTROLLERS

- .1 Brass tags with 12 mm stamped identification data filled with black paint.
- .2 Include flow diagrams for each system, of approved size, showing charts and schedules with identification of each tagged item, valve type, service, function, normal position, location of tagged item.

2.6 CONTROLS COMPONENTS IDENTIFICATION

- .1 Identify all systems, equipment, components, controls, and sensors with system nameplates specified in this section.
- .2 Inscriptions to include function and (where appropriate) fail-safe position.

2.7 LANGUAGE

- .1 Identification in English and French.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Perform work in accordance with CAN/CGSB-24.3 except as specified otherwise.
- .2 Provide ULC and or CSA registration plates as required by respective agency.
- .3 Identify systems, equipment to conform to PWGSC Preventive Maintenance Support System (PMSS).

3.3 NAMEPLATES

- .1 Locations:
 - .1 In conspicuous location to facilitate easy reading and identification from operating floor.
- .2 Standoffs:
 - .1 Provide for nameplates on hot and/or insulated surfaces.
- .3 Protection:
 - .1 Do not paint, insulate or cover.

3.4 LOCATION OF IDENTIFICATION ON PIPING AND DUCTWORK SYSTEMS

- .1 On long straight runs in open areas in boiler rooms, equipment rooms, galleries, tunnels: at not more than 17 m intervals and more frequently if required to ensure that at least one is visible from any one viewpoint in operating areas and walking aisles.
- .2 Adjacent to each change in direction.
- .3 At least once in each small room through which piping or ductwork passes.
- .4 On both sides of visual obstruction or where run is difficult to follow.
- .5 On both sides of separations such as walls, floors, partitions.
- .6 Where system is installed in pipe chases, ceiling spaces, galleries, confined spaces, at entry and exit points, and at access openings.
- .7 At beginning and end points of each run and at each piece of equipment in run.
- .8 At point immediately upstream of major manually operated or automatically controlled valves, and dampers. Where this is not possible, place identification as close as possible, preferably on upstream side.
- .9 Identification easily and accurately readable from usual operating areas and from access points.
 - .1 Position of identification approximately at right angles to most convenient line of sight, considering operating positions, lighting conditions, risk of physical damage or injury and reduced visibility over time due to dust and dirt.

3.5 VALVES, CONTROLLERS

- .1 Valves and operating controllers, except at plumbing fixtures, radiation, or where in plain sight of equipment they serve: Secure tags with non-ferrous chains or closed "S" hooks.
- .2 Install one copy of flow diagrams and valve schedules mounted in a frame behind non-glare glass where directed by the Departmental Representative. Provide one copy (reduced in size if required) in each operating and maintenance manual.
- .3 Number valves in each system consecutively.

3.6 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

Part 1 General

1.1 SUMMARY

- .1 TAB is used throughout this Section to describe the process, methods and requirements of testing, adjusting and balancing for hydronic systems.
- .2 TAB means to test, adjust and balance to perform in accordance with requirements of Contract Documents and to do other work as specified in this section.

1.2 QUALIFICATIONS OF TAB PERSONNEL

- .1 Submit names of personnel to perform TAB to Departmental Representative within ninety (90) days of award of contract.
- .2 Provide documentation confirming qualifications, successful experience.
- .3 TAB: performed in accordance with the requirements of standard under which TAB Firm's qualifications are approved:
 - .1 Associated Air Balance Council, (AABC) National Standards for Total System Balance, MN-1-2002.
 - .2 National Environmental Balancing Bureau (NEBB) TABES, Procedural Standards for Testing, Adjusting, Balancing of Environmental Systems-1998.
- .4 Recommendations and suggested practices contained in the TAB Standard: mandatory.
- .5 Use TAB Standard provisions, including checklists, and report forms to satisfy Contract requirements.
- .6 Use TAB Standard for TAB, including qualifications for TAB Firm and Specialist and calibration of TAB instruments.
- .7 Where instrument manufacturer calibration recommendations are more stringent than those listed in TAB Standard, use manufacturer's recommendations.
- .8 TAB Standard quality assurance provisions such as performance guarantees form part of this contract.
 - .1 For systems or system components not covered in TAB Standard, use TAB procedures developed by TAB Specialist.
 - .2 Where new procedures, and requirements, are applicable to Contract requirements have been published or adopted by body responsible for TAB Standard used (AABC, NEBB, or TABB), requirements and recommendations contained in these procedures and requirements are mandatory.

1.3 PURPOSE OF TAB

- .1 Test to verify proper and safe operation, determine actual point of performance, evaluate qualitative and quantitative performance of equipment, systems and controls at design, average and low loads using actual or simulated loads
- .2 Adjust and regulate equipment and systems to meet specified performance requirements and to achieve specified interaction with other related systems under normal and emergency loads and operating conditions.
- .3 Balance systems and equipment to regulate flow rates to match load requirements over full operating ranges.

1.4 EXCEPTIONS

- .1 TAB of systems and equipment regulated by codes, standards to satisfaction of authority having jurisdiction.

1.5 CO-ORDINATION

- .1 Schedule time required for TAB (including repairs, re-testing) into project construction and completion schedule to ensure completion before acceptance of project.
- .2 Do TAB of each system independently and subsequently, where interlocked with other systems, in unison with those systems.

1.6 PRE-TAB REVIEW

- .1 Review contract documents before project construction is started and confirm in writing to Departmental Representative the adequacy of provisions for TAB and other aspects of design and installation pertinent to success of TAB.
- .2 Review specified standards and report to Departmental Representative in writing proposed procedures that vary from standard.
- .3 During construction, co-ordinate location and installation of TAB devices, equipment, accessories, measurement ports and fittings.

1.7 START-UP

- .1 Follow start-up procedures as recommended by equipment manufacturer unless specified otherwise.

1.8 FOLLOW SPECIAL START-UP PROCEDURES

- .1 Notify Departmental Representative seven (7) days prior to start of TAB.
- .2 Start TAB when building is essentially completed, including:
 - .3 Installation of ceilings, doors, windows, other construction affecting TAB.
 - .4 Application of weatherstripping, sealing, and caulking.
 - .5 Pressure, leakage, or other tests specified elsewhere in Division 23.
 - .6 Provisions for TAB installed and operational.
 - .7 Start-up, verification for proper, normal and safe operation of mechanical and associated electrical and control systems affecting TAB including but not limited to:
 - .1 Proper thermal overload protection in place for electrical equipment.
 - .2 Liquid systems:
 - .1 Flushed, filled, vented.
 - .2 Correct pump rotation.
 - .3 Strainers in place, baskets clean.
 - .4 Isolating and balancing valves installed, open.
 - .5 Calibrated balancing valves installed, at factory settings.
 - .6 Chemical treatment systems complete, operational.

1.9 APPLICATION TOLERANCES

- .1 Do TAB to following tolerances of design values:

- .1 Hydronic systems: plus or minus 10 %.

1.10 ACCURACY TOLERANCES

- .1 Measured values accurate to within plus or minus 2 % of actual values.

1.11 INSTRUMENTS

- .1 Prior to TAB, submit to Departmental Representative a list of instruments used together with serial numbers.
- .2 Calibrate in accordance with requirements of most stringent of referenced standard for either applicable system or HVAC system.
- .3 Calibrate within three (3) months of TAB. Provide certificate of calibration to Departmental Representative.

1.12 SUBMITTALS

- .1 Submit, prior to commencement of TAB:
- .2 Proposed methodology and procedures for performing TAB if different from referenced standard.
- .3 .

1.13 PRELIMINARY TAB REPORT

- .1 Submit for checking and approval of Departmental Representative, prior to submission of formal TAB report, sample of rough TAB sheets. Include:
 - .1 Details of instruments used.
 - .2 Details of TAB procedures employed.
 - .3 Calculations procedures.
 - .4 Summaries.

1.14 TAB REPORT

- .1 Format in accordance with referenced standard.
- .2 TAB report to show results in SI units and to include:
 - .1 Project record drawings.
 - .2 System schematics.
- .3 Submit 6 copies of TAB Report to Departmental Representative for verification and approval, in English French both official languages in D-ring binders, complete with index tabs.

1.15 VERIFICATION

- .1 Reported results subject to verification by Departmental Representative.
- .2 Provide personnel and instrumentation to verify up to 30 % of reported results.
- .3 Number and location of verified results as directed by Departmental Representative.
- .4 Pay costs to repeat TAB as required to satisfaction of Departmental Representative.

1.16 SETTINGS

- .1 After TAB is completed to satisfaction of Departmental Representative, replace drive guards, close access doors, lock devices in set positions, ensure sensors are at required settings.
- .2 Permanently mark settings to allow restoration at any time during life of facility. Do not eradicate or cover markings.

1.17 COMPLETION OF TAB

- .1 TAB considered complete when final TAB Report received and approved by Departmental Representative.

Part 2 Products

2.1 NOT USED

- .1 Not used.

Part 3 Execution

3.1 NOT USED

- .1 Not used.

END OF SECTION

Part 1 General

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.

1.2 REFERENCES

- .1 American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE)
 - .1 ANSI/ASHRAE/IESNA 90.1-01, SI; Energy Standard for Buildings Except Low-Rise Residential Buildings.
- .2 American Society for Testing and Materials International, (ASTM)
 - .1 ASTM C612-00a, Specification for Mineral Fiber Block and Board Thermal Insulation.
- .3 Canadian General Standards Board (CGSB)
 - .1 CGSB 51-GP-52 Ma-89, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.
- .4 Thermal Insulation Association of Canada (TIAC): National Insulation Standards (R1999).
- .5 Underwriters Laboratories of Canada (ULC)
 - .1 CAN/ULC-S102-M88(R2000), Surface Burning Characteristics of Building Materials and Assemblies.
 - .2 CAN/ULC-S701-01, Thermal Insulation Polyotrene, Boards and Pipe Covering.

1.3 DEFINITIONS

- .1 For purposes of this section:
 - .1 "CONCEALED" - insulated mechanical services and equipment in suspended ceilings and non-accessible chases and furred-in spaces.
 - .2 "EXPOSED" - will mean "not concealed" as defined herein.
 - .3 Insulation systems - insulation material, fasteners, jackets, and other accessories.
- .2 TIAC Codes:
 - .1 CRD: Code Round Ductwork,
 - .2 CRF: Code Rectangular Finish.

1.4 SHOP DRAWINGS

- .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit for approval manufacturer's catalogue literature related to installation, fabrication for duct jointing recommendations.

1.5 SAMPLES

- .1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.

- .2 Submit for approval: complete assembly of each type of insulation system, insulation, coating, and adhesive proposed. Mount sample on 12 mm plywood board. Affix typewritten label beneath sample indicating service.

1.6 MANUFACTURERS' INSTRUCTIONS

- .1 Submit manufacturer's installation instructions in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Installation instructions to include procedures used, and installation standards achieved.

1.7 QUALIFICATIONS

- .1 Installer: specialist in performing work of this section, and have a successful experience in this size and type of project, qualified to standards member of TIAC.

Part 2 Products

2.1 FIRE AND SMOKE RATING

- .1 In accordance with CAN/ULC-S102:
 - .1 Maximum flame spread rating: 25.
 - .2 Maximum smoke developed rating: 50.

2.2 INSULATION

- .1 Mineral fibre: as specified includes glass fibre, rock wool, slag wool.
- .2 Thermal conductivity ("k" factor) not to exceed specified values at 24°C mean temperature when tested in accordance with ASTM C335.
- .3 TIAC Code C-1: Rigid mineral fibre board to ASTM C612, with without factory applied vapour retarder jacket to CGSB 51-GP-52Ma (as scheduled in PART 3 of this Section).
- .4 TIAC Code C-2: Mineral fibre blanket to ASTM C553 faced with without factory applied vapour retarder jacket to CGSB 51-GP-52Ma (as scheduled in PART 3 of this section).
 - .1 Mineral fibre: to ASTM C553.
 - .2 Jacket: to CGSB 51-GP-52Ma.
 - .3 Maximum "k" factor: to ASTM C553.

2.3 JACKETS

- .1 Aluminum:
 - .1 To ASTM B209 with and without moisture barrier as scheduled in PART 3 of this section.
 - .2 Thickness: 0.50 mm sheet.
 - .3 Finish: Smooth.
 - .4 Jacket banding and mechanical seals: 19 mm wide, 0.5 mm thick stainless steel.
 - .1 Stainless steel:
 - .5 Type: 304.
 - .6 Thickness: 0.25 mm sheet.
 - .7 Finish: Smooth.

- .8 Jacket banding and mechanical seals: 12 mm wide, 0.5 mm thick stainless steel.

2.4 ACCESSORIES

- .1 Vapour retarder lap adhesive:
 - .1 Water based, fire retardant type, compatible with insulation.
- .2 Outdoor Vapour Retarder Mastic:
 - .1 Vinyl emulsion type acrylic, compatible with insulation.
 - .2 Reinforcing fabric: Fibrous glass, untreated 305 g/m².
- .3 Tape: self-adhesive, aluminum, plain 75 mm wide minimum.
- .4 Contact adhesive: quick-setting
- .5 Canvas adhesive: washable.
- .6 Tie wire: 1.5 mm stainless steel.
- .7 Banding: 12 mm wide, 0.5 mm thick stainless steel.
- .8 Facing: 25 mm galvanized steel hexagonal wire mesh stitched on one face of insulation one face of insulation with expanded metal lath on other face.
- .9 Fasteners: 2 4 mm diameter pins with 35 mm diameter clips, length to suit thickness of insulation.

Part 3 Execution

3.1 PRE-INSTALLATION REQUIREMENTS

- .1 Pressure testing of ductwork systems complete, witnessed and certified.
- .2 Surfaces clean, dry, free from foreign material.

3.2 INSTALLATION

- .1 Install in accordance with TIAC National Standards.
- .2 Apply materials in accordance with manufacturers instructions and as indicated.
- .3 Use two layers with staggered joints when required nominal thickness exceeds 75 mm.
- .4 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes.
 - .1 Hangers, supports to be outside vapour retarder jacket.
- .5 Fasteners: At 300 mm o/c in horizontal and vertical directions, minimum two rows each side.

3.3 DUCTWORK INSULATION SCHEDULE

.1 Insulation types and thicknesses: Conform to following table:

	TIAC Code	Vapour Retarder	Thickness (mm)
Rectangular cold and dual temperature supply air ducts	C-1	yes	50

END OF SECTION

Part 1 General

1.1 SUMMARY

- .1 Section Includes:
 - .1 Procedures and cleaning solutions for cleaning mechanical piping systems.

1.2 REFERENCES

- .1 American Society for Testing and Materials International (ASTM)
 - .1 ASTM E202-12, Standard Test Methods for Analysis of Ethylene Glycols and Propylene Glycols.
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).

1.3 SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
- .2 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.

Part 2 Products

2.1 CLEANING SOLUTIONS

- .1 Tri-sodium phosphate: 0.40 kg per 100 L water in system.
- .2 Sodium carbonate: 0.40 kg per 100 L water in system.
- .3 Low-foaming detergent: 0.01 kg per 100 L water in system.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 CLEANING OF POTABLE WATER SYSTEMS

- .1 Timing: Systems operational, hydrostatically tested, and with safety devices functional, before cleaning is carried out.
- .2 Cleaning Agency:
 - .1 Retain qualified water treatment specialist to perform system cleaning.

-
- .3 Install instrumentation such as flow meters, orifice plates, pitot tubes, flow metering valves only after cleaning is certified as complete by water treatment specialist.
 - .4 Cleaning procedures:
 - .1 Provide detailed report outlining proposed cleaning procedures at least 4 weeks prior to proposed starting date. Report to include:
 - .1 Cleaning procedures, flow rates, elapsed time.
 - .2 Chemicals and concentrations used.
 - .3 Inhibitors and concentrations.
 - .4 Specific requirements for completion of work.
 - .5 Special precautions for protecting piping system materials and components.
 - .6 Complete analysis of water used to ensure water will not damage systems or equipment.
 - .5 Conditions at time of cleaning of systems:
 - .1 Systems: free from construction debris, dirt and other foreign material.
 - .2 Control valves: operational, fully open to ensure that terminal units can be cleaned properly.
 - .3 Strainers: clean prior to initial fill.
 - .4 Install temporary filters on pumps not equipped with permanent filters.
 - .5 Install pressure gauges on strainers to detect plugging.
 - .6 Report on Completion of Cleaning:
 - .1 When cleaning is completed, submit report, complete with certificate of compliance with specifications of cleaning component supplier.
 - .7 Hydronic Systems:
 - .1 Not used.

3.3 START-UP OF HYDRONIC SYSTEMS

- .1 Not used.

3.4 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

Part 1 General

1.1 SUMMARY

.1 Section Includes:

- .1 Materials and installation procedures for electric heating controls.

1.2 REFERENCES

.1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)

- .1 Material Safety Data Sheets (MSDS).

1.3 SUBMITTALS

.1 Product Data:

- .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.

Part 2 Products

2.1 THERMOSTAT (LINE VOLTAGE, HEATING)

.1 Line voltage wall mounted integral electric heating thermostat with:

- .1 Full load rating: 22 A at 120 V.
- .2 Temperature setting range: 5 degrees C to 30 degrees C.
- .3 Double pole.
- .4 Thermometer range: 5 degrees C to 30 degrees C.
- .5 Scale markings: Off-5-10-15-20-25 degrees C.
- .6 Set point override with timer.

2.2 THERMOSTAT GUARDS

.1 Thermostat guards: Cast metal c/w slots for air circulation to thermostat.

2.3 SAIL SWITCH

.1 Sail switch, mercury bulb type with stainless steel sail, adjustable range set for 300 fpm air velocity. Full load: A at 120 V. Maximum ambient temperature: 82 degrees C.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install control devices.
- .2 On outside wall, mount thermostats on bracket or insulated pad 25 mm from exterior wall.
- .3 Install remote sensing device and capillary tube in metallic conduit. Conduit enclosing capillary tube must not touch heater or heating cable.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

Part 1 General

1.1 SUMMARY

- .1 Section Includes:
 - .1 Materials and installation of low-pressure metallic ductwork, joints and accessories.

1.2 REFERENCES

- .1 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE).
- .2 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM A480/A480M-13c, Standard Specification for General Requirements for Flat-Rolled Stainless and Heat-Resisting Steel Plate, Sheet and Strip.
 - .2 ASTM A635/A635M-14, Standard Specification for Steel, Sheet and Strip, Heavy-Thickness Coils, Carbon, Hot Rolled.
 - .3 ASTM A653/A653M-13, Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc-Iron Alloy Coated (Galvannealed) by the Hot-Dip Process.
- .3 Department of Justice Canada (Jus).
 - .1 Canadian Environmental Protection Act (CEPA), 1999, c. 33 .
- .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
- .5 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA).
 - .1 SMACNA HVAC Duct Construction Standards - Metal and Flexible, 2nd Edition 1995 and Addendum No. 1, 1997.
 - .2 SMACNA HVAC Air Duct Leakage Test Manual, 1985, 1st Edition.
 - .3 IAQ Guideline for Occupied Buildings Under Construction 1995, 1st Edition.

1.3 SUBMITTALS

- .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data: submit WHMIS MSDS - Material Safety Data Sheets in accordance with Section 02 61 33 - Hazardous Materials for the following:
 - .1 Sealants.
 - .2 Tape.
 - .3 Proprietary Joints.

Part 2 Products

2.1 SEAL CLASSIFICATION

- .1 Classification as follows:

Maximum Pressure Pa	SMACNA Seal Class
500	C
250	C
125	C
125	Unsealed

- .2 Seal classification:

- .1 Class A: longitudinal seams, transverse joints, duct wall penetrations and connections made airtight with sealant and tape.

2.2 SEALANT

- .1 Sealant: oil resistant, polymer-type flame resistant duct sealant. Temperature range of minus 30 degrees Celsius to plus 93 degrees Celsius.

2.3 TAPE

- .1 Tape: polyvinyl treated, open weave fiberglass tape, 50 mm wide.

2.4 DUCT LEAKAGE

- .1 In accordance with SMACNA HVAC Air Duct Leakage Test Manual.

2.5 FITTINGS

- .1 Fabrication: to SMACNA.

- .2 Radiused elbows.

- .1 Rectangular: standard radius short radius with single thickness turning vanes
Centreline radius: 1.5 times width of duct.
- .2 Round: smooth radius five piece. Centreline radius: 1.5 times diameter.

- .3 Mitred elbows, rectangular:

- .1 To 400 mm: with single double thickness turning vanes.
- .2 Over 400 mm: with double thickness turning vanes.

- .4 Branches:

- .1 Rectangular main and branch: with radius on branch 1.5 times width of duct 45 degrees entry on branch.
- .2 Round main and branch: enter main duct at 45 degrees with conical connection.
- .3 Provide volume control damper in branch duct near connection to main duct.
- .4 Main duct branches: with splitter damper.

- .5 Transitions:

- .1 Diverging: 20 degrees maximum included angle.
- .2 Converging: 30 degrees maximum included angle.

- .6 Offsets:

- .1 Full short radiused elbows as indicated.
- .7 Obstruction deflectors: maintain full cross-sectional area.
- .1 Maximum included angles: as for transitions.

2.6 FIRE STOPPING

- .1 Retaining angles around duct, on both sides of fire separation.
- .2 Fire stopping material and installation must not distort duct.

2.7 GALVANIZED STEEL

- .1 Lock forming quality: to ASTM A653/A653M, Z90 zinc coating.
- .2 Thickness, fabrication and reinforcement: to ASHRAE SMACNA.
- .3 Joints: to ASHRAE SMACNA proprietary manufactured duct joint. Proprietary manufactured flanged duct joint to be considered to be a class A seal.

2.8 HANGERS AND SUPPORTS

- .1 Hangers and Supports:
 - .1 Hanger configuration: to ASHRAE and SMACNA.
 - .2 Hangers: black galvanized steel angle with galvanized steel rods to ASHRAE and SMACNA following table :

Duct Size (mm)	Angle Size (mm)	Rod Size (mm)
up to 750	25 x 25 x 3	6
751 to 1050	40 x 40 x 3	6
1051 to 1500	40 x 40 x 3	10
1501 to 2100	50 x 50 x 3	10
2101 to 2400	50 x 50 x 5	10
2401 and over	50 x 50 x 6	10

- .3 Upper hanger attachments:
 - .1 For concrete: manufactured concrete inserts.
 - .2 For steel joist: manufactured joist clamp.
 - .3 For steel beams: manufactured beam clamps:

Part 3 Execution

3.1 GENERAL

- .1 Perform work in accordance with NFPA 90A, NFPA 90B, ASHRAE, SMACNA.
- .2 Do not break continuity of insulation vapour barrier with hangers or rods.
- .3 Support risers in accordance with ASHRAE SMACNA.
- .4 Install breakaway joints in ductwork on sides of fire separation.
- .5 Install proprietary manufactured flanged duct joints in accordance with manufacturer's instructions.
- .6 Manufacture duct in lengths and diameter to accommodate installation of acoustic duct lining .

3.2 HANGERS

- .1 Strap hangers: install in accordance with SMACNA.
- .2 Angle hangers: complete with locking nuts and washers.
- .3 Hanger spacing: in accordance with ASHRAE, SMACNA as follows:

Duct Size	Spacing
(mm)	(mm)
to 1500	3000
1501 and over	2500

3.3 SEALING AND TAPING

- .1 Apply sealant to outside of joint to manufacturer's recommendations.
- .2 Bed tape in sealant and recoat with minimum of one (1) coat of sealant to manufacturers recommendations.

3.4 LEAKAGE TESTS

- .1 In accordance with SMACNA HVAC Duct Leakage Test Manual.

END OF SECTION

Part 1 General

1.1 SUMMARY

.1 Section Includes:

- .1 Fans, motors, accessories, and hardware for commercial use.

1.2 REFERENCES

.1 Air Conditioning and Mechanical Contractors (AMCA)

- .1 AMCA Publication 99-2003, Standards Handbook.
- .2 AMCA 300-08, Reverberant Room Method for Sound Testing of Fans.
- .3 AMCA 301-14, Methods for Calculating Fan Sound Ratings from Laboratory Test Data.

.2 American National Standards Institute (ANSI)/American Society of Mechanical Engineers (ASME)

- .1 ANSI/AMCA 210-07, Laboratory Methods of Testing Fans for Aerodynamic Performance Rating.

.3 Health Canada/Workplace Hazardous Materials Information System (WHMIS)

- .1 Material Safety Data Sheets (MSDS).

1.3 SYSTEM DESCRIPTION

.1 Performance Requirements:

- .1 Catalogued or published ratings for manufactured items: obtained from tests carried out by manufacturer or those ordered by manufacturer from independent testing agency signifying adherence to codes and standards in force.
- .2 Capacity: flow rate, total static pressure, bhp, efficiency, revolutions per minute, power, model, size, sound power data and as indicated on schedule.
- .3 Fans: statically and dynamically balanced, constructed in conformity with AMCA 99.
- .4 Sound ratings: comply with AMCA 301, tested to AMCA 300. Supply unit with AMCA certified sound rating seal.
- .5 Performance ratings: based on tests performed in accordance with ANSI/AMCA 210. Supply unit with AMCA certified rating seal, except for propeller fans smaller than 300 mm diameter.

1.4 SUBMITTALS

.1 Product Data:

- .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Submit two (2) copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures .

.2 Shop Drawings:

-
- .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Shop Drawings: Submit drawings stamped and signed by a professional engineer registered or licensed in Province of Ontario, Canada.
 - .3 Provide :
 - .1 Fan performance curves showing point of operation, kW, and efficiency.
 - .2 Sound rating data at point of operation.
 - .4 Indicate:
 - .1 Motors, sheaves, bearings, shaft details.
 - .2 Minimum performance achievable with variable speed controllers and variable inlet vanes as appropriate.
 - .5 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: Submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
 - .1 Departmental Representative will make available one (1) copy of systems supplier's installation instructions.
 - .6 Closeout Submittals:
 - .1 Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.5 QUALITY ASSURANCE

- .1 Not used.

1.6 MAINTENANCE

- .1 Extra Materials:
 - .1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
 - .1 Spare parts to include:
 - .1 Matched sets of belts.
 - .2 Furnish list of individual manufacturer's recommended spare parts for equipment, include:
 - .1 Bearings and seals.
 - .2 Addresses of suppliers.
 - .3 List of specialized tools necessary for adjusting, repairing or replacing.

Part 2 Products

2.1 CABINET FANS - GENERAL PURPOSE

- .1 Fan characteristics and construction: As centrifugal fans.

-
- .2 Cabinet hung single or multiple wheel with DWDI centrifugal fans in factory fabricated casing complete with vibration isolators and seismic control measures, motor, V-belt drive inside casing.
 - .3 Fabricate casing of zinc-coated or phosphate-treated steel, reinforced, and braced for rigidity. Provide removable panels for access to interior. Paint un-coated steel parts with corrosion resistant paint to CAN/CGSB 1.181. Finish inside and out, over prime coat, with rust resistant enamel. Internally line cabinet with 50 mm thick rigid acoustic insulation, pinned and cemented, complete with metal nosings on exposed edges .

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: Comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 FAN INSTALLATION

- .1 Install fans as indicated, complete with resilient mountings specified in Section 23 05 49 – Seismic Restraint Systems (SRS) – Type P2 Buildings, flexible electrical leads and flexible connections.
- .2 Bearings and extension tubes to be easily accessible.
- .3 Access doors and access panels to be easily accessible.

3.3 ANCHOR BOLTS AND TEMPLATES

- .1 Size anchor bolts to withstand seismic acceleration and velocity forces as specified.

3.4 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

Part 1 General

1.1 SUMMARY

- .1 Section Includes:
 - .1 Mechanical louvers; gooseneck hoods.

1.2 REFERENCES

- .1 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA)

1.3 SYSTEM DESCRIPTION

- .1 Performance Requirements:
 - .1 Catalogued or published ratings for manufactured items: obtained from tests carried out by manufacturer or those ordered by manufacturer from independent testing agency signifying adherence to codes and standards.

1.4 SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.

Part 2 Products

2.1 GOOSENECK HOODS

- .1 Thickness: to ASHRAE and SMACNA.
 - .1 to ASHRAE SMACNA.
- .2 Fabrication: to ASHRAE and SMACNA.
 - .1 to ASHRAE SMACNA.
- .3 Refer to detail on drawing

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 In accordance with manufacturer's and SMACNA recommendations.
- .2 Reinforce and brace as indicated.
- .3 Anchor securely into opening. Seal with caulking to ensure weather tightness.

END OF SECTION

Part 1 General

1.1 RELATED SECTIONS

- .1 Section 26 05 00 – Electrical General Requirements.

1.2 PRODUCT DATA

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product data to include:
 - .1 Replacement data for motor element, thermostat, and switch.
 - .2 Mounting methods.
 - .3 kW rating, voltage, phase.
 - .4 Cabinet material thicknesses.
 - .5 Physical size.
 - .6 Finish.
 - .7 Thermostat, transformer, controls where integral.

Part 2 Products

2.1 FORCED AIR HEATERS

- .1 Forced air heaters, ceiling mounted commercial type as follows:
 - .1 Enclosure:
 - .1 Steel, 1.2 mm thick.
 - .2 Knockouts for 12 mm diameter conduit left, right, bottom, and rear.
 - .3 Grill and frame finished off-white.
 - .2 Elements and Fan:
 - .1 Mineral insulated.
 - .2 Motor: totally enclosed, shaded pole, impedance protected motor.
 - .3 Rating:
 - .1 Refer to schedule on drawing M-1.
- .2 Controls:
 - .1 Wall mounted thermostat: type, to Section 23 09 33 - Electric and Electronic Control System for HVAC.
- .3 Built-in accessible, tamper-proof controls. 'On-Off-Fan Only' selector switch and temperature control knob.

Part 3 Execution

3.1 INSTALLATION

- .1 Install heaters in accordance with manufacturer's instructions.
- .2 Make power and control connections.

3.2 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 – Electrical General Requirements.

END OF SECTION