

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving - PWGSC / Réception des soumissions
- TPSGC
11 Laurier St. / 11, rue Laurier
Place du Portage, Phase III
Core 0B2 / Noyau 0B2
Gatineau
Québec
K1A 0S5
Bid Fax: (819) 997-9776

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Civilian Aircraft Division/Division des Avions Civils
Portage III 8C1 - 50
11 Laurier St./11 rue Laurier
Gatineau
Québec
K1A 0S5

Title - Sujet HELICOPTER PROJECT (DFO)	
Solicitation No. - N° de l'invitation F7013-120014/I	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client F7013-120014	Date 2015-09-03
GETS Reference No. - N° de référence de SEAG PW-\$CAG-003-25220	
File No. - N° de dossier 003cag.F7013-120014	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-09-30	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: MacNeil, Michael	Buyer Id - Id de l'acheteur 003cag
Telephone No. - N° de téléphone (819) 956-0078 ()	FAX No. - N° de FAX (819) 997-0437
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

F7013-120014/I

Amd. No. - N° de la modif.

004

Buyer ID - Id de l'acheteur

003cag

Client Ref. No. - N° de réf. du client

F7013-120014

File No. - N° du dossier

003cagF7013-120014

CCC No./N° CCC - FMS No/ N° VME

This page intentionally left blank

CANADIAN COAST GUARD FULL FLIGHT SIMULATOR PROCUREMENT

The purpose of this Amendment 004 is to:

- provide answers to questions received in response to the RFP

1. The questions received and the associated answers are listed in table below.

FFS-33	Question	RFP Reference: FR-001: Some discrepancies/omissions were noted on the building drawing E003 with regards to the building provided electrical services. Please refer to the attached Facilities Report Table 3-1 and Electrical Schematic for the FFS power requirements.
	Answer	Any minor discrepancies can be addressed post FFS contract award via an amendment to the facilities contract. Any major discrepancies/omissions that would significantly impact the building design should be identified to Canada as soon as possible during this RFP process.
FFS-34	Question	RFP Reference: FR-001: Please confirm if the Transport Canada building is supplying a UPS and if so, which simulator equipment will it back up?
	Answer	The current building design integrates a 100kVA UPS. Canada's aim is that the UPS will support the computer complex, interface circuits, visual system, and any computer room controlled FFS system. However, if additional power is needed, the bid proposal should identify the requirements for the Bidder's FFS and minor discrepancies can be addressed post FFS contract award via an amendment to the facilities contract.
FFS-35	Question	RFP Reference: FR-001: Please note the Roll-on/Roll-off (Ro/Ro) mezzanine height requirement for our simulator is different than the height of 3100mm shown on the building drawings.. Please confirm that Canada will update the building design to accommodate the mezzanine height required to allow the Ro/Ro capability.
	Answer	The mezzanine floor height of 3100mm has been designed to accommodate any potential FFS. If a change to the mezzanine height is required, that will be addressed post FFS contract award via an amendment to the facilities contract.
FFS-36	Question	RFP Reference: Annex A, Appendix C: Appendix C to Annex A (i.e. The Baseline Statement of Technical Requirements) includes Attachments 1 to 4 with object numbers under the column heading "Requirements". This suggests that these attachments are to be considered mandatory requirements within the Baseline Statement of Technical Requirements, and implies that all requirements within these attachments must be included in the Compliance Matrix (DID T-001). However, most of the requirements within these attachments duplicate requirements already included in the Baseline Statement of Technical Requirements. In addition, the removal of object numbers 2.0-3 to 2.0-7 from the Baseline Statement of Technical Requirements between the Draft and Final RFP stages suggests that Attachments 1 to 4 are meant to serve as informative reference as opposed to requirements documents in their own right. Please confirm that Attachments 1 to 4 of Appendix C to Annex A are intended for informational purposes only and not as separate requirements

Contract No. - N° du contrat
F7013-120014/I

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
003cag

Client Ref. No. - N° de réf. du client
F7013-120014

File No. - N° du dossier
003cagF7013-120014

CCC No./N° CCC - FMS No./N° VME

		documents, and that bidders are not required to extract the requirements from these attachments to address them in the compliance matrix.
	Answer	Attachments 1 to 4 of Appendix C to Annex A are for guidance purposes only and are not intended as requirements. Object numbers 12-15 were included in the table in error. This will be corrected in an amendment.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED