

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Electrical Safety Repairs	
Solicitation No. - N° de l'invitation EZ108-160636/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client	Date 2015-09-11
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-7595	
File No. - N° de dossier PWY-5-38161 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-09-18	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (604) 666-8228 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - Esquimalt Graving Dock - Victoria, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EZ108-160636/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

001

File No. - N° du dossier

PWY-5-38161

Buyer ID - Id de l'acheteur

pw031

CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

This Amendment 001 is raised to provide the list of Site Visit Attendees and to incorporate Addendum No. 1.

Site Visit Attendees

Rushmore Electrical Services Inc.
Prime Engineering
Mega Power Installations

Please see the attached Addendum No. 1.

All other terms and conditions remain unchanged.

The following addendum supersedes information contained in drawings and specifications issued for the project to the extent referenced. This Addendum forms part of the Tender Documents and is subject to all of the conditions set out in the contract conditions.

This electrical addendum contains one (1) page.

1. REFER TO ELECTRICAL DRAWINGS

- 1.1 Drawing E6.0
 - .1 Delete drawing E6.0.
- 1.2 Drawing E9.0
 - .1 Amend drawing with the following: Add a keynote '6' and cloud around 12.5kV OCB, 50/51 phase and ground relays upstream of T12.5 SS-1.
 - .2 Amend: Add Keynote 6 reading: "Install revised overcurrent device settings to existing overcurrent phase and ground relays. Settings to be provided by Departmental Representative. Test and commission relays and confirm correct OCB operation with revised settings using secondary injection."
 - .3 Amend: Add Keynote 7 reading: "Remove existing baffles and filters from transformer enclosure. Remove existing fiberglass air baffles from transformer core and coils. Existing exhaust ductwork connected to transformer enclosures shall be disconnected from transformer enclosure and removed up to and including the first 90 degree bend. Blank up duct work. Install blank plate on transformer enclosure roof. Exhaust duct is approximately 900mm x 1200mm in size, to be confirmed on site."
 - .4 Amend: Add a keynote '7' pointing at existing T12.5 SS-1 transformer.

2. REFER TO ELECTRICAL SPECIFICATIONS

- 2.1 General
 - .1 Remove all notations for scope of work related to the Pump House.

END OF AES ELECTRICAL ADDENDUM #1