

The following change(s) to the tender documents are effective immediately, and will form part of the contract documents:

1. GENERAL

| | |
|-----|--|
| 1.1 | The Bidding Documents are amended as noted in this Addendum, which consists of 2 pages. |
| 1.2 | This Addendum is issued prior to bid closing to incorporate revisions noted herein. Include in the Bid price all such revisions which will become part of the Work. Perform all such Work in accordance with the Contract Documents. |
| 1.3 | All affected drawings, schedules and panel changes shall be reflected in final as-built and manual submissions. |

2. CHANGES TO PREVIOUS ADDENDA

| | |
|-----|-----|
| 2.1 | N/A |
|-----|-----|

3. DRAWINGS

| | |
|-----|-----|
| 3.1 | N/A |
|-----|-----|

4. SPECIFICATIONS

| | |
|-----|-----|
| 4.1 | N/A |
|-----|-----|

5. COMMENTS

| | |
|-----|--|
| 5.1 | <p><u>Comment</u></p> <p>Can you please look into the door hardware. I believe the hardware groups listed on the door schedule are incorrect. They also are very different than the hardware list shows in appendix 2. My question is which should I follow, I believe we should be following appendix 2.</p> <p><u>Response</u></p> <p>Refer to 1/A6.1 Door, Window, Frame & Hardware Schedule:</p> <ol style="list-style-type: none">1. Revise Door D116A to Hardware Group 12. Revise Door D101A to Hardware Group 23. Revise Door D105AA (Under stair) to Hardware Group 134. Revise Door D101B to Hardware Group 145. Revise Door D100A to Hardware Group 15 <p>Refer to Specification Appendix 2 Hardware Schedule</p> <ol style="list-style-type: none">1. Group 2: ADD Electric Strike SDC-55DU-6302. Group 3: REVISE lockset to F133. Group 13: RENAME to (Door D105AA) |
|-----|--|

5.2

Comment

Room 115 is one the finish schedule, but I can't find it on the plan. Please advise.
Room 117 & 118 are on the floor plan, but not on the finish schedule. Please advise.

Response

1. Delete Room 115 from Finish Schedule on Sheet A2.3.

ADD Room "117 Corridor" and "Room 118 Copy" to Finish Schedule on Sheet A2.3. –
all room finish requirements for 117 & 118 to match Room 103 File Area.

6. ATTACHMENTS

6.1

N/A

End of Addendum No.7.