

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Feed Barn Rehabilitation	
Solicitation No. - N° de l'invitation E0209-161134/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client AAFC E0209-161134	Date 2015-09-23
GETS Reference No. - N° de référence de SEAG PW-\$PWU-107-10553	
File No. - N° de dossier PWU-5-38170 (107)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-09-28	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Anthony, Mary	Buyer Id - Id de l'acheteur pwu107
Telephone No. - N° de téléphone (780) 237-7582 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

E0209-161134/A

Amd. No. - N° de la modif.

004

Buyer ID - Id de l'acheteur

pwu107

Client Ref. No. - N° de réf. du client

AAFC E0209-161134

File No. - N° du dossier

PWU-5-38170

CCC No./N° CCC - FMS No/ N° VME

See attached Addendum No. 3

The following change(s) to the tender documents are effective immediately, and will form part of the contract documents:

1. GENERAL

1.1	The Bidding Documents are amended as noted in this Addendum, which consists of 2 pages.
1.2	This Addendum is issued prior to bid closing to incorporate revisions noted herein. Include in the Bid price all such revisions which will become part of the Work. Perform all such Work in accordance with the Contract Documents.
1.3	All affected drawings, schedules and panel changes shall be reflected in final as-built and manual submissions.

2. CHANGES TO PREVIOUS ADDENDA

2.1	N/A
-----	-----

3. DRAWINGS

3.1	N/A
-----	-----

4. SPECIFICATIONS

4.1	N/A
-----	-----

5. COMMENTS

5.1	<p><u>Comment</u> What kw do they want they mention 30kw then refer to 30kw minimum and 170kw max in the next paragraph</p> <p><u>Response</u> 1. 30kW</p>
5.2	<p><u>Comment</u> Is this enclosed or open they mention both in the spec</p> <p><u>Response</u> 1. Enclosed with factory-installed weather enclosure.</p>
	<p><u>Comment</u> 110% loading is a problem as it could void factory warranty these units are designed for 100% loading</p> <p><u>Response</u> 1. 100% loading</p>
	<p><u>Comment</u> The engine spare filters and oil they refer to them but make no mention if they are to be quoted as spare parts</p>

	<u>Response</u> 1. Provide one set of filters and oil for an oil change.
	<u>Comment</u> Asking for the radiator to have an adapter flange for ducting again open or enclosed unit question <u>Response</u> 1. Factory-assembled enclosed generator, no adaptor flange required.
	<u>Comment</u> Muffler which would they prefer critical or hospital grade difference in price and size <u>Response</u> 1. Critical grade.
	<u>Comment</u> Do they have a sound rating they are wanting to achieve <u>Response</u> 1. There is no specific sound rating required.
	<u>Comment</u> They mention a building for dB measurements but they have not indicated if it is an open unit or enclosed <u>Response</u> 1. The measurements are to occur on the perimeter of the enclosed generator.

6. ATTACHMENTS

6.1	N/A
-----	-----

End of Addendum No.3.