



GENERAL NOTE:

1. CONTRACTOR SHALL VISIT SITE PRIOR TO TENDER TO VERIFY EXISTING SERVICES AND SITE CONDITION. NO ALLOWANCE SHALL BE MADE DUE TO FAILURE TO DO SO.
2. CONTRACTOR SHALL REPORT ANY DISCREPANCIES TO THE DEPARTMENTAL REPRESENTATIVE PRIOR TO PROCEEDING WITH WORK.
3. UNLESS OTHERWISE INDICATED, ALL ELECTRICAL SERVICES AND LIGHTING SHALL BE DISCONNECTED FROM ITS POWER SOURCE AND REMOVED. (IE) ALL BRANCH WIRING MUST BE PULLED FROM CONDUIT, WALLS OR CEILING SPACE AND MADE SAFE.
4. KEEP CONSISTENCE WITH EXISTING INSTALLATION SHALL BE USING SAME BOX TYPES AND CONDUCTOR PROTECTION.