


ELEVATION — REVISED PARALLELING SWITCHGEAR  
SCALE : N.T.S.



UNDER NORMAL OPERATION, BREAKER FOR LOAD BANK IS OPEN. TO PERFORM GENERATOR TESTS WITH LOAD BANK, CLOSE THE LOAD BANK BREAKER. IF NORMAL UTILITY POWER FAILS WHILE THE LOAD BANK BREAKER IS IN THE CLOSED POSITION, THE SHUNT TRIP MECHANISM WILL OPEN THE LOAD BANK BREAKER, DISCONNECTING THE LOAD BANK FROM THE GENERATORS.



## GENERATOR REPLACEMENT DORCHESTER PENITENTIARY

drawing
dessin

# REVISED SINGLE LINE DISTRIBUTION

designed	RGR	conceded
date	SEPTEMBER 3, 2015	
drawn	RJT	designed
date	SEPTEMBER 3, 2015	
approved		approved
date		
Tender	Sourmission	
PWGSC Project Manager	Administrateur de projets TPSGC	
project number	no. du projet	
R.061866.001		
drawing no.	no. du dessin	