

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Public Works and Government Services Canada**  
**ATB Place North Tower**  
**10025 Jasper Ave./10025 ave. Jasper**  
**5th floor/5e étage**  
**Edmonton**  
**Alberta**  
**T5J 1S6**  
**Bid Fax: (780) 497-3510**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works and Government Services Canada**  
**ATB Place North Tower**  
**10025 Jasper Ave./10025 ave Jasper**  
**5th floor/5e étage**  
**Edmonton**  
**Alberta**  
**T5J 1S6**

<b>Title - Sujet</b> Road Renewal, EINP	
<b>Solicitation No. - N° de l'invitation</b> EW038-161240/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b> Parks EW038-161240	<b>Date</b> 2015-09-23
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-107-10558	
<b>File No. - N° de dossier</b> PWU-5-38178 (107)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2015-09-28</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Daylight Saving Time MDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Anthony, Mary	<b>Buyer Id - Id de l'acheteur</b> pwu107
<b>Telephone No. - N° de téléphone</b> (780) 237-7582 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

**This amendment 001 has been raised to make the following changes:****Item 1**

The quantity in the Notice of Proposed Procurement has been changed to 42,500 square metres.

**Item 2****Delete in its entirety:**

BA06 Construction Time

The Contractor shall perform and complete the Work within 30 weeks from the date of notification of acceptance of the offer.

**Insert in its place:**

BA06 Construction Time

The Contractor shall perform and complete the Work within thirty eight (38) weeks from the date of notification of acceptance of the offer.

**Item 3**

Please see attached Bidders' Optional Site Visit Attendance sheet.

**Item 4**

Please see attached Addendum #1.

**EINP ROADS RENEWAL PROJECT  
ADDENDUM No. 1**

---

**CLARIFICATIONS**

- 1 . On page 4 of 8 in Section 01 00 10 GENERAL REQUIREMENTS, in Article 10 delete point .3
  - 2 . On page 1 of 2 in Section 32 00 01 SUBGRADE PREPARATION, in Article 2.0.2, replace the third sentence with the following:  
  

***“The loosened material shall be windrowed to one side and the exposed surface shall be thoroughly compacted by a vibratory packer to uniformly roll the surface to a smooth condition.”***
  - 3 . On page 1 of 2 in Section 32 00 01 SUBGRADE PREPARATION, in Article 2.0.3.3 Gravel Surfacing Gradation, the units under Alberta Transportation Designation 4 Class 20 are in microns
- 

**QUESTIONS and ANSWERS from Bidders' Site Meeting**

- Q<sub>1</sub>** Are there any restrictions on the order in which the work can be performed?  
**A<sub>1</sub>** Due to the ongoing activity in the Administration Area, the work in the following areas shall not be commenced until the spring of 2016 unless approval is granted by the Department Representative:
- all work areas as shown on Drawing C3
  - the work in Area B shown on Drawing C2
- Q<sub>2</sub>** Are there unit prices for the removal of vegetation along the edges of the roadways and trail head parking areas?  
**A<sub>2</sub>** There is no unit price for the removal of vegetation along the roadways and trail head areas or any other areas within the contract. The cost to carry out this work should be included in the lump sum amount of the bid form.
- Q<sub>3</sub>** What are the weight restrictions on the Park Access Roads?  
**A<sub>3</sub>** Weight restrictions on all Park Access Roads will be the same as those restrictions placed on Highway 831 South of Lamont. This will include the percent axle weights and the beginning and end of the ban restrictions.
- Q<sub>4</sub>** What Park entrances may be used by the Contractors to access the work areas?  
**A<sub>4</sub>** Contractors may use any of the 3 entrances to access their work areas.
- Q<sub>5</sub>** In parking lots, do pre-cast concrete curbs need to be removed and replaced?  
**A<sub>5</sub>** It is intended that the curbs not be removed. The work limits will be 300 mm from concrete curbs, cattleguards, manholes, concrete pads and other fixed structures.
- Q<sub>6</sub>** What is the bid security and contract security required for this contract?  
**A<sub>6</sub>** Bid security and contract security are covered in the Invitation to Tender Document.

**Q<sub>7</sub>** Where can waste material be disposed of?

**A<sub>7</sub>** Stripped vegetation from the parking lots and roadways must be hauled and disposed of off site. Granular material free of deleterious material can be disposed of in the wood lot area, approximately 500 m from the Astotin Day Use Area.

**Q<sub>8</sub>** Where should questions be directed during the Tender period?

**A<sub>8</sub>** Questions arising during the Tender period should be directed to Mary Anthony, as per the Invitation to Tender Documents.

**Q<sub>9</sub>** What days and hours are allowed for work on this contract?

**A<sub>9</sub>** Please refer to Article 16.1 in the General Requirements.

---

***END OF ADDENDUM No. 1***  
(Total 2 pages)

## Bidders' Site Meeting Attendance Sheet

Representative	Company	Telephone/E-mail
Rob Hafer	Public Works and Government Services Canada	T: (780) 497-3997 E: Rob.Hafer@pwgsc-tpsgc.gc.ca
Michel Blean	West Industries Group	T: 587 982-0328 E: michel@westindustries.ca
Rith Sudyko	GCS Energy	T: 403 506 6686 E: rsudyko@gcsenergy.ca
Rembert Jeske	PCL	T: 780 203 4643 E: rjeske@pcl.com
NEIL CHRISTENSEN	BORDER PAVING	T: 780-672 3389 E: neil@borderpaving.com
Ann McLean	Devlin Construction	T: 180-640-3363 E: ann@devlinconstruction.com
DEAN MORROW	E CONSTRUCTION	T: 780-874-2075 E: DEAN.MORROW@ECLTD.CA
JARED STEVENS	E CONSTRUCTION	T: 780 874 2075 E: JARED.STEVENS@ECLTD.CA
		T: E:
		T: E:
		T: E: