

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions  
189 Prince William Street  
Room 405  
Saint John  
New Brunswick  
E2L 2B9

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Officer, Janine Donovan: Email - janine.donovan@pwgsc.gc.ca or Fax No. (506) 636-4376.

### Vendor/Firm Name and Address

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

### Issuing Office - Bureau de distribution

Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions  
189 Prince William Street  
Room 405  
Saint John  
New Bruns  
E2L 2B9

<b>Title - Sujet</b> Diesel Generators - Dorchester Med.	
<b>Solicitation No. - N° de l'invitation</b> EC016-161237/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b> R.061866.001	<b>Date</b> 2015-09-27
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-004-3703	
<b>File No. - N° de dossier</b> PWB-5-38081 (004)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-10-22</b>	<b>Time Zone</b> Fuseau horaire Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Donovan, Janine PWB	<b>Buyer Id - Id de l'acheteur</b> pwb004
<b>Telephone No. - N° de téléphone</b> (506) 636-5347 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Cette modification à l'invitation numéro un (1) est soumise pour inclure l'addenda numéro 1 suivant.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'Addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Addenda numéro 1.

### **QUESTIONS ET RÉPONSES**

**Q1:** Will the existing fuel tank be reused to supply fuel to the new 600Kw generator?

**R1:** There is no change to the fuel storage system and it supplies two generators. However, the mechanical drawings show a new fuel polishing system being added.

**Q2:** Are you replacing one 600Kw generator or two 600Kw generators?

**R2:** The solicitation documents clearly show the removal of two 300kW/375kVA units and the supply and installation of two 600kW/750kVA units.

**Q3:** What size is the critical breaker to be on the new 600Kw genset? (assume 800 amps)

**R3:** The solicitation documents state that a 100% rated S/S breaker is to be supplied with each generator. 750A would be the best option.

**Q4:** The specifications ask for eight hours of factory testing. Is this to be done on equipment sold or is a certified factory test report acceptable?

**R4:** No, testing and associated reports are specified to the equipment sold.

**Q5:** Are you replacing any transfer switches? ATS #1, #2 and #3 or replacing the generator only?

**R5:** The ATS's are not being replaced.