

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Officer, Janine Donovan: Email - janine.donovan@pwgsc.gc.ca or Fax No. (506) 636-4376.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Diesel Generators - Dorchester Med.	
Solicitation No. - N° de l'invitation EC016-161237/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client R.061866.001	Date 2015-09-27
GETS Reference No. - N° de référence de SEAG PW-\$PWB-004-3703	
File No. - N° de dossier PWB-5-38081 (004)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-10-22	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb004
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment No. One (1) is raised to include the following addendum no. 1.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum 1.

QUESTIONS AND ANSWERS

Q1: Will the existing fuel tank be reused to supply fuel to the new 600Kw generator?

A1: There is no change to the fuel storage system and it supplies two generators. However, the mechanical drawings show a new fuel polishing system being added.

Q2: Are you replacing one 600Kw generator or two 600Kw generators?

A2: The solicitation documents clearly show the removal of two 300kW/375kVA units and the supply and installation of two 600kW/750kVA units.

Q3: What size is the critical breaker to be on the new 600Kw genset? (assume 800 amps)

A3: The solicitation documents state that a 100% rated S/S breaker is to be supplied with each generator. 750A would be the best option.

Q4: The specifications ask for eight hours of factory testing. Is this to be done on equipment sold or is a certified factory test report acceptable?

A4: No, testing and associated reports are specified to the equipment sold.

Q5: Are you replacing any transfer switches? ATS #1, #2 and #3 or replacing the generator only?

A5: The ATS's are not being replaced.