

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Growth Chamber Replacement	
Solicitation No. - N° de l'invitation EZ899-160989/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client	Date 2015-09-29
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-7611	
File No. - N° de dossier PWY-5-38175 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-10-01	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 775-9382 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: AAFC - Pacific Agri-Food Research Centre - Summerland, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EZ899-160989/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

005

File No. - N° du dossier

PWY-5-38175

Buyer ID - Id de l'acheteur

pw028

CCC No./N° CCC - FMS No/ N° VME

Please find Addendum No. 4 herein.

All other terms and conditions remain unchanged.

**The following changes/clarifications in the tender documents are effective immediately.
This addendum will form part of the contract documents.**

Special Instructions to Bidders

1.0 SPECIFICATIONS

- 1.1 Refer to Section 02 41 99, Demolition for Minor Works, Site Conditions
Delete:
.3 Extent of Demolition - refer to drawing including removal and disposal of all existing furniture and tables in the galleria and atrium only after arrival and installation of new furniture.

QUESTIONS:

1. Specification Section 02 41 99 references removal of existing furniture and tables in the existing atrium and galleria however the drawings do not appear to show the extent of this work. If it is required please confirm the extent and whether or not the existing furniture is to be salvaged or disposed of.

Response: Refer to 1.1 of Addendum 4

2. Please confirm the concrete mix design for the sloped topping.

Response:

Minimum 28-days strength (MPa)

Slab on grade (Interior) - 25

Slab on grade (Exterior) – 32

Maximum aggregate size (mm)

Slab on grade (Interior) - 20

Slab on grade (Exterior) – 20

Exposure class

Slab on grade (Interior) – C-4

Slab on grade (Exterior) – C-2

Air content category

Slab on grade (Interior) - 2

Slab on grade (Exterior) - 1

3. Specification Section 03 35 00 indicates product data for non-shrink grout and densifier. As these products are not indicated in the drawings please confirm if they are to be used anywhere.

Response: Refer to the specification Non-Shrink Grout(for patching). This would be for making good existing concrete floors

Densifer - not applicable

4. Specifications are provided for Finish Carpentry however none is indicated in the drawings. Please confirm the extent if any.

Response: Refer to Drawing A-4, Provide painted 19 thick plywood backing to all new wall mount equipment in new Service Room, plus installation of finish hardware, doors, trim etc.

5. Specifications are provided for blanket insulation however none is indicated in the drawings. Please confirm extent if any. (New Service Room walls?)

Response: Refer to Drawing A-04, Legend, New Wall Assembly includes Acoustic Batt Insulation

End of Addendum #4