



**Royal Canadian Mounted Police
Gendarmerie royale du Canada**

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A:
Bid Receiving/Réception des
soumissions**

RCMP / GRC
NWR Procurement & Contracting Services
c/o Commissionaires, D Division
1091 Portage Avenue
Winnipeg, MB R3C 3K2

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

Proposal to: Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefor.

Proposition aux: Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaries

**Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de
l'entrepreneur**

Telephone No. - no de téléphone:

| | |
|--|--|
| Title-Sujet: Radon Mitigation various locations in Manitoba | |
| Solicitation No. - No. de l'invitation M5000-6-0105/B | Date 29 September 2015 |
| Amendement No. – No modif : 003 | |
| Solicitation Closes -L'invitation prend fin at - à 2:00 PM Central Daylight Savings Time on - le 08 October 2015 | |
| F.O.B. - F.A.B. Plant - Usine: Destination:√ Other-Autre: | |
| Address Enquiries to: - Adresser toutes questions à: Cathi Johannson, Senior Procurement Officer cathi.johannson@rcmp-grc.gc.ca | |
| Telephone No. - No de téléphone 204-984-1836 | Fax No. - N° de FAX: 204-984-4253 |
| Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Various RCMP identified locations throughout Manitoba | |
| This document DOES contain a Personnel Security Requirement | |
| Delivery Required - Livraison exigée: 31 March 2016 | Delivery Offered - Livraison proposée |
| Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur | |
| _____ | |
| Name /Nom | Title/Titre |
| _____ | |
| Signature /Signature | Date/Jour |
| (Please sign and return cover page with bid proposal./ Signez s'il vous plaît et la page de couverture de retour avec la proposition d'offre.) | |



Amendment 003 is raised to respond to the following question as submitted to the Contracting Authority:

Question 1:

One month Electronic Data logger test after completion: Can you provide more details? This constitutes a tremendous capital expense and financial risk if it requires valuable electronic data logging equipment (CRM) to be left on-site for 30 days in over 33 different locations with no guarantee of safe equipment return. If expensive CRMs are not used, what other options are acceptable?

Is it fair to suggest that RCMP review the applicability of this project requirement?

Response:

Please remove the requirement for a one month electronic logger test. RCMP requires the mitigation be substantiated by a short term test, by methods previously mentioned, so that the Contractor can demonstrate the mitigation has lowered Radon to below 200 Bq/m3.

The RCMP will continue with independent, long term testing through an internal Radon testing program for all RCMP properties.