

KM175-14-1300
QUESTIONS and ANSWERS #1

Q. In reference to the drawing S1 the site plan can you please provide a scale so we can determine how long the duct banks need to be.

A. The length is approximately 250 feet.