

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
PWGSC/TPSGC Acquisitions
1045 Main Street
1st Floor, Lobby C
Unit 108
Moncton, NB E1C 1H1
Bid Fax: (506) 851-6759

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
NB / PEI Division - Moncton Acquisitions Office
1045 Main Street
1st Floor, Lobby C
Unit 108
Moncton, NB E1C 1H1

Title - Sujet Water Treatment System	
Solicitation No. - N° de l'invitation 39903-160543/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client 39903-160543	Date 2015-10-01
GETS Reference No. - N° de référence de SEAG PW-\$MCT-011-5071	
File No. - N° de dossier MCT-5-38054 (011)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-11-02	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Sharpe, Charlene A.	Buyer Id - Id de l'acheteur mct011
Telephone No. - N° de téléphone (506) 851-3467 ()	FAX No. - N° de FAX (506) 851-6759
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation Amendment

Title Water Treatment System

Solicitation Amendment No. 001

This solicitation is hereby amended to provide the following questions and answers

Q1. In order to design the system properly, and to manage the process well with the right equipment, we will need to have the specific details of the feed water which will be sent through the sytem. We also will like for you to shrae the details of the final water quality (resistivity, pH range) you are desiring. Would you please provide the following information (please note listing deleted intentionally as response addresses same).

A1. Bidders must attend the mandatory site visit and are encouraged to take water samples for analysis during this visit. The water analysis results may be used to support the rationale for equipment selection as requested in (M2) Mandatory 2 Technical Evaluation Criterion. Product water quality will be discussed at the mandatory site visit.

Q2. We would also like to know if you are requesting tanks for the reverse osmosis permeate, and details of waht you are envisioning for the layout before and after the electro-deionization equipment.

A2. No, we are not requesting permeate storage tanks as outlined in Annex A, Statement of Work, Section 4 Scope. The bidder's RFP submission may include a conceptual piping flow diagram for their proposed water treatment system and be provided as part of the technical proposal Annex C, Technical Evauation Criteria. This flow diagram is to illustrate the bidder's proposed equipment layout.

Q3. I would like to know if it is possible to have an alternative arrangement in regards to the mandatory site meeting for the above tender. The site meeting is scheduled for Monday, October 5th which conflicts with the annual Atlantic Canada Water-Wastewater Association Conference taking place in St. John's, NL, October 4th-7th.

A3. Part 2 - Bidders Instructions / 2.2.2 Mandatory Site Visit has been changed to Thursday, October 8, 2015. The site visit will begin at 9:00 am, Atlantic Daylight Saving Time in Boardroom UO-08.

AND

-
- (1) Reference: **Page 1 of 2, Cover Page, Solicitation Closes**
DELETE “at 2:00 PM, on 2015-11-02 Atlantic Daylight Saving Time ADT”; and
INSERT “at 2:00 PM, on 2015-11-02 **Atlantic Standard Time AST**”.
- (2) Reference: **Page 3 of 16, Article 2.2.2 Mandatory Site Visit**
DELETE Article 2.2.2 Mandatory Site Visit in its entirety; and
INSERT Article 2.2.2 Mandatory Site Visit (**Revised October 1, 2015**) attached.

If your bid has already been forwarded and you wish to revise same, this revision should be sent either in a sealed envelope and mailed to the above address or by facsimile (506) 851-6759 and reach the undersigned before the appropriate closing date. The solicitation number and the closing date are to be shown on the outside of the sealed envelope or on the facsimile transmission.

All other terms and conditions of the solicitation document remain unchanged.

All enquiries concerning this amendment are to be forwarded to:

Name Charlene Sharpe
Telephone No.: (506) 851-3467
Facsimile No: (506) 851-6759

(Derived from - Provenant de: XNB025D, 23/01/2008)

2.2.2 Mandatory Site Visit (Revised October 1, 2015)

It is mandatory that the Bidder or a representative of the Bidder visit the work site. Arrangements have been made for the site visit to be held at 93 Mount Edward Road, Charlottetown, Prince Edward Island, on Thursday, October 8, 2015. The site visit will begin at 9:00 am, Atlantic Daylight Saving Time in Boardroom UO-08.

Bidders must communicate with the Contracting Authority no later than 3:30 pm, Atlantic Daylight Saving Time, Tuesday, October 6, 2015, to confirm attendance and provide the name(s) of the person(s) who will attend. Bidders will be required to sign an attendance sheet. Bidders should confirm in their bid that they have attended the site visit. Bidders who do not attend the mandatory site visit or do not send a representative will not be given an alternative appointment and their bid will be declared non-responsive. Any clarifications or changes to the bid solicitation resulting from the site visit will be included as an amendment to the bid solicitation

(Derived from - Provenant de: A9040T, 2015/07/03)