

PART 1 - GENERAL

1.1 RELATED REQUIREMENTS

- .1 Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CSA C22.1-12, Canadian Electrical Code, Part 1.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 – Construction/Demolition Waste management and Disposal.

1.5 MEASUREMENT FOR PAYMENT

- .1 No separate measurement for payment shall be made for items under this section. Include costs incidental in the Lump Sum Amount of work on the Combined Price Form.

PART 2 - PRODUCTS

2.1 JUNCTION AND PULL BOXES

- .1 Construction: welded steel enclosure. Enclosure to provide a degree of environmental protection equal to or higher than CSA Type 1 for indoor and 4X for outdoor.
 - .2 Covers Flush Mounted: 25 mm minimum extension all around.
 - .3 Covers Surface Mounted: screw-on turned edge covers.
-

PART 3 - EXECUTION

3.1 JUNCTION AND PULL BOXES

- .1 Install pull boxes in inconspicuous but accessible locations.
- .2 Only main junction and pull boxes are indicated. Install additional pull boxes as required by CSA C22.1.

3.2 IDENTIFICATION

- .1 Equipment Identification: to Section 26 05 00 - Common Work Results for Electrical.
- .2 All junction boxes: indicate panel and circuit number.