

PART 1 - GENERAL

1.1 RELATED REQUIREMENTS

- .1 Section 26 05 32 - Outlet Boxes, Conduit Boxes and Fittings.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CAN/CSA C22.2 No. 18.1-13, Metallic Outlet Boxes.
 - .2 CSA C22.2 No. 45.1-07(R2012), Rigid Metal Conduit.
 - .3 CSA C22.2 No. 56-13, Flexible Metal Conduit and Liquid-Tight Flexible Metal Conduit.
 - .4 CSA C22.2 No. 83-M1985(R2013), Electrical Metallic Tubing.
 - .5 CSA C22.2 No. 211.2-06(R2011), Rigid PVC (Unplasticized) Conduit.
 - .6 CAN/CSA No. 18.3-12, Conduit, Tubing and Cable Fittings.
 - .7 CSA C22.2 No. 211.1-06(R2011), Rigid Types EB1 and DB2/ES2 PVC Conduit.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product data: submit manufacturer's printed product literature, specifications and datasheets.
 - .1 Submit cable manufacturing data.
- .3 Quality assurance submittals:
 - .1 Test reports: submit certified test reports.
 - .2 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .3 Instructions: submit manufacturer's installation instructions.

1.4 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .2 Place materials defined as hazardous or toxic waste in designated containers.
 - .3 Ensure emptied containers are sealed and stored safely for disposal away from children.
-

1.5 MEASUREMENT FOR PAYMENT

- .1 No separate measurement for payment shall be made for items under this section. Include costs incidental in the Lump Sum Amount of work on the Combined Price Form.

PART 2 - PRODUCTS

2.1 CABLES AND REELS

- .1 Provide cables on reels or coils.
 - .1 Mark or tag each cable and outside of each reel or coil, to indicate cable length, voltage rating, conductor size, and manufacturer's lot number and reel number.
- .2 Each coil or reel of cable to contain only one continuous cable without splices.
- .3 Identify cables for exclusively dc applications.

2.2 CONDUITS

- .1 Rigid metal conduit: to CSA C22.2 No. 45, hot dipped galvanized steel threaded.
- .2 Electrical metallic tubing (EMT): to CSA C22.2 No. 83, with couplings.
- .3 Rigid pvc conduit: to CSA C22.2 No. 211.2. PVC conduits that are not concrete encased shall be Schedule 40.
- .4 Flexible metal conduit: to CSA C22.2 No. 56, liquid-tight flexible metal.

2.3 CONDUIT FASTENINGS

- .1 One hole steel straps to secure surface conduits 53 mm and smaller.
 - .1 Two hole steel straps for conduits larger than 53 mm.

2.4 CONDUIT FITTINGS

- .1 Fittings: to CAN/CSA C22.2 No. 18, manufactured for use with conduit specified. Coating: same as conduit.
 - .2 Ensure factory "ells" (condulets) where 90 degrees bends for 27 mm and larger conduits, except for communications systems.
-

2.5 EXPANSION FITTINGS FOR RIGID CONDUIT

- .1 Watertight expansion fittings with integral bonding jumper suitable for linear expansion and 19 mm deflection.

2.6 FISH CORD

- .1 Polypropylene.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Conceal conduits.
 - .2 Use rigid hot dipped galvanized steel threaded conduit where specified or subject to mechanical injury.
 - .3 Use rigid pvc conduit underground.
 - .4 Minimum conduit size for lighting and power circuits: 21 mm.
 - .5 Bend conduit cold:
 - .1 Replace conduit if kinked or flattened more than 1/10th of its original diameter.
 - .6 Mechanically bend steel conduit over 21 mm diameter.
 - .7 Field threads on rigid conduit must be of sufficient length to draw conduits up tight.
 - .8 Install fish cord in empty conduits.
 - .9 Remove and replace blocked conduit sections.
 - .1 Do not use liquids to clean out conduits.
 - .10 Dry conduits out before installing wire.
-

3.3 CONCEALED CONDUITS

- .1 Run parallel or perpendicular to building lines.

3.4 CONDUITS IN CAST-IN-PLACE CONCRETE

- .1 Locate to suit reinforcing steel.
 - .1 Install in centre one third of slab.
- .2 Protect conduits from damage where they stub out of concrete.
- .3 Install sleeves where conduits pass through slab.
- .4 Provide oversized sleeve for conduits passing through waterproof membrane, before membrane is installed.
 - .1 Use cold mastic between sleeve and conduit.
- .5 Conduits in slabs: minimum slab thickness four (4) times conduit diameter.
- .6 Encase conduits completely in concrete with minimum 25 mm concrete cover, unless noted otherwise.
- .7 Organize conduits in slab to minimize cross-overs.

3.5 CONDUITS UNDERGROUND

- .1 Slope conduits to provide drainage.
- .2 Waterproof joints (pvc excepted) with heavy coat of bituminous paint.