

PART 1 - GENERAL

1.1 SECTION INCLUDES

- .1 Fire Safety Requirements

1.2 RELATED WORK

- .1 Section 01 35 25 - Special Procedures on Lockout Requirements.
- .2 Section 01 35 29 - Health and Safety Requirements

1.3 REFERENCES

- .1 Fire Protection Standards issued by Fire Protection Services of Human Resources Development Canada as follows:
 - .1 FCC No. 301-June 1982 Standard for Construction Operations (http://www.hrsdc.gc.ca/eng/labour/fire_protection/policies_standards/commissioner/301/page00.shtml).
 - .2 FCC standards may also be viewed at the Regional Labour Canada office located at Johnson Centre, 10 Fort William Place, St. John's, NL, A1C 1K4, Telephone: 1-800-641-4049; Fax: (709) 772-5985.

1.4 SUBMITTALS

- .1 Submit copy of Hot Work Procedure to Departmental Representative for review, seven (7) days prior to the requirements for Hot Work.
- .2 Submit in accordance with the Submittal General Requirements specified in Section 01 33 00.

1.5 FIRE SAFETY REQUIREMENTS

- .1 Implement and follow fire safety measures during work. Comply with the latest edition of the following:
 - .1 National Fire Code
 - .2 Fire Protection Standards FCC 301 and FCC 302.
 - .3 Federal and Provincial Occupational Health and Safety Acts and Regulations as specified in section 01 35 29.
- .2 In event of conflict between any provisions of above authorities the most stringent provision will apply. Should a dispute arise in determining the most stringent

requirement, Departmental Representative will advise on the course of action to be followed.

1.6 DOCUMENTS ON SITE

- .1 Keep hazard assessment documentation on site for duration of work.
- .2 Upon request, make available to Departmental Representative or to authorized safety representative for inspection.

1.7 MEASUREMMENT FOR PAYMENT

- .1 No separate measurement for payment shall be made for items under this section. Include costs for Special Procedures on Fire Safety Requirements in the Lump Sum Amount on the Combined Price Form.

PART 2 - PRODUCTS

Not applicable

PART 3 - EXECUTION

Not applicable