

PART 1 - GENERAL

1.1 RELATED REQUIREMENTS

- .1 Section 26 29 03 - Control Devices.

1.2 REFERENCES

- .1 CSA International
 - .1 CSA C22.2 No.14-13, Industrial Control Equipment.
- .2 National Electrical Manufacturers Association (NEMA)
 - .1 NEMA ICS 2-2000 (R2005), Controllers, Contactors and Overload Relays Rated 600 V.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for contactors and include product characteristics, performance criteria, physical size, finish and limitations.

1.4 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for contactors for incorporation into manual.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
 - .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
-

- .3 Storage and Handling Requirements:
 - .1 Store materials off ground indoors and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect contactors from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
- .4 Packaging Waste Management: remove for reuse and return of packaging materials as specified in Construction Waste Management Plan Waste Reduction Workplan in accordance with Section 01 74 21 - Construction/ Demolition Waste Management and Disposal.

1.5 MEASUREMENT FOR PAYMENT

- .1 No separate measurement for payment shall be made for items under this section. Include costs incidental in the Lump Sum Amount of work on the Combined Price Form.

PART 2 - PRODUCTS

2.1 CONTACTORS

- .1 Contactors: to CSA C22.2 No.14.
- .2 Electrically held controlled by pilot devices as indicated and rated for type of load controlled. Half size contactors not accepted.
- .3 Breaker combination contactor as indicated.
- .4 Complete with two (2) normally open and two (2) normally closed auxiliary contacts unless indicated otherwise.
- .5 Mount in CSA Enclosure Type 1 unless otherwise indicated.
- .6 Include following options in cover:
 - .1 Red and Green indicating lamp.
 - .2 Hand-Off-Auto selector switch.
- .7 Control transformer: in accordance with Section 26 29 03 - Control Devices, factory wired and installed in contactor enclosure.

2.2 EQUIPMENT IDENTIFICATION

- .1 Identify equipment in accordance with Section 26 05 00 - Common Work Results for Electrical.

- .2 Size 4 nameplate indicating name of load controlled as indicated.

2.3 WARNING SIGNS

- .1 Provide warning signs in accordance with Section 26 05 00 - Common Work Results - For Electrical.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Install contactors and connect power wires and auxiliary control devices.
- .2 Identify contactors with nameplates or labels indicating panel and circuit number.
- .3 Test contactors in accordance with 26 05 00 - Common Work Results for Electrical.

3.2 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

3.3 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials cause by contactor installation.