



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Bid Receiving – Main Floor Parks Canada John Cabot Building, 10 Barter's Hill, 5th Floor St. John's, NL A1C 6M1

Attn: Colleen Sheehan

Amendment #2

INVITATION TO TENDER
APPEL D'OFFRES

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ciannexée, au(x) prix indiqué(s).

Comments - Commentaries


Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency John Cabot Building, 10 Barter's Hill, 5th Floor St. John's, NL A1C 6M1

	~
Title-Sujet	Date
Point Pelee Visitor Centre Theatre Rehabilitation – Point Pelee National Park, Parks Canada	09-10-2015
Solicitation No No. de l'invitation Client Ref. No No.	do wéf du oliout

Rehabilitation - Point	Pelee	09-10-2015	
National Park, Parks C	anada		
Solicitation No No. de l'invitation		de réf du client.	
5P300-15-5274	n/a		
GETS Reference No. – No de reference de SEAG			
Solicitation Closes	Time Zone		
L'invitation prend fin –	Fuseau horaire -		
at – á 02:00 PM on – le 2015-10-14	Eastern Daylight	Time (EDT)	
F.O.B F.A.B.			
Plant-Usine: ☐ Destination: ☐ Other-Autre: ☐			
Address Inquiries to: - Adresser toute demande de renseignements à :			
Colleen Sheehan Colleen.sheehan@pc.gc.ca			
Telephone No No de téléphone	Fax No. – No de F	AX:	
(709)772-6129	(709)772-3651		
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein			
Vendor/Firm Name and Address			
Raison sociale et adresse du fournisseur/de l'entrepreneur :			
Telephone No No de telephone:			
Facsimile No N° de télécopieur:			
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur			





- 1. Questions and Answers #2
- Q1. If Silt Protection is required, please proceed detail of protection.
- A1. The Contractor shall supply construction staging plan, traffic coordination plan, tree protection/silt and erosion control plan to the Department Representative or designate for approval prior to construction.
- Q2. On drawing L104, shows the new work for the front of the building. Is that the extent of replacement of sidewalk as shown on drawing?
- A2. The path system that exists now in precast concrete unit pavers will be replaced with a 2.8m wide cast in place concrete path. The width and depth is intended to support light duty park maintenance vehicles. Assume a quantity of 360 square meters by a depth of 200mm for Type 1 paving as the basis for tendering.
- Q3. Please provide elevations of existing sidewalks, berms, etc and new proposed work. A3. There is no topographic information available at this time. The site is essentially flat. Bidders may assume new grades will be close to existing grades with slight alterations to improve slopes away from the building. The existing berm to be removed is approximately 600mm high with side slopes at 3 horizontal to 1 vertical. Prior to commencing work on site contractor to confirm existing grades which will be reviewed and scope of work adjusted if necessary.
- Q4. Please confirm the litter and recycling receptacles are provided by Parks Canada as per drawing notes.
- A4. yes that is correct. Litter and recycling receptacles are provided by Parks Canada.
- Q5. Can existing window sizes be provided so that the blinds can be quoted? A5. The new Window sizes are as follows and they should base quantities on this for pricing:
- 3 at 2165 high X 900mm wide and 4 at 865 high X 1000mm wide.
- Q6. There is a section in the specifications for roller window shades. I can't find a reference to the shades on the drawings. Please confirm the location(s) for the shades.
- A6. Location for the shade is the window in the workshop area.
- Q7. The table model number specified does not match the size specified. No mention of finishes for table or fabric for seat on chair? What is required? Standard finishes and Grade A fabric?
- A7. Standard finishes and Grade A fabric are required
- Q8. Would you accept dauphin North America alternatives?
- A8. Dauphin North America is acceptable as an alternative, as always they will have to meet performance of the specified product.
- Q9. Would you accept TRANE as an equivalent supplier for the roof mounted HVAC unit. A9. Yes.
- Q10. On the Landscape Drawings there is mention of Flagpole Aggregate Finishes. Is there a Flagpole required for this job? if so where is the info for this as far as Qty, Size & a General Spec?
- A10. No, a flagpole is not included in this job.