

Part 1 General

1.1 USE OF SYSTEMS

- .1 Use of existing heating and ventilating systems for supplying temporary heat or ventilation is permitted during construction, however the following conditions must be met:
 - .1 Any new systems are cleaned and flushed before use.
 - .2 Areas to be heated/ventilated are clean and will not thereafter be subjected to dust-producing processes.
 - .3 There is no possibility of damage from any cause.
 - .4 All return and exhaust systems have approved filters over openings, inlets, outlets throughout dust-producing construction area.
 - .5 Systems will be:
 - .1 Operated as per manufacturer's recommendations and instructions.
 - .2 Operated by Contractor.
 - .3 Monitored continuously by Contractor.
 - .6 Warranties and guarantees are not relaxed.
 - .7 Regular preventive and other manufacturers recommended maintenance routines are performed by Contractor at own expense and under supervision of Departmental Representative.
 - .8 Before static completion. Ductwork and underfloor areas within renovation space to be cleaned internally and externally, restored to "as- new" condition, replace filters in air systems.
- .2 Filters specified in this Section are over and above those specified in other Sections of this project.
- .3 Exhaust systems are not included in approvals for temporary heating ventilation.

Part 2 Products

2.1 NOT USED

- .1 Not Used.

Part 3 Execution

3.1 NOT USED

- .1 Not Used.

END OF SECTION