

**PART 1      General**

**1.1            REFERENCES**

- .1      Fire Commissioner of Canada FC403 Sprinkler System
- .2      National Fire Prevention Association NFPA 13- 2013, Standard for the Installation of Sprinkler Systems.

**1.2            SHOP DRAWINGS AND PRODUCT DATA**

- .1      Submit shop drawings and product data in accordance with Section 21 05 01 - Common Work Results - Mechanical and in accordance with NFPA 13, working plans and design requirements.

**1.3            CLOSEOUT SUBMITTALS**

- .1      Provide maintenance data for incorporation into manual specified in Section 21 05 01 - Common Work Results - Mechanical.
- .2      Sprinkler contractor shall provide stamped as-built drawing.

**PART 2      Products**

**2.1            SPRINKLER HEADS**

- .1      Install and relocate sprinkler heads in the locations shown on the drawings.

**2.2            ESCUTCHEONS**

- .1      Install new sprinkler escutcheons with new or relocated sprinkler heads, and replace where missing through the project renovation space.

**PART 3      Execution**

**3.1            INSTALLATION**

- .1      Install, inspect and test to acceptance in accordance with NFPA 13.
- .2      Test zone valves for affected zones after piping work is complete.
- .3      Testing to be witnessed by Fire Commissioner of Canada authority having jurisdiction.

**END OF SECTION**