

Addendum/Addenda

No./N° 3

Project Description / Description de projet S77 outdoor generator		
Solicitation No./ N° de sollicitation 15-22098	Project No./N° de projet 5088	W.O. No./N° d'ordre de travail A1-006925-07-01
Departmental Representative / Représentant Ministériel Maurice Richard	Date Oct 14, 2015	
Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

1. E01, RM. B35, note for wiring between 77TSW01 to panel EMG PDSB/N is revised as note 4, wiring and 77TSW01 and panel EMG PDSB/N are existing.
2. Q : E02 Note 9 – re-route and extend /provide new....is there anyway of know where this feed was going to originally?
A : Existing feed to be re-routed is indicated in E01 note 4.
3. E04, detail 3, MCC#2 in RM. B12 is revised as MCC #1, as per E02 single line diagram.

