



LEVEL C2 - PLUMBING &
FIRE PROTECTION - DEMOLITION & NEW WORK

- ① CONTRACTOR SHALL BE RESPONSIBLE FOR DEACTIVATION, DRAINING AND REFILLING OF WET PIPE SPRINKLER SYSTEM ON A DAILY BASIS. COORDINATE WITH BUILDING OWNER.
- ② REMOVE EXISTING SPRINKLERS AS INDICATED.
- ③ PROVIDE NEW UPRIGHT SPRINKLERS TO MAINTAIN COVERAGE AS PER NFPA.
- ④ REMOVE EXISTING CHILLED WATER PIPING C/W VALVES, ACCESSORIES AND CONTROLS. CAP AS INDICATED.
- ⑤ REMOVE EXISTING CONDENSATE PIPING AS INDICATED.
- ⑥ PROVIDE NEW FIRE EXTINGUISHER AS INDICATED.
- ⑦ REMOVE EXISTING PLUMBING FIXTURES AS INDICATED C/W ASSOCIATED ACCESSORIES. CAP SANITARY FLUSH AT FLOOR. CAP DOW, DHW & VENT ABOVE CEILING LEVEL.
- ⑧ REMOVE EXISTING SANITARY PIPE, CAP FLOOR WITH FLOOR.