

**Ottawa Walls Repairs 2015 (Ottawa, Ontario)**  
**R.079197.001, Solicitation No: EQ754-161305/A**

Addendum Information

- Item 1 - Specification Section 05 52 20- 2.4.1 & 2.5.1 asks for galvanizing & powder coating of the handrail. Drawing 107 Note 7 states Standard Pipe painted black. These are two different systems, which actually applies?

**The specifications govern.** DWG 107 is a reference drawing for the concrete line, expansion and lamp posts fabrication and sizing.

- Item 2 - The Pedestrian Pathway to be used as outlined on drawing 101 is quite substantial and the documents state that the contractor is to maintain this pathway throughout the winter. This is specialized work requiring special equipment for plowing, sanding and/or salting. Not withstanding this, the insurance premium for us to cover this requirement will be astronomical. The NCC currently plows this pathway, why are they not going to continue to do so?

Replace text within Specification Section 01 11 00, item 1.27.6.1 with following text:

**The Municipality in conjunction with the NCC will provide snow removal for the pedestrian detour pathway, provided its surface is in fair condition and will not promote damage to their equipment or the pathway itself. Contractor is to maintain all temporary surfaces installed for pedestrian detour in good condition and maintain associated signage, lighting and barriers in place for the duration of the project.**